

PURVANCHAL VIDYUT VITARAN NIGAM LTD.

SCHEME FOR
HOUSEHOLD ELECTRIFICATION
DISTRICT : Azamgarh (UTTAR PRADESH)

DEEN DAYAL UPADHYAYA GRAM JYOTI YOJANA

Table of Contents

Sl.No.	Format No.	Name	Page No.
1	A	General Information	1
2	A(I)	Brief Writeup	2
3	A(II)	Minutes	2
4	A(III)	Pert Chart	2
5	A(IV)	Certificate	2
6	A(V)	Basic Details of District	2
7	A(VI)	Abstract : Scope of Work & Estimated Cost	4
8	A(VII)	Financial Bankability	39
9	B	Electrification of UE villages	41
10	B(I)	Block-wise coverage of villages	42
11	B(II)	Villagewise/Habitation wise coverage	44
12	B(III)	Existing Habitation Wise Infrastructure	44
13	B(IV)	Village Wise/Habitation Proposed Works	44
14	B(V)	Existing REDB Infrastructure	44
15	B(VI)	Block-Wise Substation	48
16	B(VII)	Feederwise DTs	50
17	C	Feeder Segregation	58
18	C(I)	Details of New 11 KV or 22 KV Lines	59
19	C(II)	Works Proposed Under Feeder Separation	65
20	D	Connecting unconnected RHHs	196
21	D(I)	Block-wise coverage of villages	197
22	D(II)	Villagewise/Habitation wise coverage	199
23	D(III)	Existing Habitation Wise Infrastructure	215
24	D(IV)	Village Wise/Habitation Proposed Works	231
25	D(V)	Existing REDB Infrastructure	276
26	D(VI)	Block-Wise Substation	280
27	D(VII)	Eligibility for Augmentation of Existing 33/11 KV Substations	282
28	D(VIII)	Feederwise DTs	310
29	E	Metering	318
30	E(I)	DTR Metering	319
31	E(II)	Consumer Metering	405
32	E(III)	Feeder Metering	412
33	F	System Strengthening and Augmentation	414
34	F(I)	Block-Wise Substation	415
35	F(II)	New 33 (or 66) KV REDB Works Proposed	417

36	F(III)	Proposed Augumentation of Existing Sub-station	418
37	F(IV)	EHV Substation Feeding the District	420
38	F(V)	Districtwise Details of Existing 66 KV or 33 KV Lines	425
39	F(VI)	Districtwise Details of Existing 11 KV or 22 KV Lines	428
40	F(VII)	Details of New 66 KV or 33 KV Lines	436
41	F(VIII)	Details of New 11 KV or 22 KV Lines	437
42	F(IX)	Augmentation of 66 KV or 33 KV Lines	438
43	G	SAGY	439
44	G(I)	Block-wise coverage of villages	440
45	G(II)	Villagewise/Habitation wise coverage	442
46	G(III)	Existing Habitation Wise Infrastructure	445
47	G(IV)	Village Wise/Habitation Proposed Works	448

Section -A
Basic Details of District
State : UTTAR PRADESH
District : Azamgarh

Basic Details of District

State : UTTAR PRADESH
District : Azamgarh

Name of Project Implementing Agency	Purvanchal Vidyut Vitaran Nigam Ltd.
Name of DISCOM	Purvanchal Vidyut Vitaran Nigam Ltd.
Name of State	UTTAR PRADESH
Name of District	Azamgarh
Total Population of district	4613913
Total Geographical Area(SqKm)	4054
Percentage of Hilly area	0
Total Block in the district	20
Total Urban Town in the district	12
Total Urban Population in the district	393401
Population Of Urban Area	393401
Total Census Revenue Villages in the district	4108
Total Habitations in the district	0
Total Rural Population in the district	4220512

House Holds Details :-

Description	2001 Census	2011 Census	CAGR	Total HHs by 31.03.2015 as derived	Total HHs by 31.03.2019 as derived
Total House Holds in the district	569568	659930	2.31	764628	885936
Rural HH in the district	525339	608684	1.16	705252	817140
Urban HH in the district	44229	51246	1.15	59376	68796
Total Energised HH in the district	158272	183381	1.16	212473	246181
Urban HH electrified in the district	31801	36846	1.15	42691	49464
Rural HH electrified in the district	126471	146535	1.16	169782	196717
Balance Un-electrified Rural HH	398868	462149	0	535470	620423

Basic Details of District

State : UTTAR PRADESH
District : Azamgarh

Balance Un-electrified Urban HH	12428	14400	0	16685	19332					
Balance Total un-electrified HH in the district	0	0	0	0	0					
Status of Already Sanctioned 10th / 11th / 12th Plan Projects :-										
Plan	Un-Electrified Villages		Intensive Electrified Villages		Total Habitation		RHH Incl. BPL		BPL	
	Coverage	Achievement	Coverage	Achievement	Coverage	Achievement	Coverage	Achievement	Coverage	Achievement
10th	1940	1810	0	0	0	0	104603	50191	104603	50191
11th	0	0	0	0	0	0	0	0	0	0
12th	0	0	3310	0	8417	0	407161	0	101844	0

Abstract : Scope of Work & Estimated Cost

State : UTTAR PRADESH
District : Azamgarh

S.No.	Item of Works	Sub Item	Unit	Quantity	Unit Cost(In Lac)	Total Cost(In Lac)
	B.Feeder Seperation					
	DTR					
1	AHIRAULA-Ahiraulla	25 KVA(3 Ph)	Nos.	34	2.64	89.76
2	AHIRAULA-Atraulia	25 KVA(3 Ph)	Nos.	19	2.64	50.16
3	AHIRAULA-Kaptanganj	25 KVA(3 Ph)	Nos.	13	2.64	34.32
4	AMUWARI NARAINPUR-Bhuana	25 KVA(3 Ph)	Nos.	15	2.64	39.6
5	AMUWARI NARAINPUR-East	25 KVA(3 Ph)	Nos.	27	2.64	71.28
6	AMUWARI NARAINPUR-West	25 KVA(3 Ph)	Nos.	11	2.64	29.04
7	ATRAULIA-ATRAULIA	25 KVA(3 Ph)	Nos.	17	2.64	44.88
8	ATRAULIA-EAST	25 KVA(3 Ph)	Nos.	20	2.64	52.8
9	ATRAULIA-NORTH	25 KVA(3 Ph)	Nos.	12	2.64	31.68
10	ATRAULIA-WEST	25 KVA(3 Ph)	Nos.	20	2.64	52.8
11	ATRAULIA-West 2	25 KVA(3 Ph)	Nos.	22	2.64	58.08
12	BAGH BAHAR-Kalan	25 KVA(3 Ph)	Nos.	13	2.64	34.32
13	BAGH BAHAR-Khairuddinpur	25 KVA(3 Ph)	Nos.	11	2.64	29.04
14	BAGH BAHAR-Sahdulla	25 KVA(3 Ph)	Nos.	19	2.64	50.16
15	BARDAH-Bahadurpur	25 KVA(3 Ph)	Nos.	19	2.64	50.16
16	BARDAH-Bardah	25 KVA(3 Ph)	Nos.	22	2.64	58.08
17	BARDAH-Jiblee	25 KVA(3 Ph)	Nos.	14	2.64	36.96
18	BHAWAR NATH-Heera palti	25 KVA(3 Ph)	Nos.	17	2.64	44.88
19	BHAWAR NATH-Kandharapur	25 KVA(3 Ph)	Nos.	14	2.64	36.96
20	BILARIYAGANJ-East	25 KVA(3 Ph)	Nos.	23	2.64	60.72
21	BILARIYAGANJ-North	25 KVA(3 Ph)	Nos.	26	2.64	68.64

Abstract : Scope of Work & Estimated Cost

State : UTTAR PRADESH
District : Azamgarh

S.No.	Item of Works	Sub Item	Unit	Quantity	Unit Cost(In Lac)	Total Cost(In Lac)
22	BILARIYAGANJ-West	25 KVA(3 Ph)	Nos.	27	2.64	71.28
23	CHANDESHWAR-Karanpur	25 KVA(3 Ph)	Nos.	20	2.64	52.8
24	CHANDESHWAR-Nibi	25 KVA(3 Ph)	Nos.	26	2.64	68.64
25	CHANDESHWAR-Sameda	25 KVA(3 Ph)	Nos.	5	2.64	13.2
26	CHHAU-Belu	25 KVA(3 Ph)	Nos.	34	2.64	89.76
27	CHHAU-Chhau	25 KVA(3 Ph)	Nos.	10	2.64	26.4
28	CHHAU-Gambhirpur	25 KVA(3 Ph)	Nos.	14	2.64	36.96
29	DATTATREYA-Mirzapur	25 KVA(3 Ph)	Nos.	19	2.64	50.16
30	DATTATREYA-Mohnathpur	25 KVA(3 Ph)	Nos.	19	2.64	50.16
31	DATTATREYA-Nizamabad	25 KVA(3 Ph)	Nos.	17	2.64	44.88
32	DEOGAON-Basahi	25 KVA(3 Ph)	Nos.	14	2.64	36.96
33	DEOGAON-Deogaon	25 KVA(3 Ph)	Nos.	20	2.64	52.8
34	DEOGAON-Kanhjit	25 KVA(3 Ph)	Nos.	30	2.64	79.2
35	GADDO PUR-Gaddo Pur	25 KVA(3 Ph)	Nos.	20	2.64	52.8
36	GADDO PUR-Palthi	25 KVA(3 Ph)	Nos.	20	2.64	52.8
37	GOPALGANJ-Gopalganj	25 KVA(3 Ph)	Nos.	16	2.64	42.24
38	GOPALGANJ-Marfora	25 KVA(3 Ph)	Nos.	18	2.64	47.52
39	GOSAI KI BAZAR-Gosai ki Bazar	25 KVA(3 Ph)	Nos.	11	2.64	29.04
40	GOSAI KI BAZAR-Pandaha	25 KVA(3 Ph)	Nos.	15	2.64	39.6
41	GOSAI KI BAZAR-Ubarpur	25 KVA(3 Ph)	Nos.	11	2.64	29.04
42	GOTHAWAN-Gothawan	25 KVA(3 Ph)	Nos.	14	2.64	36.96
43	GOTHAWAN-Nandaoh	25 KVA(3 Ph)	Nos.	19	2.64	50.16
44	JAHANGANJ-Godhawra	25 KVA(3 Ph)	Nos.	20	2.64	52.8

Abstract : Scope of Work & Estimated Cost

State : UTTAR PRADESH
District : Azamgarh

S.No.	Item of Works	Sub Item	Unit	Quantity	Unit Cost(In Lac)	Total Cost(In Lac)
45	JAHANGANJ-Jahanaganj	25 KVA(3 Ph)	Nos.	15	2.64	39.6
46	JAHANGANJ-Parasi	25 KVA(3 Ph)	Nos.	22	2.64	58.08
47	JAHANGANJ-Sumbhi	25 KVA(3 Ph)	Nos.	17	2.64	44.88
48	JIRAKPUR-Agehta	25 KVA(3 Ph)	Nos.	17	2.64	44.88
49	JIRAKPUR-Sikraura	25 KVA(3 Ph)	Nos.	20	2.64	52.8
50	JIYANPUR-East	25 KVA(3 Ph)	Nos.	18	2.64	47.52
51	JIYANPUR-North	25 KVA(3 Ph)	Nos.	17	2.64	44.88
52	JIYANPUR-West	25 KVA(3 Ph)	Nos.	15	2.64	39.6
53	KANDHARPUR-Azampur	25 KVA(3 Ph)	Nos.	9	2.64	23.76
54	KANDHARPUR-Kandharpur	25 KVA(3 Ph)	Nos.	13	2.64	34.32
55	KANILA-Barora	25 KVA(3 Ph)	Nos.	19	2.64	50.16
56	KANILA-Jigarsandi	25 KVA(3 Ph)	Nos.	18	2.64	47.52
57	KAPTANGANJ-Bhawanpur	25 KVA(3 Ph)	Nos.	15	2.64	39.6
58	KAPTANGANJ-Deoria	25 KVA(3 Ph)	Nos.	11	2.64	29.04
59	KAPTANGANJ-kaptanganj	25 KVA(3 Ph)	Nos.	14	2.64	36.96
60	KAPTANGANJ-Mehmauni	25 KVA(3 Ph)	Nos.	10	2.64	26.4
61	KARSARA-Bela	25 KVA(3 Ph)	Nos.	5	2.64	13.2
62	KARSARA-Chutara	25 KVA(3 Ph)	Nos.	8	2.64	21.12
63	KARSARA-Karsara	25 KVA(3 Ph)	Nos.	37	2.64	97.68
64	KHAMARIYA-Kamharia	25 KVA(3 Ph)	Nos.	26	2.64	68.64
65	KHAMARIYA-Khatahan	25 KVA(3 Ph)	Nos.	21	2.64	55.44
66	LALGANJ-Devgaon	25 KVA(3 Ph)	Nos.	10	2.64	26.4
67	LALGANJ-Gosai bazar	25 KVA(3 Ph)	Nos.	21	2.64	55.44

Abstract : Scope of Work & Estimated Cost

State : UTTAR PRADESH
District : Azamgarh

S.No.	Item of Works	Sub Item	Unit	Quantity	Unit Cost(In Lac)	Total Cost(In Lac)
68	LALGANJ-Lumbhua	25 KVA(3 Ph)	Nos.	22	2.64	58.08
69	LALGANJ-Sonwar	25 KVA(3 Ph)	Nos.	19	2.64	50.16
70	LATGHAT-Bardeeha	25 KVA(3 Ph)	Nos.	17	2.64	44.88
71	LATGHAT-Kaithauli	25 KVA(3 Ph)	Nos.	14	2.64	36.96
72	LATGHAT-Mahula	25 KVA(3 Ph)	Nos.	16	2.64	42.24
73	MAHRAJGANJ-East	25 KVA(3 Ph)	Nos.	36	2.64	95.04
74	MAHRAJGANJ-North	25 KVA(3 Ph)	Nos.	19	2.64	50.16
75	MAHRAJGANJ-West	25 KVA(3 Ph)	Nos.	22	2.64	58.08
76	MAHRAJGANJ-World bank	25 KVA(3 Ph)	Nos.	14	2.64	36.96
77	MAHUL-Bazar Gosai	25 KVA(3 Ph)	Nos.	10	2.64	26.4
78	MALTADI-Basgaon	25 KVA(3 Ph)	Nos.	29	2.64	76.56
79	MALTADI-North	25 KVA(3 Ph)	Nos.	11	2.64	29.04
80	MALTADI-West	25 KVA(3 Ph)	Nos.	13	2.64	34.32
81	MANJHARI-Dhania kundi	25 KVA(3 Ph)	Nos.	5	2.64	13.2
82	MANJHARI-Kariawar	25 KVA(3 Ph)	Nos.	8	2.64	21.12
83	MANJHARI-Manjhari	25 KVA(3 Ph)	Nos.	5	2.64	13.2
84	MARTINGANJ-Bakhara Feeder	25 KVA(3 Ph)	Nos.	24	2.64	63.36
85	MARTINGANJ-Belwana Feeder	25 KVA(3 Ph)	Nos.	29	2.64	76.56
86	MARTINGANJ-Siswara Feeder	25 KVA(3 Ph)	Nos.	14	2.64	36.96
87	MAU KUTUBPUR-Bazar Gosai	25 KVA(3 Ph)	Nos.	24	2.64	63.36
88	MAU KUTUBPUR-North	25 KVA(3 Ph)	Nos.	14	2.64	36.96
89	MAU KUTUBPUR-West	25 KVA(3 Ph)	Nos.	5	2.64	13.2
90	MDIYAPAR-Badhiya	25 KVA(3 Ph)	Nos.	11	2.64	29.04

Abstract : Scope of Work & Estimated Cost

State : UTTAR PRADESH
District : Azamgarh

S.No.	Item of Works	Sub Item	Unit	Quantity	Unit Cost(In Lac)	Total Cost(In Lac)
91	MDIYAPAR-Bhedaura	25 KVA(3 Ph)	Nos.	15	2.64	39.6
92	MDIYAPAR-Karsara	25 KVA(3 Ph)	Nos.	12	2.64	31.68
93	MEH NAGAR-Chakwara	25 KVA(3 Ph)	Nos.	16	2.64	42.24
94	MEH NAGAR-Kharag Pur	25 KVA(3 Ph)	Nos.	13	2.64	34.32
95	MEH NAGAR-Laudah	25 KVA(3 Ph)	Nos.	12	2.64	31.68
96	MEHNAJPUR-Mehnaj Pur	25 KVA(3 Ph)	Nos.	14	2.64	36.96
97	MEHNAJPUR-Nath PUR	25 KVA(3 Ph)	Nos.	21	2.64	55.44
98	MEHNAJPUR-Rowa para	25 KVA(3 Ph)	Nos.	21	2.64	55.44
99	MOHABBATPUR-Bamhaur	25 KVA(3 Ph)	Nos.	18	2.64	47.52
100	MOHABBATPUR-Shahgarh	25 KVA(3 Ph)	Nos.	14	2.64	36.96
101	MUBARAKPUR-Newada Rural	25 KVA(3 Ph)	Nos.	23	2.64	60.72
102	MUBARAKPUR-Sthiyaon	25 KVA(3 Ph)	Nos.	18	2.64	47.52
103	MUHAMMAD PUR-Bindra Bazar	25 KVA(3 Ph)	Nos.	6	2.64	15.84
104	MUHAMMAD PUR-North	25 KVA(3 Ph)	Nos.	14	2.64	36.96
105	MUHAMMAD PUR-Rowa	25 KVA(3 Ph)	Nos.	18	2.64	47.52
106	MUHAMMAD PUR-South	25 KVA(3 Ph)	Nos.	23	2.64	60.72
107	ORA-Deohatta	25 KVA(3 Ph)	Nos.	5	2.64	13.2
108	ORA-Ora	25 KVA(3 Ph)	Nos.	6	2.64	15.84
109	ORA-Sarai Barkat	25 KVA(3 Ph)	Nos.	6	2.64	15.84
110	PALAHANA-Lhua	25 KVA(3 Ph)	Nos.	27	2.64	71.28
111	PALAHANA-Palahana	25 KVA(3 Ph)	Nos.	26	2.64	68.64
112	PATWADH KAUTAK-EAST	25 KVA(3 Ph)	Nos.	15	2.64	39.6
113	PATWADH KAUTAK-South	25 KVA(3 Ph)	Nos.	14	2.64	36.96

Abstract : Scope of Work & Estimated Cost

State : UTTAR PRADESH
District : Azamgarh

S.No.	Item of Works	Sub Item	Unit	Quantity	Unit Cost(In Lac)	Total Cost(In Lac)
114	PATWADH KAUTAK-West	25 KVA(3 Ph)	Nos.	22	2.64	58.08
115	PAWAI-Balaipur Feeder	25 KVA(3 Ph)	Nos.	29	2.64	76.56
116	PAWAI-Belwai Feeder	25 KVA(3 Ph)	Nos.	28	2.64	73.92
117	PAWAI-Mahul Feeder	25 KVA(3 Ph)	Nos.	32	2.64	84.48
118	PAWAI-Pawai	25 KVA(3 Ph)	Nos.	10	2.64	26.4
119	PHOOLPUR-East	25 KVA(3 Ph)	Nos.	10	2.64	26.4
120	PHOOLPUR-North	25 KVA(3 Ph)	Nos.	20	2.64	52.8
121	PHOOLPUR-South	25 KVA(3 Ph)	Nos.	11	2.64	29.04
122	PHOOLPUR-West	25 KVA(3 Ph)	Nos.	23	2.64	60.72
123	PUSHP NAGAR-Deedarganj	25 KVA(3 Ph)	Nos.	16	2.64	42.24
124	PUSHP NAGAR-Sikraura	25 KVA(3 Ph)	Nos.	14	2.64	36.96
125	RANI KI SARAI-Rani ki sarai	25 KVA(3 Ph)	Nos.	14	2.64	36.96
126	RANI KI SARAI-Sonwara	25 KVA(3 Ph)	Nos.	17	2.64	44.88
127	RANI KI SARAI-Vasti	25 KVA(3 Ph)	Nos.	11	2.64	29.04
128	RANIPUR-Khatoliya Feeder	25 KVA(3 Ph)	Nos.	4	2.64	10.56
129	RANIPUR-Koilsa Feeder	25 KVA(3 Ph)	Nos.	17	2.64	44.88
130	RANIPUR-Tonari Feeder	25 KVA(3 Ph)	Nos.	16	2.64	42.24
131	RASEPUR-Bongariya	25 KVA(3 Ph)	Nos.	17	2.64	44.88
132	RASEPUR-Kanchanpur	25 KVA(3 Ph)	Nos.	27	2.64	71.28
133	RASEPUR-Sherpur	25 KVA(3 Ph)	Nos.	22	2.64	58.08
134	RAUNAPUR-East	25 KVA(3 Ph)	Nos.	19	2.64	50.16
135	RAUNAPUR-South	25 KVA(3 Ph)	Nos.	26	2.64	68.64
136	RAUNAPUR-West	25 KVA(3 Ph)	Nos.	17	2.64	44.88

Abstract : Scope of Work & Estimated Cost

State : UTTAR PRADESH
District : Azamgarh

S.No.	Item of Works	Sub Item	Unit	Quantity	Unit Cost(In Lac)	Total Cost(In Lac)
137	SARAI MEER-Basti	25 KVA(3 Ph)	Nos.	11	2.64	29.04
138	SARAI MEER-Nandau	25 KVA(3 Ph)	Nos.	20	2.64	52.8
139	SHEIKHPURA-Ahopatti	25 KVA(3 Ph)	Nos.	32	2.64	84.48
140	SHEIKHPURA-Badhapur	25 KVA(3 Ph)	Nos.	10	2.64	26.4
141	SHERPUR-Parsaha	25 KVA(3 Ph)	Nos.	5	2.64	13.2
142	SHERPUR-Sherpur Kuti	25 KVA(3 Ph)	Nos.	8	2.64	21.12
143	SIKHULA-Chimkuni	25 KVA(3 Ph)	Nos.	10	2.64	26.4
144	SIKHULA-Sultanipuri	25 KVA(3 Ph)	Nos.	11	2.64	29.04
145	SOFIPUR-Nizamabad	25 KVA(3 Ph)	Nos.	16	2.64	42.24
146	SOFIPUR-Nizamabad 2	25 KVA(3 Ph)	Nos.	29	2.64	76.56
147	SOFIPUR-Semari	25 KVA(3 Ph)	Nos.	5	2.64	13.2
148	SOFIPUR-Tahbarpur	25 KVA(3 Ph)	Nos.	23	2.64	60.72
149	TARWA-Meh Nagar	25 KVA(3 Ph)	Nos.	12	2.64	31.68
150	TARWA-Mehnajpur	25 KVA(3 Ph)	Nos.	14	2.64	36.96
151	TARWA-Sidhauna	25 KVA(3 Ph)	Nos.	14	2.64	36.96
152	TEHSIL BURHANPUR-Basgan	25 KVA(3 Ph)	Nos.	11	2.64	29.04
153	TEHSIL BURHANPUR-Bheelampur	25 KVA(3 Ph)	Nos.	5	2.64	13.2
154	TEHSIL BURHANPUR-Makhanaha	25 KVA(3 Ph)	Nos.	23	2.64	60.72
155	THEKMA-Sarai Mohan	25 KVA(3 Ph)	Nos.	17	2.64	44.88
156	THEKMA-Tahbarpur	25 KVA(3 Ph)	Nos.	22	2.64	58.08
157	THEKMA-Thekma	25 KVA(3 Ph)	Nos.	21	2.64	55.44
158	ZAFFARPUR-South	25 KVA(3 Ph)	Nos.	36	2.64	95.04
Sub-Total (DTR)				2700		7128

Abstract : Scope of Work & Estimated Cost

State : UTTAR PRADESH
District : Azamgarh

S.No.	Item of Works	Sub Item	Unit	Quantity	Unit Cost(In Lac)	Total Cost(In Lac)
	New 11 KV Bay					
159	New Feeder-1(AHIRAULA To New Location)	11 KV Bay	Nos.	1	5.69	5.69
160	New Feeder-1(Atraulia To New Location)	11 KV Bay	Nos.	1	5.69	5.69
161	New Feeder-1(BARDAH To New Location)	11 KV Bay	Nos.	1	5.69	5.69
162	New Feeder-1(BHAWAR NATH To New Location)	11 KV Bay	Nos.	1	5.69	5.69
163	New Feeder-1(BILARIYAGANJ To New Location)	11 KV Bay	Nos.	1	5.69	5.69
164	New Feeder-1(CHANDESHWAR To New Location)	11 KV Bay	Nos.	1	5.69	5.69
165	New Feeder-1(CHHAU To New Location)	11 KV Bay	Nos.	1	5.69	5.69
166	New Feeder-1(DATTATREYA To New Location)	11 KV Bay	Nos.	1	5.69	5.69
167	New Feeder-1(DEOGAON To New Location)	11 KV Bay	Nos.	1	5.69	5.69
168	New Feeder-1(GADDO PUR To New Location)	11 KV Bay	Nos.	1	5.69	5.69
169	New Feeder-1(GOPALGANJ To New Location)	11 KV Bay	Nos.	1	5.69	5.69
170	New Feeder-1(GOSAI KI BAZAR To New Location)	11 KV Bay	Nos.	1	5.69	5.69
171	New Feeder-1(GOTHAWAN To New Location)	11 KV Bay	Nos.	1	5.69	5.69
172	New Feeder-1(JAHANGANJ To New Location)	11 KV Bay	Nos.	1	5.69	5.69
173	New Feeder-1(JIRAKPUR To New Location)	11 KV Bay	Nos.	1	5.69	5.69
174	New Feeder-1(KANDHARPUR To New Location)	11 KV Bay	Nos.	1	5.69	5.69
175	New Feeder-1(KANILA To New Location)	11 KV Bay	Nos.	1	5.69	5.69
176	New Feeder-1(KAPTANGANJ To New Location)	11 KV Bay	Nos.	1	5.69	5.69
177	New Feeder-1(KARSARA To New Location)	11 KV Bay	Nos.	1	5.69	5.69
178	New Feeder-1(Khairuddinpur To New Location)	11 KV Bay	Nos.	1	5.69	5.69
179	New Feeder-1(KHAMARIYA To New Location)	11 KV Bay	Nos.	1	5.69	5.69

Abstract : Scope of Work & Estimated Cost

State : UTTAR PRADESH
District : Azamgarh

S.No.	Item of Works	Sub Item	Unit	Quantity	Unit Cost(In Lac)	Total Cost(In Lac)
180	New Feeder-1(LALGANJ To New Location)	11 KV Bay	Nos.	1	5.69	5.69
181	New Feeder-1(MAHRAJGANJ To New Location)	11 KV Bay	Nos.	1	5.69	5.69
182	New Feeder-1(MALTADI To New Location)	11 KV Bay	Nos.	1	5.69	5.69
183	New Feeder-1(MANJHARI To New Location)	11 KV Bay	Nos.	1	5.69	5.69
184	New Feeder-1(Martinganj To New Location)	11 KV Bay	Nos.	1	5.69	5.69
185	New Feeder-1(Mau Kutubpur To New Location)	11 KV Bay	Nos.	1	5.69	5.69
186	New Feeder-1(Mdiyapar To New Location)	11 KV Bay	Nos.	1	5.69	5.69
187	New Feeder-1(MEH NAGAR To New Location)	11 KV Bay	Nos.	1	5.69	5.69
188	New Feeder-1(MEHNAJPUR To New Location)	11 KV Bay	Nos.	1	5.69	5.69
189	New Feeder-1(MOHABBATPUR To New Location)	11 KV Bay	Nos.	1	5.69	5.69
190	New Feeder-1(MUBARAKPUR To New Location)	11 KV Bay	Nos.	1	5.69	5.69
191	New Feeder-1(MUHAMMAD PUR To New Location)	11 KV Bay	Nos.	1	5.69	5.69
192	New Feeder-1(ORA To New Location)	11 KV Bay	Nos.	1	5.69	5.69
193	New Feeder-1(PALAHANA To New Location)	11 KV Bay	Nos.	1	5.69	5.69
194	New Feeder-1(PATWADH KAUTAK To New Location)	11 KV Bay	Nos.	1	5.69	5.69
195	New Feeder-1(Pawai To New Location)	11 KV Bay	Nos.	1	5.69	5.69
196	New Feeder-1(PHOOLPUR To New Location)	11 KV Bay	Nos.	1	5.69	5.69
197	New Feeder-1(PUSHP NAGAR To New Location)	11 KV Bay	Nos.	1	5.69	5.69
198	New Feeder-1(RANI KI SARAI To New Location)	11 KV Bay	Nos.	1	5.69	5.69
199	New Feeder-1(RANIPUR To New Location)	11 KV Bay	Nos.	1	5.69	5.69
200	New Feeder-1(RASEPUR To New Location)	11 KV Bay	Nos.	1	5.69	5.69

Abstract : Scope of Work & Estimated Cost

State : UTTAR PRADESH
District : Azamgarh

S.No.	Item of Works	Sub Item	Unit	Quantity	Unit Cost(In Lac)	Total Cost(In Lac)
201	New Feeder-1(RAUNAPUR To New Location)	11 KV Bay	Nos.	1	5.69	5.69
202	New Feeder-1(SARAI MEER To New Location)	11 KV Bay	Nos.	1	5.69	5.69
203	New Feeder-1(Sheikhpura To New Location)	11 KV Bay	Nos.	1	5.69	5.69
204	New Feeder-1(SHERPUR To New Location)	11 KV Bay	Nos.	1	5.69	5.69
205	New Feeder-1(SIKHULA To New Location)	11 KV Bay	Nos.	1	5.69	5.69
206	New Feeder-1(SOFIPUR To New Location)	11 KV Bay	Nos.	1	5.69	5.69
207	New feeder-1(TARWA To New Location)	11 KV Bay	Nos.	1	5.69	5.69
208	New Feeder-1(TEHSIL BURHANPUR To New Location)	11 KV Bay	Nos.	1	5.69	5.69
209	New Feeder-1(THEKMA To New Location)	11 KV Bay	Nos.	1	5.69	5.69
210	New Feeder-1(ZAFFARPUR To New Location)	11 KV Bay	Nos.	1	5.69	5.69
211	New Feeder-2(BHAWAR NATH To New Location)	11 KV Bay	Nos.	1	5.69	5.69
212	New Feeder-2(BILARIYAGANJ To New Location)	11 KV Bay	Nos.	1	5.69	5.69
213	New Feeder-2(CHANDESHWAR To New Location)	11 KV Bay	Nos.	1	5.69	5.69
214	New Feeder-2(JAHANGANJ To New Location)	11 KV Bay	Nos.	1	5.69	5.69
215	New Feeder-2(LALGANJ To New Location)	11 KV Bay	Nos.	1	5.69	5.69
216	New Feeder-2(MAHUL To New Loaction)	11 KV Bay	Nos.	1	5.69	5.69
217	New Feeder-2(Mdiyapar To New Location)	11 KV Bay	Nos.	1	5.69	5.69
218	New Feeder-2(MEH NAGAR To New Location)	11 KV Bay	Nos.	1	5.69	5.69
219	New Feeder-2(MOHABBATPUR To New Location)	11 KV Bay	Nos.	1	5.69	5.69
220	New Feeder-2(MUBARAKPUR To New Location)	11 KV Bay	Nos.	1	5.69	5.69
221	New Feeder-2(PHOOLPUR To New Location)	11 KV Bay	Nos.	1	5.69	5.69

Abstract : Scope of Work & Estimated Cost

State : UTTAR PRADESH
District : Azamgarh

S.No.	Item of Works	Sub Item	Unit	Quantity	Unit Cost(In Lac)	Total Cost(In Lac)
222	New Feeder-2(RANI KI SARAI To New Location)	11 KV Bay	Nos.	1	5.69	5.69
223	New Feeder-2(SARAI MEER To New Location)	11 KV Bay	Nos.	1	5.69	5.69
Sub-Total (New 11 KV Bay)				65		369.85
	New 11 KV Line					
224	New Feeder-1(AHIRAULA To New Location)	PCC POLES WITH RABBIT CONDUCTOR	Kms.	15	4.33	64.95
225	New Feeder-1(AMUWARI NARAINPUR To New Location)	PCC POLES WITH RABBIT CONDUCTOR	Kms.	20	4.33	86.6
226	New Feeder-1(Atraulia To New Location)	PCC POLES WITH RABBIT CONDUCTOR	Kms.	11.4	4.33	49.362
227	New Feeder-1(BARDAH To New Location)	PCC POLES WITH RABBIT CONDUCTOR	Kms.	32	4.33	138.56
228	New Feeder-1(BHAWAR NATH To New Location)	PCC POLES WITH RABBIT CONDUCTOR	Kms.	14	4.33	60.62
229	New Feeder-1(BILARIYAGANJ To New Location)	PCC POLES WITH RABBIT CONDUCTOR	Kms.	13	4.33	56.29
230	New Feeder-1(CHANDESHWAR To New Location)	PCC POLES WITH RABBIT CONDUCTOR	Kms.	16	4.33	69.28
231	New Feeder-1(CHHAU To New Location)	PCC POLES WITH RABBIT CONDUCTOR	Kms.	10	4.33	43.3
232	New Feeder-1(DATTATREYA To New Location)	PCC POLES WITH RABBIT CONDUCTOR	Kms.	14	4.33	60.62
233	New Feeder-1(DEOGAON To New Location)	PCC POLES WITH RABBIT CONDUCTOR	Kms.	10.74	4.33	46.5042
234	New Feeder-1(GADDO PUR To New Location)	PCC POLES WITH RABBIT CONDUCTOR	Kms.	15	4.33	64.95
235	New Feeder-1(GOPALGANJ To New Location)	PCC POLES WITH RABBIT CONDUCTOR	Kms.	10	4.33	43.3
236	New Feeder-1(GOSAI KI BAZAR To New Location)	PCC POLES WITH RABBIT CONDUCTOR	Kms.	12	4.33	51.96
237	New Feeder-1(GOTHAWAN To New Location)	PCC POLES WITH RABBIT CONDUCTOR	Kms.	15.3	4.33	66.249
238	New Feeder-1(JAHANGANJ To New Location)	PCC POLES WITH RABBIT CONDUCTOR	Kms.	11	4.33	47.63
239	New Feeder-1(JIRAKPUR To New Location)	PCC POLES WITH RABBIT CONDUCTOR	Kms.	10.2	4.33	44.166
240	New Feeder-1(JIYANPUR To New Location)	PCC POLES WITH RABBIT CONDUCTOR	Kms.	10	4.33	43.3

Abstract : Scope of Work & Estimated Cost

State : UTTAR PRADESH
District : Azamgarh

S.No.	Item of Works	Sub Item	Unit	Quantity	Unit Cost(In Lac)	Total Cost(In Lac)
241	New Feeder-1(KANDHARPUR To New Location)	PCC POLES WITH RABBIT CONDUCTOR	Kms.	10.2	4.33	44.166
242	New Feeder-1(KANILA To New Location)	PCC POLES WITH RABBIT CONDUCTOR	Kms.	12	4.33	51.96
243	New Feeder-1(KAPTANGANJ To New Location)	PCC POLES WITH RABBIT CONDUCTOR	Kms.	10.2	4.33	44.166
244	New Feeder-1(KARSARA To New Location)	PCC POLES WITH RABBIT CONDUCTOR	Kms.	7.8	4.33	33.774
245	New Feeder-1(Khairuddinpur To New Location)	PCC POLES WITH RABBIT CONDUCTOR	Kms.	20	4.33	86.6
246	New Feeder-1(KHAMARIYA To New Location)	PCC POLES WITH RABBIT CONDUCTOR	Kms.	10.2	4.33	44.166
247	New Feeder-1(LALGANJ To New Location)	PCC POLES WITH RABBIT CONDUCTOR	Kms.	10	4.33	43.3
248	New Feeder-1(LATGHAT To New Location)	PCC POLES WITH RABBIT CONDUCTOR	Kms.	10	4.33	43.3
249	New Feeder-1(MAHRAJGANJ To New Location)	PCC POLES WITH RABBIT CONDUCTOR	Kms.	13	4.33	56.29
250	New Feeder-1(MALTADI To New Location)	PCC POLES WITH RABBIT CONDUCTOR	Kms.	15	4.33	64.95
251	New Feeder-1(MANJHARI To New Location)	PCC POLES WITH RABBIT CONDUCTOR	Kms.	12	4.33	51.96
252	New Feeder-1(Martinganj To New Location)	PCC POLES WITH RABBIT CONDUCTOR	Kms.	34	4.33	147.22
253	New Feeder-1(Mau Kutubpur To New Location)	PCC POLES WITH RABBIT CONDUCTOR	Kms.	16	4.33	69.28
254	New Feeder-1(Mdiyapar To New Location)	PCC POLES WITH RABBIT CONDUCTOR	Kms.	12	4.33	51.96
255	New Feeder-1(MEH NAGAR To New Location)	PCC POLES WITH RABBIT CONDUCTOR	Kms.	8	4.33	34.64
256	New Feeder-1(MEHNAJPUR To New Location)	PCC POLES WITH RABBIT CONDUCTOR	Kms.	20	4.33	86.6
257	New Feeder-1(MOHABBATPUR To New Location)	PCC POLES WITH RABBIT CONDUCTOR	Kms.	17	4.33	73.61
258	New Feeder-1(MUBARAKPUR To New Location)	PCC POLES WITH RABBIT CONDUCTOR	Kms.	15	4.33	64.95
259	New Feeder-1(MUHAMMAD PUR To New Location)	PCC POLES WITH RABBIT CONDUCTOR	Kms.	28	4.33	121.24
260	New Feeder-1(ORA To New Location)	PCC POLES WITH RABBIT CONDUCTOR	Kms.	16	4.33	69.28
261	New Feeder-1(PALAHANA To New Location)	PCC POLES WITH RABBIT CONDUCTOR	Kms.	10.2	4.33	44.166

Abstract : Scope of Work & Estimated Cost

State : UTTAR PRADESH
District : Azamgarh

S.No.	Item of Works	Sub Item	Unit	Quantity	Unit Cost(In Lac)	Total Cost(In Lac)
262	New Feeder-1(PATWADH KAUTAK To New Location)	PCC POLES WITH RABBIT CONDUCTOR	Kms.	9	4.33	38.97
263	New Feeder-1(Pawai To New Location)	PCC POLES WITH RABBIT CONDUCTOR	Kms.	13	4.33	56.29
264	New Feeder-1(PHOOLPUR To New Location)	PCC POLES WITH RABBIT CONDUCTOR	Kms.	24	4.33	103.92
265	New Feeder-1(PUSHP NAGAR To New Location)	PCC POLES WITH RABBIT CONDUCTOR	Kms.	13	4.33	56.29
266	New Feeder-1(RANI KI SARAI To New Location)	PCC POLES WITH RABBIT CONDUCTOR	Kms.	11	4.33	47.63
267	New Feeder-1(RANIPUR To New Location)	PCC POLES WITH RABBIT CONDUCTOR	Kms.	14.4	4.33	62.352
268	New Feeder-1(RASEPUR To New Location)	PCC POLES WITH RABBIT CONDUCTOR	Kms.	13	4.33	56.29
269	New Feeder-1(RAUNAPUR To New Location)	PCC POLES WITH RABBIT CONDUCTOR	Kms.	11	4.33	47.63
270	New Feeder-1(SARAI MEER To New Location)	PCC POLES WITH RABBIT CONDUCTOR	Kms.	9	4.33	38.97
271	New Feeder-1(Sheikhpura To New Location)	PCC POLES WITH RABBIT CONDUCTOR	Kms.	15	4.33	64.95
272	New Feeder-1(SHERPUR To New Location)	PCC POLES WITH RABBIT CONDUCTOR	Kms.	10	4.33	43.3
273	New Feeder-1(SIKHULA To New Location)	PCC POLES WITH RABBIT CONDUCTOR	Kms.	20	4.33	86.6
274	New Feeder-1(SOFIPUR To New Location)	PCC POLES WITH RABBIT CONDUCTOR	Kms.	12	4.33	51.96
275	New feeder-1(TARWA To New Location)	PCC POLES WITH RABBIT CONDUCTOR	Kms.	10.2	4.33	44.166
276	New Feeder-1(TEHSIL BURHANPUR To New Location)	PCC POLES WITH RABBIT CONDUCTOR	Kms.	11.4	4.33	49.362
277	New Feeder-1(THEKMA To New Location)	PCC POLES WITH RABBIT CONDUCTOR	Kms.	10.2	4.33	44.166
278	New Feeder-1(ZAFFARPUR To New Location)	PCC POLES WITH RABBIT CONDUCTOR	Kms.	10	4.33	43.3
279	New Feeder-2(AMUWARI NARAINPUR To New Location)	PCC POLES WITH RABBIT CONDUCTOR	Kms.	15	4.33	64.95
280	New Feeder-2(BHAWAR NATH To New Location)	PCC POLES WITH RABBIT CONDUCTOR	Kms.	17	4.33	73.61
281	New Feeder-2(BILARIYAGANJ To New Location)	PCC POLES WITH RABBIT CONDUCTOR	Kms.	12	4.33	51.96
282	New Feeder-2(CHANDESHWAR To New Location)	PCC POLES WITH RABBIT CONDUCTOR	Kms.	10	4.33	43.3

Abstract : Scope of Work & Estimated Cost

State : UTTAR PRADESH
District : Azamgarh

S.No.	Item of Works	Sub Item	Unit	Quantity	Unit Cost(In Lac)	Total Cost(In Lac)
283	New Feeder-2(JAHANGANJ To New Location)	PCC POLES WITH RABBIT CONDUCTOR	Kms.	13	4.33	56.29
284	New Feeder-2(JIYANPUR To New Location)	PCC POLES WITH RABBIT CONDUCTOR	Kms.	14	4.33	60.62
285	New Feeder-2(LALGANJ To New Location)	PCC POLES WITH RABBIT CONDUCTOR	Kms.	20	4.33	86.6
286	New Feeder-2(LATGHAT To New Location)	PCC POLES WITH RABBIT CONDUCTOR	Kms.	15.13	4.33	65.5129
287	New Feeder-2(MAHUL To New Location)	PCC POLES WITH RABBIT CONDUCTOR	Kms.	24	4.33	103.92
288	New Feeder-2(Mdiyapar To New Location)	PCC POLES WITH RABBIT CONDUCTOR	Kms.	12	4.33	51.96
289	New Feeder-2(MEH NAGAR To New Location)	PCC POLES WITH RABBIT CONDUCTOR	Kms.	15	4.33	64.95
290	New Feeder-2(MOHABBATPUR To New Location)	PCC POLES WITH RABBIT CONDUCTOR	Kms.	12	4.33	51.96
291	New Feeder-2(MUBARAKPUR To New Location)	PCC POLES WITH RABBIT CONDUCTOR	Kms.	18	4.33	77.94
292	New Feeder-2(PHOOLPUR To New Location)	PCC POLES WITH RABBIT CONDUCTOR	Kms.	10	4.33	43.3
293	New Feeder-2(RANI KI SARAI To New Location)	PCC POLES WITH RABBIT CONDUCTOR	Kms.	10	4.33	43.3
294	New Feeder-2(SARAI MEER To New Location)	PCC POLES WITH RABBIT CONDUCTOR	Kms.	14	4.33	60.62
Sub-Total (New 11 KV Line)				993.57		4302.1581
Total (B.Feeder Seperation)						11800.0081
C.Sansad Adarsh Gram Yozna						
BPL Hhs						
1	Atraulia	Total BPL Hhs proposed to be electrified	Nos.	22	0.03	0.66
2	Palhani	Total BPL Hhs proposed to be electrified	Nos.	21	0.03	0.63
3	Palhna	Total BPL Hhs proposed to be electrified	Nos.	10	0.03	0.3
Sub-Total (BPL Hhs)				53		1.59
New 11 KV Line DTR						
4	Atraulia	25 KVA (3 Ph)	Nos.	10	2.64	26.4

Abstract : Scope of Work & Estimated Cost

State : UTTAR PRADESH
District : Azamgarh

S.No.	Item of Works	Sub Item	Unit	Quantity	Unit Cost(In Lac)	Total Cost(In Lac)
5	Palhani	25 KVA (3 Ph)	Nos.	9	2.64	23.76
6	Palhna	25 KVA (3 Ph)	Nos.	4	2.64	10.56
Sub-Total (New 11 KV Line DTR)				23		60.72
New 11 KV Spur Line						
7	Atraulia	11 KV Weasel Conductor	Kms.	1.72	6.19	10.6468
8	Palhani	11 KV Weasel Conductor	Kms.	1.76	6.19	10.8944
9	Palhna	11 KV Weasel Conductor	Kms.	1.17	6.19	7.2423
Sub-Total (New 11 KV Spur Line)				4.65		28.7835
New LT AB Cable						
10	Atraulia	2X25+1X16	Kms.	1.82	3.72	6.7704
		3X50+1X35+1X16	Kms.	1.5	5.14	7.71
11	Palhani	2X25+1X16	Kms.	1.55	3.72	5.766
		3X50+1X35+1X16	Kms.	1.05	5.14	5.397
12	Palhna	2X25+1X16	Kms.	0.71	3.72	2.6412
		3X50+1X35+1X16	Kms.	0.49	5.14	2.5186
Sub-Total (New LT AB Cable)				7.12		30.8032
Total (C.Sansad Adarsh Gram Yozna)						121.8967
D.Connecting / UnConnecting HHs						
BPL Hhs						
1	Ahiraula	Total BPL Hhs proposed to be electrified	Nos.	9	0.03	0.27
2	Atraulia	Total BPL Hhs proposed to be electrified	Nos.	10	0.03	0.3
3	Azmatgarh	Total BPL Hhs proposed to be electrified	Nos.	12	0.03	0.36
4	Bilariyaganj	Total BPL Hhs proposed to be electrified	Nos.	10	0.03	0.3

Abstract : Scope of Work & Estimated Cost

State : UTTAR PRADESH
District : Azamgarh

S.No.	Item of Works	Sub Item	Unit	Quantity	Unit Cost(In Lac)	Total Cost(In Lac)
5	Haraiya	Total BPL Hhs proposed to be electrified	Nos.	14	0.03	0.42
6	Jahanaganj	Total BPL Hhs proposed to be electrified	Nos.	119	0.03	3.57
7	Koilsa	Total BPL Hhs proposed to be electrified	Nos.	24	0.03	0.72
8	Lalganj	Total BPL Hhs proposed to be electrified	Nos.	58	0.03	1.74
9	Mahrajanj	Total BPL Hhs proposed to be electrified	Nos.	12	0.03	0.36
10	Martinganj	Total BPL Hhs proposed to be electrified	Nos.	38	0.03	1.14
11	Mehnagar	Total BPL Hhs proposed to be electrified	Nos.	21	0.03	0.63
12	Mirzapur	Total BPL Hhs proposed to be electrified	Nos.	54	0.03	1.62
13	Mohammadpur	Total BPL Hhs proposed to be electrified	Nos.	12	0.03	0.36
14	Palhani	Total BPL Hhs proposed to be electrified	Nos.	14	0.03	0.42
15	Palhna	Total BPL Hhs proposed to be electrified	Nos.	69	0.03	2.07
16	Pawai	Total BPL Hhs proposed to be electrified	Nos.	24	0.03	0.72
17	Phulpur	Total BPL Hhs proposed to be electrified	Nos.	7	0.03	0.21
18	Rani Ki Sarai	Total BPL Hhs proposed to be electrified	Nos.	93	0.03	2.79
19	Sathiyaon	Total BPL Hhs proposed to be electrified	Nos.	13	0.03	0.39
20	Tahbarpur	Total BPL Hhs proposed to be electrified	Nos.	32	0.03	0.96
21	Tarwa	Total BPL Hhs proposed to be electrified	Nos.	8	0.03	0.24
22	Thekma	Total BPL Hhs proposed to be electrified	Nos.	16	0.03	0.48
Sub-Total (BPL Hhs)				669		20.07
New 11 KV Line DTR						
23	Ahiraula	25 KVA (3 Ph)	Nos.	4	2.64	10.56
24	Atraulia	25 KVA (3 Ph)	Nos.	5	2.64	13.2
25	Azmatgarh	25 KVA (3 Ph)	Nos.	7	2.64	18.48

Abstract : Scope of Work & Estimated Cost

State : UTTAR PRADESH
District : Azamgarh

S.No.	Item of Works	Sub Item	Unit	Quantity	Unit Cost(In Lac)	Total Cost(In Lac)
26	Bilariyaganj	25 KVA (3 Ph)	Nos.	4	2.64	10.56
27	Haraiya	25 KVA (3 Ph)	Nos.	7	2.64	18.48
28	Jahanaganj	25 KVA (3 Ph)	Nos.	35	2.64	92.4
		63 KVA (3 Ph)	Nos.	4	3.45	13.8
29	Koilsa	25 KVA (3 Ph)	Nos.	11	2.64	29.04
30	Lalganj	25 KVA (3 Ph)	Nos.	18	2.64	47.52
		63 KVA (3 Ph)	Nos.	4	3.45	13.8
31	Mahrajganj	25 KVA (3 Ph)	Nos.	8	2.64	21.12
32	Martinganj	25 KVA (3 Ph)	Nos.	18	2.64	47.52
33	Mehnagar	25 KVA (3 Ph)	Nos.	13	2.64	34.32
34	Mirzapur	25 KVA (3 Ph)	Nos.	19	2.64	50.16
35	Mohammadpur	25 KVA (3 Ph)	Nos.	6	2.64	15.84
36	Palhani	25 KVA (3 Ph)	Nos.	6	2.64	15.84
37	Palhna	25 KVA (3 Ph)	Nos.	27	2.64	71.28
38	Pawai	25 KVA (3 Ph)	Nos.	11	2.64	29.04
39	Phulpur	25 KVA (3 Ph)	Nos.	4	2.64	10.56
40	Rani Ki Sarai	25 KVA (3 Ph)	Nos.	37	2.64	97.68
41	Sathiyaon	25 KVA (3 Ph)	Nos.	5	2.64	13.2
42	Tahbarpur	25 KVA (3 Ph)	Nos.	15	2.64	39.6
43	Tarwa	25 KVA (3 Ph)	Nos.	5	2.64	13.2
44	Thekma	25 KVA (3 Ph)	Nos.	6	2.64	15.84
Sub-Total (New 11 KV Line DTR)				279		743.04
New 11 KV Spur Line						

Abstract : Scope of Work & Estimated Cost

State : UTTAR PRADESH
District : Azamgarh

S.No.	Item of Works	Sub Item	Unit	Quantity	Unit Cost(In Lac)	Total Cost(In Lac)
45	Ahiraula	11 KV Weasel Conductor	Kms.	1.29	6.19	7.9851
46	Atraulia	11 KV Weasel Conductor	Kms.	1.6	6.19	9.904
47	Azmatgarh	11 KV Weasel Conductor	Kms.	2.24	6.19	13.8656
48	Bilariyaganj	11 KV Weasel Conductor	Kms.	1.34	6.19	8.2946
49	Haraiya	11 KV Weasel Conductor	Kms.	2.28	6.19	14.1132
50	Jahanaganj	11 KV Weasel Conductor	Kms.	14.05	6.19	86.9695
51	Koilsa	11 KV Weasel Conductor	Kms.	3.64	6.19	22.5316
52	Lalganj	11 KV Weasel Conductor	Kms.	7.5	6.19	46.425
53	Mahrajganj	11 KV Weasel Conductor	Kms.	2.43	6.19	15.0417
54	Martinganj	11 KV Weasel Conductor	Kms.	5.71	6.19	35.3449
55	Mehnagar	11 KV Weasel Conductor	Kms.	3.99	6.19	24.6981
56	Mirzapur	11 KV Weasel Conductor	Kms.	6.66	6.19	41.2254
57	Mohammadpur	11 KV Weasel Conductor	Kms.	1.9	6.19	11.761
58	Palhani	11 KV Weasel Conductor	Kms.	2	6.19	12.38
59	Palhna	11 KV Weasel Conductor	Kms.	9.58	6.19	59.3002
60	Pawai	11 KV Weasel Conductor	Kms.	3.57	6.19	22.0983
61	Phulpur	11 KV Weasel Conductor	Kms.	1.24	6.19	7.6756
62	Rani Ki Sarai	11 KV Weasel Conductor	Kms.	12.71	6.19	78.6749
63	Sathiyaon	11 KV Weasel Conductor	Kms.	1.71	6.19	10.5849
64	Tahbarpur	11 KV Weasel Conductor	Kms.	4.86	6.19	30.0834
65	Tarwa	11 KV Weasel Conductor	Kms.	1.55	6.19	9.5945
66	Thekma	11 KV Weasel Conductor	Kms.	2.04	6.19	12.6276
Sub-Total (New 11 KV Spur Line)				93.89		581.1791

Abstract : Scope of Work & Estimated Cost

State : UTTAR PRADESH
District : Azamgarh

S.No.	Item of Works	Sub Item	Unit	Quantity	Unit Cost(In Lac)	Total Cost(In Lac)
	New LT AB Cable					
67	Ahiraula	2X25+1X16	Kms.	1.17	3.72	4.3524
		3X50+1X35+1X16	Kms.	0.5	5.14	2.57
68	Atraulia	2X25+1X16	Kms.	1.45	3.72	5.394
		3X50+1X35+1X16	Kms.	0.61	5.14	3.1354
69	Azmatgarh	2X25+1X16	Kms.	1.86	3.72	6.9192
		3X50+1X35+1X16	Kms.	0.85	5.14	4.369
70	Bilariyaganj	2X25+1X16	Kms.	1.13	3.72	4.2036
		3X50+1X35+1X16	Kms.	0.5	5.14	2.57
71	Haraiya	2X25+1X16	Kms.	2.05	3.72	7.626
		3X50+1X35+1X16	Kms.	0.91	5.14	4.6774
72	Jahanaganj	2X25+1X16	Kms.	12.5	3.72	46.5
		3X50+1X35+1X16	Kms.	5.18	5.14	26.6252
73	Koilsa	2X25+1X16	Kms.	3.25	3.72	12.09
		3X50+1X35+1X16	Kms.	1.38	5.14	7.0932
74	Lalganj	2X25+1X16	Kms.	6.75	3.72	25.11
		3X50+1X35+1X16	Kms.	2.96	5.14	15.2144
75	Mahrajganj	2X25+1X16	Kms.	2.22	3.72	8.2584
		3X50+1X35+1X16	Kms.	0.93	5.14	4.7802
76	Martinganj	2X25+1X16	Kms.	5.12	3.72	19.0464
		3X50+1X35+1X16	Kms.	2.19	5.14	11.2566
77	Mehnnagar	2X25+1X16	Kms.	3.63	3.72	13.5036
		3X50+1X35+1X16	Kms.	1.61	5.14	8.2754

Abstract : Scope of Work & Estimated Cost

State : UTTAR PRADESH
District : Azamgarh

S.No.	Item of Works	Sub Item	Unit	Quantity	Unit Cost(In Lac)	Total Cost(In Lac)
78	Mirzapur	2X25+1X16	Kms.	5.97	3.72	22.2084
		3X50+1X35+1X16	Kms.	2.46	5.14	12.6444
79	Mohammadpur	2X25+1X16	Kms.	1.73	3.72	6.4356
		3X50+1X35+1X16	Kms.	0.73	5.14	3.7522
80	Palhani	2X25+1X16	Kms.	1.8	3.72	6.696
		3X50+1X35+1X16	Kms.	0.75	5.14	3.855
81	Palhna	2X25+1X16	Kms.	8.91	3.72	33.1452
		3X50+1X35+1X16	Kms.	3.9	5.14	20.046
82	Pawai	2X25+1X16	Kms.	3.24	3.72	12.0528
		3X50+1X35+1X16	Kms.	1.4	5.14	7.196
83	Phulpur	2X25+1X16	Kms.	1.13	3.72	4.2036
		3X50+1X35+1X16	Kms.	0.48	5.14	2.4672
84	Rani Ki Sarai	2X25+1X16	Kms.	11.39	3.72	42.3708
		3X50+1X35+1X16	Kms.	4.78	5.14	24.5692
85	Sathiyaon	2X25+1X16	Kms.	1.54	3.72	5.7288
		3X50+1X35+1X16	Kms.	0.64	5.14	3.2896
86	Tahbarpur	2X25+1X16	Kms.	4.4	3.72	16.368
		3X50+1X35+1X16	Kms.	1.87	5.14	9.6118
87	Tarwa	2X25+1X16	Kms.	1.41	3.72	5.2452
		3X50+1X35+1X16	Kms.	0.59	5.14	3.0326
88	Thekma	2X25+1X16	Kms.	1.83	3.72	6.8076
		3X50+1X35+1X16	Kms.	0.76	5.14	3.9064
Sub-Total (New LT AB Cable)				120.46		499.2028

Abstract : Scope of Work & Estimated Cost

State : UTTAR PRADESH
District : Azamgarh

S.No.	Item of Works	Sub Item	Unit	Quantity	Unit Cost(In Lac)	Total Cost(In Lac)
Total (D.Connecting / UnConnecting HHs)						1843.4919
	E.Metering					
	DTR Metering					
1	Ahiraula	No. of DTR meter Proposed in DDUGJY (10 KVA)	Nos.	30	0.14	4.2
		No. of DTR meter Proposed in DDUGJY (100 KVA)	Nos.	3	0.14	0.42
		No. of DTR meter Proposed in DDUGJY (16 KVA)	Nos.	16	0.14	2.24
		No. of DTR meter Proposed in DDUGJY (25 KVA)	Nos.	22	0.14	3.08
		No. of DTR meter Proposed in DDUGJY (250 KVA)	Nos.	1	0.14	0.14
		No. of DTR meter Proposed in DDUGJY (63 KVA)	Nos.	18	0.14	2.52
2	Atraulia	No. of DTR meter Proposed in DDUGJY (10 KVA)	Nos.	23	0.14	3.22
		No. of DTR meter Proposed in DDUGJY (100 KVA)	Nos.	5	0.14	0.7
		No. of DTR meter Proposed in DDUGJY (16 KVA)	Nos.	8	0.14	1.12
		No. of DTR meter Proposed in DDUGJY (25 KVA)	Nos.	17	0.14	2.38
		No. of DTR meter Proposed in DDUGJY (63 KVA)	Nos.	8	0.14	1.12
3	Azmatgarh	No. of DTR meter Proposed in DDUGJY (10 KVA)	Nos.	63	0.14	8.82
		No. of DTR meter Proposed in DDUGJY (100 KVA)	Nos.	8	0.14	1.12
		No. of DTR meter Proposed in DDUGJY (16 KVA)	Nos.	21	0.14	2.94
		No. of DTR meter Proposed in DDUGJY (25 KVA)	Nos.	36	0.14	5.04
		No. of DTR meter Proposed in DDUGJY (250 KVA)	Nos.	2	0.14	0.28
		No. of DTR meter Proposed in DDUGJY (63 KVA)	Nos.	23	0.14	3.22
4	Bilariyaganj	No. of DTR meter Proposed in DDUGJY (10 KVA)	Nos.	33	0.14	4.62
		No. of DTR meter Proposed in DDUGJY (100 KVA)	Nos.	5	0.14	0.7
		No. of DTR meter Proposed in DDUGJY (16 KVA)	Nos.	12	0.14	1.68

Abstract : Scope of Work & Estimated Cost

State : UTTAR PRADESH
District : Azamgarh

S.No.	Item of Works	Sub Item	Unit	Quantity	Unit Cost(In Lac)	Total Cost(In Lac)
		No. of DTR meter Proposed in DDUGJY (25 KVA)	Nos.	21	0.14	2.94
		No. of DTR meter Proposed in DDUGJY (250 KVA)	Nos.	1	0.14	0.14
		No. of DTR meter Proposed in DDUGJY (63 KVA)	Nos.	16	0.14	2.24
5	Haraiya	No. of DTR meter Proposed in DDUGJY (10 KVA)	Nos.	22	0.14	3.08
		No. of DTR meter Proposed in DDUGJY (100 KVA)	Nos.	3	0.14	0.42
		No. of DTR meter Proposed in DDUGJY (16 KVA)	Nos.	12	0.14	1.68
		No. of DTR meter Proposed in DDUGJY (25 KVA)	Nos.	17	0.14	2.38
		No. of DTR meter Proposed in DDUGJY (63 KVA)	Nos.	16	0.14	2.24
6	Jahanaganj	No. of DTR meter Proposed in DDUGJY (10 KVA)	Nos.	45	0.14	6.3
		No. of DTR meter Proposed in DDUGJY (100 KVA)	Nos.	8	0.14	1.12
		No. of DTR meter Proposed in DDUGJY (16 KVA)	Nos.	20	0.14	2.8
		No. of DTR meter Proposed in DDUGJY (25 KVA)	Nos.	28	0.14	3.92
		No. of DTR meter Proposed in DDUGJY (250 KVA)	Nos.	3	0.14	0.42
		No. of DTR meter Proposed in DDUGJY (63 KVA)	Nos.	20	0.14	2.8
7	Koilsa	No. of DTR meter Proposed in DDUGJY (10 KVA)	Nos.	40	0.14	5.6
		No. of DTR meter Proposed in DDUGJY (100 KVA)	Nos.	2	0.14	0.28
		No. of DTR meter Proposed in DDUGJY (16 KVA)	Nos.	23	0.14	3.22
		No. of DTR meter Proposed in DDUGJY (25 KVA)	Nos.	31	0.14	4.34
		No. of DTR meter Proposed in DDUGJY (250 KVA)	Nos.	1	0.14	0.14
		No. of DTR meter Proposed in DDUGJY (63 KVA)	Nos.	17	0.14	2.38
8	Lalganj	No. of DTR meter Proposed in DDUGJY (10 KVA)	Nos.	59	0.14	8.26
		No. of DTR meter Proposed in DDUGJY (100 KVA)	Nos.	4	0.14	0.56
		No. of DTR meter Proposed in DDUGJY (16 KVA)	Nos.	22	0.14	3.08

Abstract : Scope of Work & Estimated Cost

State : UTTAR PRADESH
District : Azamgarh

S.No.	Item of Works	Sub Item	Unit	Quantity	Unit Cost(In Lac)	Total Cost(In Lac)
		No. of DTR meter Proposed in DDUGJY (25 KVA)	Nos.	44	0.14	6.16
		No. of DTR meter Proposed in DDUGJY (63 KVA)	Nos.	26	0.14	3.64
9	Mahrajanj	No. of DTR meter Proposed in DDUGJY (10 KVA)	Nos.	42	0.14	5.88
		No. of DTR meter Proposed in DDUGJY (100 KVA)	Nos.	7	0.14	0.98
		No. of DTR meter Proposed in DDUGJY (16 KVA)	Nos.	10	0.14	1.4
		No. of DTR meter Proposed in DDUGJY (25 KVA)	Nos.	23	0.14	3.22
		No. of DTR meter Proposed in DDUGJY (250 KVA)	Nos.	3	0.14	0.42
		No. of DTR meter Proposed in DDUGJY (63 KVA)	Nos.	12	0.14	1.68
10	Martinganj	No. of DTR meter Proposed in DDUGJY (10 KVA)	Nos.	12	0.14	1.68
		No. of DTR meter Proposed in DDUGJY (100 KVA)	Nos.	4	0.14	0.56
		No. of DTR meter Proposed in DDUGJY (16 KVA)	Nos.	4	0.14	0.56
		No. of DTR meter Proposed in DDUGJY (25 KVA)	Nos.	10	0.14	1.4
		No. of DTR meter Proposed in DDUGJY (250 KVA)	Nos.	1	0.14	0.14
		No. of DTR meter Proposed in DDUGJY (63 KVA)	Nos.	7	0.14	0.98
11	Mehrnagar	No. of DTR meter Proposed in DDUGJY (10 KVA)	Nos.	28	0.14	3.92
		No. of DTR meter Proposed in DDUGJY (100 KVA)	Nos.	1	0.14	0.14
		No. of DTR meter Proposed in DDUGJY (16 KVA)	Nos.	13	0.14	1.82
		No. of DTR meter Proposed in DDUGJY (25 KVA)	Nos.	18	0.14	2.52
		No. of DTR meter Proposed in DDUGJY (63 KVA)	Nos.	6	0.14	0.84
12	Mirzapur	No. of DTR meter Proposed in DDUGJY (10 KVA)	Nos.	22	0.14	3.08
		No. of DTR meter Proposed in DDUGJY (100 KVA)	Nos.	4	0.14	0.56
		No. of DTR meter Proposed in DDUGJY (16 KVA)	Nos.	12	0.14	1.68
		No. of DTR meter Proposed in DDUGJY (25 KVA)	Nos.	17	0.14	2.38

Abstract : Scope of Work & Estimated Cost

State : UTTAR PRADESH
District : Azamgarh

S.No.	Item of Works	Sub Item	Unit	Quantity	Unit Cost(In Lac)	Total Cost(In Lac)
		No. of DTR meter Proposed in DDUGJY (63 KVA)	Nos.	11	0.14	1.54
13	Mohammadpur	No. of DTR meter Proposed in DDUGJY (10 KVA)	Nos.	40	0.14	5.6
		No. of DTR meter Proposed in DDUGJY (100 KVA)	Nos.	4	0.14	0.56
		No. of DTR meter Proposed in DDUGJY (16 KVA)	Nos.	16	0.14	2.24
		No. of DTR meter Proposed in DDUGJY (25 KVA)	Nos.	30	0.14	4.2
		No. of DTR meter Proposed in DDUGJY (250 KVA)	Nos.	1	0.14	0.14
		No. of DTR meter Proposed in DDUGJY (63 KVA)	Nos.	22	0.14	3.08
		14	Palhani	No. of DTR meter Proposed in DDUGJY (10 KVA)	Nos.	12
No. of DTR meter Proposed in DDUGJY (100 KVA)	Nos.			1	0.14	0.14
No. of DTR meter Proposed in DDUGJY (16 KVA)	Nos.			3	0.14	0.42
No. of DTR meter Proposed in DDUGJY (25 KVA)	Nos.			8	0.14	1.12
No. of DTR meter Proposed in DDUGJY (63 KVA)	Nos.			4	0.14	0.56
15	Palhna	No. of DTR meter Proposed in DDUGJY (10 KVA)	Nos.	53	0.14	7.42
		No. of DTR meter Proposed in DDUGJY (100 KVA)	Nos.	5	0.14	0.7
		No. of DTR meter Proposed in DDUGJY (16 KVA)	Nos.	17	0.14	2.38
		No. of DTR meter Proposed in DDUGJY (25 KVA)	Nos.	41	0.14	5.74
		No. of DTR meter Proposed in DDUGJY (250 KVA)	Nos.	1	0.14	0.14
		No. of DTR meter Proposed in DDUGJY (63 KVA)	Nos.	20	0.14	2.8
16	Pawai	No. of DTR meter Proposed in DDUGJY (10 KVA)	Nos.	27	0.14	3.78
		No. of DTR meter Proposed in DDUGJY (100 KVA)	Nos.	9	0.14	1.26
		No. of DTR meter Proposed in DDUGJY (16 KVA)	Nos.	12	0.14	1.68
		No. of DTR meter Proposed in DDUGJY (25 KVA)	Nos.	22	0.14	3.08
		No. of DTR meter Proposed in DDUGJY (250 KVA)	Nos.	1	0.14	0.14

Abstract : Scope of Work & Estimated Cost

State : UTTAR PRADESH
District : Azamgarh

S.No.	Item of Works	Sub Item	Unit	Quantity	Unit Cost(In Lac)	Total Cost(In Lac)
		No. of DTR meter Proposed in DDUGJY (63 KVA)	Nos.	13	0.14	1.82
17	Phulpur	No. of DTR meter Proposed in DDUGJY (10 KVA)	Nos.	31	0.14	4.34
		No. of DTR meter Proposed in DDUGJY (100 KVA)	Nos.	7	0.14	0.98
		No. of DTR meter Proposed in DDUGJY (16 KVA)	Nos.	12	0.14	1.68
		No. of DTR meter Proposed in DDUGJY (25 KVA)	Nos.	24	0.14	3.36
		No. of DTR meter Proposed in DDUGJY (250 KVA)	Nos.	1	0.14	0.14
		No. of DTR meter Proposed in DDUGJY (63 KVA)	Nos.	8	0.14	1.12
		18	Rani Ki Sarai	No. of DTR meter Proposed in DDUGJY (10 KVA)	Nos.	20
No. of DTR meter Proposed in DDUGJY (100 KVA)	Nos.			1	0.14	0.14
No. of DTR meter Proposed in DDUGJY (16 KVA)	Nos.			5	0.14	0.7
No. of DTR meter Proposed in DDUGJY (25 KVA)	Nos.			8	0.14	1.12
No. of DTR meter Proposed in DDUGJY (250 KVA)	Nos.			1	0.14	0.14
No. of DTR meter Proposed in DDUGJY (63 KVA)	Nos.			4	0.14	0.56
19	Sathiyaon	No. of DTR meter Proposed in DDUGJY (10 KVA)	Nos.	21	0.14	2.94
		No. of DTR meter Proposed in DDUGJY (100 KVA)	Nos.	2	0.14	0.28
		No. of DTR meter Proposed in DDUGJY (16 KVA)	Nos.	6	0.14	0.84
		No. of DTR meter Proposed in DDUGJY (25 KVA)	Nos.	14	0.14	1.96
		No. of DTR meter Proposed in DDUGJY (250 KVA)	Nos.	1	0.14	0.14
		No. of DTR meter Proposed in DDUGJY (63 KVA)	Nos.	9	0.14	1.26
20	Tahbarpur	No. of DTR meter Proposed in DDUGJY (10 KVA)	Nos.	37	0.14	5.18
		No. of DTR meter Proposed in DDUGJY (100 KVA)	Nos.	3	0.14	0.42
		No. of DTR meter Proposed in DDUGJY (16 KVA)	Nos.	13	0.14	1.82
		No. of DTR meter Proposed in DDUGJY (25 KVA)	Nos.	19	0.14	2.66

Abstract : Scope of Work & Estimated Cost

State : UTTAR PRADESH
District : Azamgarh

S.No.	Item of Works	Sub Item	Unit	Quantity	Unit Cost(In Lac)	Total Cost(In Lac)
		No. of DTR meter Proposed in DDUGJY (250 KVA)	Nos.	2	0.14	0.28
		No. of DTR meter Proposed in DDUGJY (63 KVA)	Nos.	15	0.14	2.1
21	Tarwa	No. of DTR meter Proposed in DDUGJY (10 KVA)	Nos.	38	0.14	5.32
		No. of DTR meter Proposed in DDUGJY (100 KVA)	Nos.	5	0.14	0.7
		No. of DTR meter Proposed in DDUGJY (16 KVA)	Nos.	13	0.14	1.82
		No. of DTR meter Proposed in DDUGJY (25 KVA)	Nos.	29	0.14	4.06
		No. of DTR meter Proposed in DDUGJY (250 KVA)	Nos.	2	0.14	0.28
		No. of DTR meter Proposed in DDUGJY (63 KVA)	Nos.	20	0.14	2.8
22	Thekma	No. of DTR meter Proposed in DDUGJY (10 KVA)	Nos.	31	0.14	4.34
		No. of DTR meter Proposed in DDUGJY (100 KVA)	Nos.	4	0.14	0.56
		No. of DTR meter Proposed in DDUGJY (16 KVA)	Nos.	11	0.14	1.54
		No. of DTR meter Proposed in DDUGJY (25 KVA)	Nos.	21	0.14	2.94
		No. of DTR meter Proposed in DDUGJY (250 KVA)	Nos.	1	0.14	0.14
		No. of DTR meter Proposed in DDUGJY (63 KVA)	Nos.	15	0.14	2.1
Sub-Total (DTR Metering)				1938		271.32
	Feeder Metering					
23	Ahiraula	11KV Feeder Meters Required for Meterization Without CT/PT	Nos.	3	0.05	0.15
		33KV Feeder Meters Required for Meterization Without CT/PT	Nos.	1	1.02	1.02
24	Atraulia	11KV Feeder Meters Required for Meterization Without CT/PT	Nos.	2	0.05	0.1
25	Azmatgarh	11KV Feeder Meters Required for Meterization Without CT/PT	Nos.	6	0.05	0.3

Abstract : Scope of Work & Estimated Cost

State : UTTAR PRADESH
District : Azamgarh

S.No.	Item of Works	Sub Item	Unit	Quantity	Unit Cost(In Lac)	Total Cost(In Lac)
26	Bilariyaganj	11KV Feeder Meters Required for Meterization Without CT/PT	Nos.	3	0.05	0.15
27	Haraiya	11KV Feeder Meters Required for Meterization Without CT/PT	Nos.	3	0.05	0.15
28	Jahanaganj	11KV Feeder Meters Required for Meterization Without CT/PT	Nos.	5	0.05	0.25
29	Koilsa	11KV Feeder Meters Required for Meterization Without CT/PT	Nos.	6	0.05	0.3
30	Lalganj	11KV Feeder Meters Required for Meterization Without CT/PT	Nos.	5	0.05	0.25
31	Mahrajanj	11KV Feeder Meters Required for Meterization Without CT/PT	Nos.	3	0.05	0.15
32	Martinganj	11KV Feeder Meters Required for Meterization Without CT/PT	Nos.	1	0.05	0.05
		33KV Feeder Meters Required for Meterization Without CT/PT	Nos.	1	1.02	1.02
33	Mehnagar	11KV Feeder Meters Required for Meterization Without CT/PT	Nos.	3	0.05	0.15
34	Mirzapur	11KV Feeder Meters Required for Meterization Without CT/PT	Nos.	3	0.05	0.15
35	Mohammadpur	11KV Feeder Meters Required for Meterization Without CT/PT	Nos.	4	0.05	0.2
36	Palhani	11KV Feeder Meters Required for Meterization Without CT/PT	Nos.	2	0.05	0.1
37	Palhna	11KV Feeder Meters Required for Meterization Without CT/PT	Nos.	5	0.05	0.25
		33KV Feeder Meters Required for Meterization Without CT/PT	Nos.	1	1.02	1.02
38	Pawai	11KV Feeder Meters Required for Meterization Without CT/PT	Nos.	3	0.05	0.15

Abstract : Scope of Work & Estimated Cost

State : UTTAR PRADESH
District : Azamgarh

S.No.	Item of Works	Sub Item	Unit	Quantity	Unit Cost(In Lac)	Total Cost(In Lac)
39	Phulpur	11KV Feeder Meters Required for Meterization Without CT/PT	Nos.	4	0.05	0.2
40	Rani Ki Sarai	11KV Feeder Meters Required for Meterization Without CT/PT	Nos.	1	0.05	0.05
41	Sathiyaon	11KV Feeder Meters Required for Meterization Without CT/PT	Nos.	3	0.05	0.15
42	Tahbarpur	11KV Feeder Meters Required for Meterization Without CT/PT	Nos.	5	0.05	0.25
43	Tarwa	11KV Feeder Meters Required for Meterization Without CT/PT	Nos.	4	0.05	0.2
44	Thekma	11KV Feeder Meters Required for Meterization Without CT/PT	Nos.	3	0.05	0.15
Sub-Total (Feeder Metering)				80		6.91
LT Metering(Consumer Metering)						
45	Ahiraula	Installation of New Meters(1-Ph Domestic and Commercial Meters)	Nos.	582	0.01	5.82
		Installation of New Meters(3-Ph Domestic and Commercial Meters)	Nos.	20	0.04	0.8
46	Atraulia	Installation of New Meters(1-Ph Domestic and Commercial Meters)	Nos.	340	0.01	3.4
		Installation of New Meters(3-Ph Domestic and Commercial Meters)	Nos.	16	0.04	0.64
47	Azmatgarh	Installation of New Meters(1-Ph Domestic and Commercial Meters)	Nos.	635	0.01	6.35
		Installation of New Meters(3-Ph Domestic and Commercial Meters)	Nos.	22	0.04	0.88
48	Bilariyaganj	Installation of New Meters(1-Ph Domestic and Commercial Meters)	Nos.	641	0.01	6.41
		Installation of New Meters(3-Ph Domestic and Commercial Meters)	Nos.	22	0.04	0.88

Abstract : Scope of Work & Estimated Cost

State : UTTAR PRADESH
District : Azamgarh

S.No.	Item of Works	Sub Item	Unit	Quantity	Unit Cost(In Lac)	Total Cost(In Lac)
49	Haraiya	Installation of New Meters(1-Ph Domestic and Commercial Meters)	Nos.	566	0.01	5.66
		Installation of New Meters(3-Ph Domestic and Commercial Meters)	Nos.	19	0.04	0.76
50	Jahanaganj	Installation of New Meters(1-Ph Domestic and Commercial Meters)	Nos.	515	0.01	5.15
		Installation of New Meters(3-Ph Domestic and Commercial Meters)	Nos.	17	0.04	0.68
51	Koilsa	Installation of New Meters(1-Ph Domestic and Commercial Meters)	Nos.	535	0.01	5.35
		Installation of New Meters(3-Ph Domestic and Commercial Meters)	Nos.	18	0.04	0.72
52	Lalganj	Installation of New Meters(1-Ph Domestic and Commercial Meters)	Nos.	602	0.01	6.02
		Installation of New Meters(3-Ph Domestic and Commercial Meters)	Nos.	20	0.04	0.8
53	Mahrajanj	Installation of New Meters(1-Ph Domestic and Commercial Meters)	Nos.	581	0.01	5.81
		Installation of New Meters(3-Ph Domestic and Commercial Meters)	Nos.	19	0.04	0.76
54	Martinganj	Installation of New Meters(1-Ph Domestic and Commercial Meters)	Nos.	520	0.01	5.2
		Installation of New Meters(3-Ph Domestic and Commercial Meters)	Nos.	17	0.04	0.68
55	Mehnagar	Installation of New Meters(1-Ph Domestic and Commercial Meters)	Nos.	527	0.01	5.27
		Installation of New Meters(3-Ph Domestic and Commercial Meters)	Nos.	18	0.04	0.72
56	Mirzapur	Installation of New Meters(1-Ph Domestic and Commercial Meters)	Nos.	570	0.01	5.7

Abstract : Scope of Work & Estimated Cost

State : UTTAR PRADESH
District : Azamgarh

S.No.	Item of Works	Sub Item	Unit	Quantity	Unit Cost(In Lac)	Total Cost(In Lac)
		Installation of New Meters(3-Ph Domestic and Commercial Meters)	Nos.	19	0.04	0.76
57	Mohammadpur	Installation of New Meters(1-Ph Domestic and Commercial Meters)	Nos.	499	0.01	4.99
		Installation of New Meters(3-Ph Domestic and Commercial Meters)	Nos.	17	0.04	0.68
58	Palhani	Installation of New Meters(1-Ph Domestic and Commercial Meters)	Nos.	544	0.01	5.44
		Installation of New Meters(3-Ph Domestic and Commercial Meters)	Nos.	18	0.04	0.72
59	Palhna	Installation of New Meters(1-Ph Domestic and Commercial Meters)	Nos.	317	0.01	3.17
		Installation of New Meters(3-Ph Domestic and Commercial Meters)	Nos.	11	0.04	0.44
60	Pawai	Installation of New Meters(1-Ph Domestic and Commercial Meters)	Nos.	570	0.01	5.7
		Installation of New Meters(3-Ph Domestic and Commercial Meters)	Nos.	19	0.04	0.76
61	Phulpur	Installation of New Meters(1-Ph Domestic and Commercial Meters)	Nos.	558	0.01	5.58
		Installation of New Meters(3-Ph Domestic and Commercial Meters)	Nos.	19	0.04	0.76
62	Rani Ki Sarai	Installation of New Meters(1-Ph Domestic and Commercial Meters)	Nos.	641	0.01	6.41
		Installation of New Meters(3-Ph Domestic and Commercial Meters)	Nos.	22	0.04	0.88
63	Sathiyaon	Installation of New Meters(1-Ph Domestic and Commercial Meters)	Nos.	624	0.01	6.24
		Installation of New Meters(3-Ph Domestic and Commercial Meters)	Nos.	21	0.04	0.84

Abstract : Scope of Work & Estimated Cost

State : UTTAR PRADESH
District : Azamgarh

S.No.	Item of Works	Sub Item	Unit	Quantity	Unit Cost(In Lac)	Total Cost(In Lac)
64	Tahbarpur	Installation of New Meters(1-Ph Domestic and Commercial Meters)	Nos.	513	0.01	5.13
		Installation of New Meters(3-Ph Domestic and Commercial Meters)	Nos.	17	0.04	0.68
65	Tarwa	Installation of New Meters(1-Ph Domestic and Commercial Meters)	Nos.	584	0.01	5.84
		Installation of New Meters(3-Ph Domestic and Commercial Meters)	Nos.	20	0.04	0.8
66	Thekma	Installation of New Meters(1-Ph Domestic and Commercial Meters)	Nos.	541	0.01	5.41
		Installation of New Meters(3-Ph Domestic and Commercial Meters)	Nos.	18	0.04	0.72
Sub-Total (LT Metering(Consumer Metering))				12414		136.41
Total (E.Metering)						414.64
F.System Strengthening						
33 KV Line Augmentation						
1	From TARWA To MEHNAJPUR-Section 1	Dog-100 sqmm.	Kms.	7	4.37	30.59
Sub-Total (33 KV Line Augmentation)				7		30.59
33/11 KV S/S Augmentation						
2	AHIRAULA(1x5+0+0+0+0)	T-OFF (for FSP)	Nos.	24	0.031	0.744
3	AMUWARI NARAINPUR(1x5+0+0+0+0)	AUGMENTATION OF POWER TRANSFORMER USING OLD X-MER WITH 2 NO. ADDL BAY ON 11 KV SIDE 3.15 MVA TO 5.0 MVA	Nos.	1	17.8	17.8
		T-OFF (for FSP)	Nos.	24	0.031	0.744
4	ATRAULIA(1x5+1x10+0+0+0)	AUGMENTATION OF POWER TRANSFORMER FROM 5 MVA TO 10 MVA	Nos.	1	113.9	113.9
		T-OFF (for FSP)	Nos.	33	0.031	1.023

Abstract : Scope of Work & Estimated Cost

State : UTTAR PRADESH
District : Azamgarh

S.No.	Item of Works	Sub Item	Unit	Quantity	Unit Cost(In Lac)	Total Cost(In Lac)
5	BAGH BAHAR(1x5+0+0+0+0)	T-OFF (for FSP)	Nos.	34	0.031	1.054
6	BARDAH(1x5+0+0+0+0)	T-OFF (for FSP)	Nos.	40	0.031	1.24
7	BHAWAR NATH(1x5+1x10+0+0+0)	T-OFF (for FSP)	Nos.	27	0.031	0.837
8	BILARIYAGANJ(1x5+1x5+0+0+0)	T-OFF (for FSP)	Nos.	40	0.031	1.24
9	CHANDESHWAR(1x5+1x10+0+0+0)	AUGMENTATION OF POWER TRANSFORMER FROM 5 MVA TO 10 MVA	Nos.	1	113.9	113.9
		T-OFF (for FSP)	Nos.	40	0.031	1.24
10	CHHAU(1x5+0+0+0+0)	T-OFF (for FSP)	Nos.	42	0.031	1.302
11	DATTATREYA(1x5+0+0+0+0)	T-OFF (for FSP)	Nos.	62	0.031	1.922
12	DEOGAON(1x5+0+0+0+0)	T-OFF (for FSP)	Nos.	51	0.031	1.581
13	GADDO PUR(1x5+0+0+0+0)	T-OFF (for FSP)	Nos.	36	0.031	1.116
14	GOPALGANJ(1x5+0+0+0+0)	T-OFF (for FSP)	Nos.	30	0.031	0.93
15	GOSAI KI BAZAR(1x5+0+0+0+0)	T-OFF (for FSP)	Nos.	42	0.031	1.302
16	GOTHAWAN(1x5+0+0+0+0)	T-OFF (for FSP)	Nos.	34	0.031	1.054
17	JAHANGANJ(1x5+1x5+0+0+0)	T-OFF (for FSP)	Nos.	47	0.031	1.457
18	JIRAKPUR(1x5+0+0+0+0)	T-OFF (for FSP)	Nos.	37	0.031	1.147
19	JIYANPUR(1x5+1x10+0+0+0)	AUGMENTATION OF POWER TRANSFORMER FROM 5 MVA TO 10 MVA	Nos.	1	113.9	113.9
		T-OFF (for FSP)	Nos.	47	0.031	1.457
20	KANDHARPUR(1x5+0+0+0+0)	T-OFF (for FSP)	Nos.	23	0.031	0.713
21	KANILA(1x5+0+0+0+0)	T-OFF (for FSP)	Nos.	33	0.031	1.023
22	KAPTANGANJ(1x3+1x5+0+0+0)	T-OFF (for FSP)	Nos.	48	0.031	1.488
23	KARSARA(1x5+0+0+0+0)	T-OFF (for FSP)	Nos.	31	0.031	0.961
24	KHAMARIYA(1x5+0+0+0+0)	T-OFF (for FSP)	Nos.	27	0.031	0.837

Abstract : Scope of Work & Estimated Cost

State : UTTAR PRADESH
District : Azamgarh

S.No.	Item of Works	Sub Item	Unit	Quantity	Unit Cost(In Lac)	Total Cost(In Lac)
25	LALGANJ(1x5+1x10+0+0+0)	Extension of Control Room	Nos.	1	4.16	4.16
		T-OFF (for FSP)	Nos.	65	0.031	2.015
26	LATGHAT(1x5+0+0+0+0)	AUGMENTATION OF POWER TRANSFORMER USING OLD X-MER WITH 2 NO. ADDL BAY ON 11 KV SIDE 3.15 MVA TO 5.0 MVA	Nos.	1	17.8	17.8
		T-OFF (for FSP)	Nos.	46	0.031	1.426
27	MAHRAJGANJ(1x3+1x5+0+0+0)	T-OFF (for FSP)	Nos.	42	0.031	1.302
28	MAHUL(1x5+0+0+0+0)	T-OFF (for FSP)	Nos.	5	0.031	0.155
29	MALTADI(1x5+0+0+0+0)	T-OFF (for FSP)	Nos.	52	0.031	1.612
30	MANJHARI(1x5+0+0+0+0)	T-OFF (for FSP)	Nos.	21	0.031	0.651
31	MARTINGANJ(1x5+0+0+0+0)	T-OFF (for FSP)	Nos.	46	0.031	1.426
32	MAU KUTUBPUR(1x5+0+0+0+0)	AUGMENTATION OF POWER TRANSFORMER USING OLD X-MER WITH 2 NO. ADDL BAY ON 11 KV SIDE 3.15 MVA TO 5.0 MVA	Nos.	1	17.8	17.8
		T-OFF (for FSP)	Nos.	21	0.031	0.651
33	MDIYAPAR(1x5+0+0+0+0)	T-OFF (for FSP)	Nos.	23	0.031	0.713
34	MEH NAGAR(1x5+1x5+0+0+0)	T-OFF (for FSP)	Nos.	42	0.031	1.302
35	MEHNAJPUR(1x5+0+0+0+0)	T-OFF (for FSP)	Nos.	45	0.031	1.395
36	MOHABBATPUR(1x5+0+0+0+0)	T-OFF (for FSP)	Nos.	30	0.031	0.93
37	MUBARAKPUR(1x10+1x10+0+0+0)	T-off (for FSP)	Nos.	22	0.031	0.682
38	MUHAMMAD PUR(1x5+1x5+0+0+0)	T-OFF (for FSP)	Nos.	46	0.031	1.426
39	ORA(1x3+0+0+0+0)	T-OFF (for FSP)	Nos.	20	0.031	0.62
40	PALAHANA(1x3+0+0+0+0)	T-OFF (for FSP)	Nos.	30	0.031	0.93
41	PATWADH KAUTAK(1x5+0+0+0+0)	T-OFF (for FSP)	Nos.	46	0.031	1.426
42	PAWAI(1x5+1x5+0+0+0)	T-OFF (for FSP)	Nos.	66	0.031	2.046

Abstract : Scope of Work & Estimated Cost

State : UTTAR PRADESH
District : Azamgarh

S.No.	Item of Works	Sub Item	Unit	Quantity	Unit Cost(In Lac)	Total Cost(In Lac)
43	PHOOLPUR(1x8+1x10+0+0+0)	Extension of Control Room	Nos.	1	4.16	4.16
		T-OFF (for FSP)	Nos.	58	0.031	1.798
44	PUSHP NAGAR(1x5+0+0+0+0)	T-OFF (for FSP)	Nos.	25	0.031	0.775
45	RANI KI SARAI(1x3+1x5+0+0+0)	T-OFF (for FSP)	Nos.	41	0.031	1.271
46	RANIPUR(1x5+0+0+0+0)	T-OFF (for FSP)	Nos.	35	0.031	1.085
47	RASEPUR(1x5+0+0+0+0)	T-OFF (for FSP)	Nos.	39	0.031	1.209
48	RAUNAPUR(1x5+1x10+0+0+0)	AUGMENTATION OF POWER TRANSFORMER FROM 5 MVA TO 10 MVA	Nos.	1	113.9	113.9
		T-OFF (for FSP)	Nos.	37	0.031	1.147
49	SARAI MEER(1x5+1x5+0+0+0)	T-OFF (for FSP)	Nos.	34	0.031	1.054
50	SHEIKHPURA(1x5+0+0+0+0)	T-OFF (for FSP)	Nos.	26	0.031	0.806
51	SHERPUR(1x5+0+0+0+0)	T-OFF (for FSP)	Nos.	16	0.031	0.496
52	SIKHULA(1x5+0+0+0+0)	T-OFF (for FSP)	Nos.	27	0.031	0.837
53	SOFIPUR(1x5+1x5+0+0+0)	T-OFF (for FSP)	Nos.	50	0.031	1.55
54	TARWA(1x3+1x5+0+0+0)	T-OFF (for FSP)	Nos.	22	0.031	0.682
55	TEHSIL BURHANPUR(1x5+0+0+0+0)	T-OFF (for FSP)	Nos.	47	0.031	1.457
56	THEKMA(1x3+1x5+0+0+0)	T-OFF (for FSP)	Nos.	45	0.031	1.395
57	ZAFFARPUR(1x5+1x10+0+0+0)	T-OFF (for FSP)	Nos.	19	0.031	0.589
Sub-Total (33/11 KV S/S Augmentation)				2050		580.591
New 11 KV Line						
58	New Feeder 1(Sathiyav (Amilo) To New Location)	PCC POLES WITH RABBIT CONDUCTOR	Kms.	4	4.33	17.32
59	New Feeder 2(Sathiyav (Amilo) To New Location)	PCC POLES WITH RABBIT CONDUCTOR	Kms.	3	4.33	12.99
60	New Feeder 3(Sathiyav (Amilo) To New Location)	PCC POLES WITH RABBIT CONDUCTOR	Kms.	4.37	4.33	18.9221

Abstract : Scope of Work & Estimated Cost

State : UTTAR PRADESH
District : Azamgarh

S.No.	Item of Works	Sub Item	Unit	Quantity	Unit Cost(In Lac)	Total Cost(In Lac)
Sub-Total (New 11 KV Line)				11.37		49.2321
New 33 KV Bay						
61	From Hafizpur To Sathiyav (Amilo)	33 KV Bay	Nos.	1	22	22
Sub-Total (New 33 KV Bay)				1		22
New 33 KV Line						
62	From Hafizpur To Sathiyav (Amilo)	33KV LINE ON PCC POLES WITH DOG CONDUCTOR	Kms.	16	7.29	116.64
Sub-Total (New 33 KV Line)				16		116.64
New 33/11 KV S/S						
63	Sathiyav (Amilo)(1x5)	1x5	Nos.	1	169.95	169.95
Sub-Total (New 33/11 KV S/S)				1		169.95
Total (F.System Strengthening)						969.0031
Grand Total (Total DPR Cost)						15149.0398

Financial Bankability

State : UTTAR PRADESH
District : Azamgarh

*All Amount in Lacs

Total Cost of the Project		Rs.	15149.0398
Benefits of the Scheme			
a. Value of benefit due to sale of additional energy		Rs.	-666.855
b. Value of benefit due to saving in technical loss		Rs.	1092.7735
c. Value of benefit due to saving in commercial loss		Rs.	468.3315
Total financial Benefit		Rs.	894.25
IRR of The Project			0.44097
Year	Outflow	Inflow	
1	50% of Project Cost	6762.9642	
2	50% of Project Cost	6038.36089	20% of Financial Benefites
3			100% of Financial Benefites
4			100% of Financial Benefites
5			100% of Financial Benefites
6			100% of Financial Benefites
7			100% of Financial Benefites
8			100% of Financial Benefites
9			100% of Financial Benefites
10			100% of Financial Benefites
11			100% of Financial Benefites
12			100% of Financial Benefites
13			100% of Financial Benefites
14			100% of Financial Benefites

Financial Bankability

State : UTTAR PRADESH
 District : Azamgarh

15		100% of Financial Benefites	163.37613
16		100% of Financial Benefites	145.87155
17		100% of Financial Benefites	130.24245
18		100% of Financial Benefites	116.2879
19		100% of Financial Benefites	103.82849
20		100% of Financial Benefites	92.704
21		100% of Financial Benefites	82.77143
22		100% of Financial Benefites	73.90306
23		100% of Financial Benefites	65.98488
24		100% of Financial Benefites	58.91507
25		100% of Financial Benefites	52.60274
Total		12801.32509	5644.97715

Electrification of UE villages

State : UTTAR PRADESH

District : Azamgarh

Block-wise coverage of villages

State : UTTAR PRADESH
District : Azamgarh

S.No.	Name of Block	Total no. of villages as per census	Villages proposed under present scheme	Habitations proposed under present scheme	Total RHhs (Incl. BPL Hhs)	No of RHhs already electrified upto 31.03.15	% Electrification as on 31.03.15	RHhs(Incl. BPL) Already sanctioned and under execution in erstwhile RGGVY/State/ other schemes	Balance to be electrified	RHhs Proposed under present scheme	BPL Proposed under present scheme
1	2	3	4	5	6	7	8	9	10	11	12
1	Ahiraula	0	0	0	0	0	0	0	0	0	0
2	Atraulia	0	0	0	0	0	0	0	0	0	0
3	Azmatgarh	0	0	0	0	0	0	0	0	0	0
4	Bilariyaganj	0	0	0	0	0	0	0	0	0	0
5	Haraiya	0	0	0	0	0	0	0	0	0	0
6	Jahanaganj	0	0	0	0	0	0	0	0	0	0
7	Koilsa	0	0	0	0	0	0	0	0	0	0
8	Lalganj	0	0	0	0	0	0	0	0	0	0
9	Mahrajganj	0	0	0	0	0	0	0	0	0	0
10	Martinganj	0	0	0	0	0	0	0	0	0	0
11	Mehnagar	0	0	0	0	0	0	0	0	0	0
12	Mirzapur	0	0	0	0	0	0	0	0	0	0
13	Mohammadpur	0	0	0	0	0	0	0	0	0	0
14	Palhani	0	0	0	0	0	0	0	0	0	0
15	Palhna	0	0	0	0	0	0	0	0	0	0
16	Pawai	0	0	0	0	0	0	0	0	0	0
17	Phulpur	0	0	0	0	0	0	0	0	0	0
18	Rani Ki Sarai	0	0	0	0	0	0	0	0	0	0
19	Sathiyaon	0	0	0	0	0	0	0	0	0	0
20	Tahbarpur	0	0	0	0	0	0	0	0	0	0

Block-wise coverage of villages

State : UTTAR PRADESH
 District : Azamgarh

S.No.	Name of Block	Total no. of villages as per census	Villages proposed under present scheme	Habitations proposed under present scheme	Total RHhs (Incl. BPL Hhs)	No of RHhs already electrified upto 31.03.15	% Electrification as on 31.03.15	RHhs(Incl. BPL) Already sanctioned and under execution in erstwhile RGGVY/State/ other schemes	Balance to be electrified	RHhs Proposed under present scheme	BPL Proposed under present scheme
1	2	3	4	5	6	7	8	9	10	11	12
21	Tarwa	0	0	0	0	0	0	0	0	0	0
22	Thekma	0	0	0	0	0	0	0	0	0	0
Total		0	0	0	0	0	0	0	0	0	0

Existing REDB Infrastructure

State : UTTAR PRADESH
District : Azamgarh

S.No.	Name of Block	Name of SubStation	Type of Sub-Station (33/11 or 66/11 KV)	Power Transformer Detail (MVA)	Total Power Transformer Capacity (MVA)	Constructed Under(Scheme)	GPS Co-ordinate	Name of Feeding EHV SubStation	Distance from Feeding EHV SubStation (in KM)	Type	Existing 11 KV Bay
1	Ahiraula	AHIRAULA	33/11 KV	1x5+0+0+0+0	5	1	N26 12.487 E82 54.959	Phoolpur	22	Radial	3
		MDIYAPAR	33/11 KV	1x5+0+0+0+0	5	1	N26 16.104 E82 55.609	Koilsa	18	Radial	3
		MAHUL	33/11 KV	1x5+0+0+0+0	5	1	N26 08.473 E82 48.518	Phoolpur	8	Radial	1
2	Atraulia	ATRAULIA	33/11 KV	1x5+1x5+0+0+0	10	1	N26 20.672 E82 55.608	Atrauliya	0.2	Radial	5
3	Azmatgarh	AMUWARI NARAINPUR	33/11 KV	1x3+0+0+0+0	3	1	N26 06.496 E83 21.656	Hafizpur	35	LILO	3
		JIYANPUR	33/11 KV	1x5+1x5+0+0+0	10	1	N26 09.522 E83 20.013	Hafizpur	19	Radial	5
		LATGHAT	33/11 KV	1x3+1x5+0+0+0	8	1	N26 13.405 E83 23.210	Dohri ghat (Mau District)	12	Radial	3
		MALTADI	33/11 KV	1x5+0+0+0+0	5	1	N26 10.689 E83 17.335	Dohri ghat (Mau District)	25	LILO	3
4	Bilariyaganj	BILARIYAGANJ	33/11 KV	1x5+1x5+0+0+0	10	1	N26 11.815 E83 14.193	Hafizpur	17	Radial	4
		PATWADH KAUTAK	33/11 KV	1x5+0+0+0+0	5	1	N26 09.246 E83 12.296	Hafizpur	10	LILO	3
5	Haraiya	RAUNAPUR	33/11 KV	1x5+0+0+0+0	5	1	N26 16.787 E83 16.983	Hafizpur	30	LILO	4
		MAU KUTUBPUR	33/11 KV	1x3+0+0+0+0	3	1	N26 14.693 E83 17.184	Dohri ghat (Mau District)	7	LILO	3
6	Jahanaganj	CHANDESHWAR	33/11 KV	1x5+1x5+0+0+0	10	1	N26 00.041 E83 12.475	Sidhari	7	Radial	4
		JAHANGANJ	33/11 KV	1x5+1x5+0+0+0	10	1	N25 56.529 E83 16.391	Sidhari	20	Radial	4
		KANILA	33/11 KV	1x5+0+0+0+0	5	1	N25 53.762 E83 13.272	Sidhari	20	LILO	3

Existing REDB Infrastructure

State : UTTAR PRADESH
District : Azamgarh

S.No.	Name of Block	Name of SubStation	Type of Sub-Station (33/11 or 66/11 KV)	Power Transformer Detail (MVA)	Total Power Transformer Capacity (MVA)	Constructed Under(Scheme)	GPS Co-ordinate	Name of Feeding EHV SubStation	Distance from Feeding EHV SubStation (in KM)	Type	Existing 11 KV Bay
		SHERPUR	33/11 KV	1x5+0+0+0+0	5	1	N25 52.687 E83 17.082	Sidhari	35	LILO	2
7	Koilsa	GOPALGANJ	33/11 KV	1x5+0+0+0+0	5	1	N26 11.818 E82 59.383	Koilsa	20	LILO	2
		RANIPUR	33/11 KV	1x5+0+0+0+0	5	1	N26 16.260 E83 01.383	Koilsa	0.2	LILO	3
		SIKHULA	33/11 KV	1x5+0+0+0+0	5	1	N26 14.798 E82 58.011	Koilsa	31	LILO	3
		TEHSIL BURHANPUR	33/11 KV	1x5+0+0+0+0	5	1	N26 17.224 E82 59.999	Koilsa	15	Radial	3
8	Lalganj	DEOGAON	33/11 KV	1x5+0+0+0+0	5	1	N25 44.522 E82 59.939	Lalganj	7	Radial	3
		LALGANJ	33/11 KV	1x5+1x10+0+0+0	15	1	N25 47.734 E82 59.737	Lalganj	0.05	Radial	5
		JIRAKPUR	33/11 KV	1x5+0+0+0+0	5	1	N25 45.250 E82 56.864	Lalganj	17	Radial	2
		GOSAI KI BAZAR	33/11 KV	1x5+0+0+0+0	5	1	N25 51.259 E83 00.705	Lalganj	8	Radial	3
9	Mahrajanj	MAHRAJGANJ	33/11 KV	1x3+1x5+0+0+0	8	1	N26 15.231 E83 07.230	Koilsa	10	LILO	4
		KAPTANGANJ	33/11 KV	1x3+1x5+0+0+0	8	1	N26 12.381 E83 05.103	Koilsa	10	Radial	4
10	Martinganj	MARTINGANJ	33/11 KV	1x5+0+0+0+0	5	1	N25 54.5081 E82 48.4127	Lalganj	35	LILO	3
11	Mehnnagar	MEH NAGAR	33/11 KV	1x5+1x5+0+0+0	10	1	N25 53.351 E83 05.641	Meh Nagar	1	Radial	4
		KHAMARIYA	33/11 KV	1x5+0+0+0+0	5	1	N25 48.663 E83 12.235	Lalganj	32	LILO	2
12	Mirzapur	DATTATREYA	33/11 KV	1x5+0+0+0+0	5	1	N26 03.683 E83 01.383	Phoolpur	17	Radial	3

Existing REDB Infrastructure

State : UTTAR PRADESH
District : Azamgarh

S.No.	Name of Block	Name of SubStation	Type of Sub-Station (33/11 or 66/11 KV)	Power Transformer Detail (MVA)	Total Power Transformer Capacity (MVA)	Constructed Under(Scheme)	GPS Co-ordinate	Name of Feeding EHV SubStation	Distance from Feeding EHV SubStation (in KM)	Type	Existing 11 KV Bay
		SARAI MEER	33/11 KV	1x5+1x5+0+0+0	10	1	N26 01.544 E82 53.791	Phoolpur	10	Radial	3
13	Mohammadpur	CHHAU	33/11 KV	1x5+0+0+0+0	5	1	N25 56.828 E82 57.078	Lalganj	32	LILO	3
		MUHAMMAD PUR	33/11 KV	1x5+1x5+0+0+0	10	1	N25 56.902 E83 01.669	Sidhari	22	Radial	4
		GOTHAWAN	33/11 KV	1x5+0+0+0+0	5	1	N25 56.213 E82 54.166	Lalganj	20	LILO	2
14	Palhani	ZAFFARPUR	33/11 KV	1x5+1x10+0+0+0	15	1	N26 02.620 E83 09.220	Hafizpur	18	LILO	4
15	Palhna	SHEIKHPURA	33/11 KV	1x5+0+0+0+0	5	1	N26 04.284 E83 12.378	Hafizpur	2	Radial	2
		KARSARA	33/11 KV	1x5+0+0+0+0	5	1	N25 43.438 E83 05.619	Lalganj	20	LILO	3
		PALAHANA	33/11 KV	1x3+0+0+0+0	3	1	N25 45.993 E83 04.677	Lalganj	10.5	LILO	2
		BHAWAR NATH	33/11 KV	1x5+1x10+0+0+0	15	1	N26 05.621 E83 09.412	Hafizpur	5	Radial	3
		KANDHARPUR	33/11 KV	1x5+0+0+0+0	5	1	N26 08.031 E83 07.675	Hafizpur	35	Radial	2
16	Pawai	BAGH BAHAR	33/11 KV	1x5+0+0+0+0	5	1	N26 08.668 E82 42.871	Phoolpur	20	LILO	3
		PAWAI	33/11 KV	1x5+1x5+0+0+0	10	1	N26 10.523 E82 43.731	Phoolpur	17	Radial	4
17	Phulpur	PHOOLPUR	33/11 KV	1x8+1x10+0+0+0	18	1	N26 05.607 E82 52.054	Phoolpur	1	Radial	6
		GADDO PUR	33/11 KV	1x5+0+0+0+0	5	1	N26 02.598 E82 47.620	Phoolpur	20	LILO	2
		PUSHP NAGAR	33/11 KV	1x5+0+0+0+0	5	1	N26 00.345 E82 48.169	Phoolpur	16	LILO	3

Existing REDB Infrastructure

State : UTTAR PRADESH
District : Azamgarh

S.No.	Name of Block	Name of SubStation	Type of Sub-Station (33/11 or 66/11 KV)	Power Transformer Detail (MVA)	Total Power Transformer Capacity (MVA)	Constructed Under(Scheme)	GPS Co-ordinate	Name of Feeding EHV SubStation	Distance from Feeding EHV SubStation (in KM)	Type	Existing 11 KV Bay
18	Rani Ki Sarai	RANI KI SARAI	33/11 KV	1x3+1x5+0+0+0	8	1	N25 59.755 E83 05.513	Sidhari	12	LILO	3
19	Sathiyaon	MOHABBATPUR	33/11 KV	1x5+0+0+0+0	5	1	N26 03.582 E83 14.569	Hafizpur	12	LILO	2
		MUBARAKPUR	33/11 KV	1x10+1x10+0+0+0	20	1	N26 04.648 E83 17.700	Hafizpur	18	Radial	5
20	Tahbarpur	SOFIPUR	33/11 KV	1x5+1x5+0+0+0	10	1	N26 05.414 E83 04.226	Sidhari	20	Radial	4
		ORA	33/11 KV	1x3+0+0+0+0	3	1	N26 08.935 E83 03.324	Sidhari	28	LILO	3
		MANJHARI	33/11 KV	1x5+0+0+0+0	5	1	N26 06.865 E83 00.469	Phoolpur	21	LILO	3
21	Tarwa	RASEPUR	33/11 KV	1x5+0+0+0+0	5	1	N25 50.090 E83 18.898	Sidhari	50	LILO	3
		TARWA	33/11 KV	1x3+1x5+0+0+0	8	1	N25 45.858 E83 11.025	Lalganj	20	Radial	4
		MEHNAJPUR	33/11 KV	1x5+0+0+0+0	5	1	N25 40.749 E83 06.729	Lalganj	30	LILO	3
22	Thekma	BARDAH	33/11 KV	1x5+0+0+0+0	5	1	N25 48.373 E82 50.762	Lalganj	20	Radial	3
		THEKMA	33/11 KV	1x3+1x5+0+0+0	8	1	N25 51.783 E82 55.463	Lalganj	17	Radial	4
Total					398						

Block-Wise Substation

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of Block	Existing 33/11 kV Sub-Station as on 31.03.2015		33/11 kV Sub-Station already sanctioned and under execution in RGGVY/State/Other schemes as on 31.03.2015		New 33/11 kV Sub-Stations proposed under present scheme		Aug of existing 33/11kV Sub-Stations proposed in the scheme		Total 33/11 kV	
		No. of S/s (Nos)	PT Capacity (MVA)	No. of S/s (Nos)	PT Capacity (MVA)	No. of S/s (Nos)	PT Capacity (MVA)	No. of S/s (Nos)	PT Capacity (MVA)	No. of S/s (Nos)	PT Capacity (MVA)
1	Ahiraula	3	15	0	0	0	0	0	0	3	15
2	Atraulia	1	10	0	0	0	0	0	0	1	10
3	Azmatgarh	4	26	0	0	0	0	0	0	4	26
4	Bilariyaganj	2	15	0	0	0	0	0	0	2	15
5	Haraiya	2	8	0	0	0	0	0	0	2	8
6	Jahanaganj	4	30	0	0	0	0	0	0	4	30
7	Koilsa	4	20	0	0	0	0	0	0	4	20
8	Lalganj	4	30	0	0	0	0	0	0	4	30
9	Mahrajanj	2	16	0	0	0	0	0	0	2	16
10	Martinganj	1	5	0	0	0	0	0	0	1	5
11	Mehnagar	2	15	0	0	0	0	0	0	2	15
12	Mirzapur	2	15	0	0	0	0	0	0	2	15
13	Mohammadpur	3	20	0	0	0	0	0	0	3	20
14	Palhani	1	15	0	0	0	0	0	0	1	15
15	Palhna	5	33	0	0	0	0	0	0	5	33
16	Pawai	2	15	0	0	0	0	0	0	2	15
17	Phulpur	3	28	0	0	0	0	0	0	3	28
18	Rani Ki Sarai	1	8	0	0	0	0	0	0	1	8
19	Sathiyaon	2	25	0	0	0	0	0	0	2	25
20	Tahbarpur	3	18	0	0	0	0	0	0	3	18

Block-Wise Substation

State : UTTAR PRADESH
 District : Azamgarh

Sl.No.	Name of Block	Existing 33/11 kV Sub-Station as on 31.03.2015		33/11 kV Sub-Station already sanctioned and under execution in RGGVY/State/Other schemes as on 31.03.2015		New 33/11 kV Sub-Stations proposed under present scheme		Aug of existing 33/11kV Sub-Stations proposed in the scheme		Total 33/11 kV	
		No. of S/s (Nos)	PT Capacity (MVA)	No. of S/s (Nos)	PT Capacity (MVA)	No. of S/s (Nos)	PT Capacity (MVA)	No. of S/s (Nos)	PT Capacity (MVA)	No. of S/s (Nos)	PT Capacity (MVA)
21	Tarwa	3	18	0	0	0	0	0	0	3	18
22	Thekma	2	13	0	0	0	0	0	0	2	13

Feederwise DTs

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of Block	Name of 33/11 KV Source Substation	Name of 11 KV or 22 KV Feeder	Existing Distribution Transformer (DTs) as on 31.03.2015		Already sanctioned and under execution in RGGVY/State/Other schemes		DTs proposed to be installed under present scheme		Total DT capacity	
1	Ahraula	AHIRAULA	Ahraula	100	5.89	37	0.96	0	0	100	5.89
		AHIRAULA	Atraulia	83	2.41	31	0.81	0	0	83	2.41
		AHIRAULA	Kaptanganj	73	1.87	28	0.74	0	0	73	1.87
		MDIYAPAR	Karsara	69	1.78	25	0.63	0	0	69	1.78
		MDIYAPAR	Bhedaura	98	2.64	37	0.96	0	0	98	2.64
		MDIYAPAR	Badhiya	51	1.63	19	0.48	0	0	51	1.63
		MAHUL	Bazar Gosai	98	2.02	37	0.96	0	0	98	2.02
2	Atraulia	ATRAULIA	ATRAULIA	96	2.83	36	0.94	0	0	96	2.83
		ATRAULIA	WEST	77	2.09	29	0.76	0	0	77	2.09
		ATRAULIA	EAST	72	2	27	0.71	0	0	72	2
		ATRAULIA	NORTH	85	3.32	32	0.84	0	0	85	3.32
		ATRAULIA	West 2	56	2.61	20	0.5	0	0	56	2.61
3	Azmatgarh	AMUWARI NARAINPUR	East	74	3.5	28	0.74	0	0	74	3.5
		AMUWARI NARAINPUR	West	70	2.06	25	0.63	0	0	70	2.06
		AMUWARI NARAINPUR	Bhuana	76	2.84	29	0.76	0	0	76	2.84
		JIYANPUR	North	53	2.79	19	0.48	0	0	53	2.79
		JIYANPUR	East	90	3.04	34	0.89	0	0	90	3.04
		JIYANPUR	West	88	2.43	33	0.86	0	0	88	2.43
		LATGHAT	Kaithauli	109	2.71	41	1.06	0	0	109	2.71
		LATGHAT	Mahula	94	2.27	35	0.91	0	0	94	2.27
		LATGHAT	Bardeeha	74	2.11	28	0.74	0	0	74	2.11

Feederwise DTs

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of Block	Name of 33/11 KV Source Substation	Name of 11 KV or 22 KV Feeder	Existing Distribution Transformer (DTs) as on 31.03.2015		Already sanctioned and under execution in RGGVY/State/Other schemes		DTs proposed to be installed under present scheme		Total DT capacity	
		MALTADI	Basgaon	105	4.33	39	1.01	0	0	105	4.33
		MALTADI	North	74	1.8	28	0.74	0	0	74	1.8
		MALTADI	West	82	2.08	31	0.81	0	0	82	2.08
4	Bilariyaganj	BILARIYAGANJ	North	94	3.6	35	0.91	0	0	94	3.6
		BILARIYAGANJ	East	84	4.48	32	0.84	0	0	84	4.48
		BILARIYAGANJ	West	114	4.41	42	1.09	0	0	114	4.41
		PATWADH KAUTAK	EAST	98	2.85	37	0.96	0	0	98	2.85
		PATWADH KAUTAK	West	93	3.72	35	0.91	0	0	93	3.72
		PATWADH KAUTAK	South	97	2.95	36	0.94	0	0	97	2.95
5	Haraiya	RAUNAPUR	West	78	2.69	29	0.76	0	0	78	2.69
		RAUNAPUR	East	85	3.11	32	0.84	0	0	85	3.11
		RAUNAPUR	South	132	5.1	49	1.26	0	0	132	5.1
		MAU KUTUBPUR	North	41	0.74	15	0.38	0	0	41	0.74
		MAU KUTUBPUR	West	33	0.72	12	0.3	0	0	33	0.72
		MAU KUTUBPUR	Bazar Gosai	83	4.04	31	0.81	0	0	83	4.04
6	Jahanaganj	CHANDESHWAR	Nibi	90	4.85	34	0.89	0	0	90	4.85
		CHANDESHWAR	Sameda	55	0.77	20	0.5	0	0	55	0.77
		CHANDESHWAR	Karanpur	74	3.63	28	0.74	0	0	74	3.63
		JAHANGANJ	Jahanaganj	78	2.26	29	0.76	0	0	78	2.26
		JAHANGANJ	Parasi	66	2.95	24	0.6	0	0	66	2.95
		JAHANGANJ	Godhawra	66	3.24	24	0.6	0	0	66	3.24

Feederwise DTs

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of Block	Name of 33/11 KV Source Substation	Name of 11 KV or 22 KV Feeder	Existing Distribution Transformer (DTs) as on 31.03.2015		Already sanctioned and under execution in RGGVY/State/Other schemes		DTs proposed to be installed under present scheme		Total DT capacity	
		JAHANGANJ	Sumbhi	109	3.97	41	1.06	0	0	109	3.97
		KANILA	Barora	99	3.78	37	0.96	0	0	99	3.78
		KANILA	Jigarsandi	87	2.79	33	0.86	0	0	87	2.79
		SHERPUR	Sherpur Kuti	35	0.9	13	0.33	0	0	35	0.9
		SHERPUR	Parsaha	29	0.56	11	0.28	0	0	29	0.56
7	Koilsa	GOPALGANJ	Gopalganj	92	2.76	34	0.89	0	0	92	2.76
		GOPALGANJ	Marfora	68	2.1	25	0.63	0	0	68	2.1
		RANIPUR	Khatoliya Feeder	47	0.92	17	0.43	0	0	47	0.92
		RANIPUR	Tonari Feeder	72	1.6	27	0.71	0	0	72	1.6
		RANIPUR	Koilsa Feeder	92	3.77	34	0.89	0	0	92	3.77
		SIKHULA	Sultanipuri	97	2.14	36	0.94	0	0	97	2.14
		SIKHULA	Chimkuni	58	0.94	21	0.53	0	0	58	0.94
		TEHSIL BURHANPUR	Basgan	80	2.89	30	0.79	0	0	80	2.89
		TEHSIL BURHANPUR	Bheelampur	48	1.24	17	0.43	0	0	48	1.24
		TEHSIL BURHANPUR	Makhanaha	72	2	42	1.09	0	0	72	2
8	Lalganj	DEOGAON	Deogaon	74	2.04	28	0.74	0	0	74	2.04
		DEOGAON	Kanhjit	121	4.1	45	1.16	0	0	121	4.1
		DEOGAON	Basahi	91	2.64	34	0.89	0	0	91	2.64
		LALGANJ	Sonwar	89	2.77	33	0.86	0	0	89	2.77
		LALGANJ	Gosai bazar	93	2.94	35	0.91	0	0	93	2.94
		LALGANJ	Devgaon	77	1.8	29	0.76	0	0	77	1.8

Feederwise DTs

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of Block	Name of 33/11 KV Source Substation	Name of 11 KV or 22 KV Feeder	Existing Distribution Transformer (DTs) as on 31.03.2015		Already sanctioned and under execution in RGGVY/State/Other schemes		DTs proposed to be installed under present scheme		Total DT capacity	
		LALGANJ	Lumbhua	97	3.05	36	0.94	0	0	97	3.05
		JIRAKPUR	Sikraura	83	2.77	31	0.81	0	0	83	2.77
		JIRAKPUR	Agehta	55	2.36	20	0.5	0	0	55	2.36
		GOSAI KI BAZAR	Ubarpur	73	1.7	28	0.74	0	0	73	1.7
		GOSAI KI BAZAR	Gosai ki Bazar	79	1.55	30	0.79	0	0	79	1.55
		GOSAI KI BAZAR	Pandaha	92	3.06	34	0.89	0	0	92	3.06
9	Mahrajanj	MAHRAJGANJ	West	84	3.27	32	0.84	0	0	84	3.27
		MAHRAJGANJ	East	111	7.62	41	1.06	0	0	111	7.62
		MAHRAJGANJ	North	81	3.62	30	0.79	0	0	81	3.62
		MAHRAJGANJ	World bank	60	1.8	22	0.55	0	0	60	1.8
		KAPTANGANJ	Bhawanpur	85	2.45	32	0.84	0	0	85	2.45
		KAPTANGANJ	kaptanganj	43	1.42	16	0.4	0	0	43	1.42
		KAPTANGANJ	Deoria	86	2.32	32	0.84	0	0	86	2.32
		KAPTANGANJ	Mehmauni	74	2.04	28	0.74	0	0	74	2.04
10	Martinganj	MARTINGANJ	Bakhara Feeder	66	2.93	24	0.6	0	0	66	2.93
		MARTINGANJ	Siswara Feeder	66	2.09	24	0.6	0	0	66	2.09
		MARTINGANJ	Belwana Feeder	112	5.54	42	1.09	0	0	112	5.54
11	Mehnagar	MEH NAGAR	Laudah	87	2.5	33	0.86	0	0	87	2.5
		MEH NAGAR	Chakwara	75	1.4	28	0.74	0	0	75	1.4
		MEH NAGAR	Kharag Pur	39	1.34	14	0.35	0	0	39	1.34
		KHAMARIYA	Khatahan	110	2.87	40	1	0	0	110	2.87

Feederwise DTs

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of Block	Name of 33/11 KV Source Substation	Name of 11 KV or 22 KV Feeder	Existing Distribution Transformer (DTs) as on 31.03.2015		Already sanctioned and under execution in RGGVY/State/Other schemes		DTs proposed to be installed under present scheme		Total DT capacity	
		KHAMARIYA	Kamharia	128	4.06	47	1.18	0	0	128	4.06
12	Mirzapur	DATTATREYA	Nizamabad	64	2.09	23	0.58	0	0	64	2.09
		DATTATREYA	Mirzapur	102	3.17	38	0.99	0	0	102	3.17
		DATTATREYA	Mohnathpur	90	2.87	34	0.89	0	0	90	2.87
		SARAI MEER	Basti	64	1.49	23	0.58	0	0	64	1.49
		SARAI MEER	Nandau	90	3.18	34	0.89	0	0	90	3.18
13	Mohammadpur	CHHAU	Belu	149	5.92	55	1.41	0	0	149	5.92
		CHHAU	Chhau	60	1.69	22	0.55	0	0	60	1.69
		CHHAU	Gambhirpur	51	1.13	19	0.48	0	0	51	1.13
		MUHAMMAD PUR	North	51	1.58	19	0.48	0	0	51	1.58
		MUHAMMAD PUR	South	136	4.68	51	1.31	0	0	136	4.68
		MUHAMMAD PUR	Rowa	101	3.82	38	0.99	0	0	101	3.82
		MUHAMMAD PUR	Bindra Bazar	21	0.3	8	0.2	0	0	21	0.3
		GOTHAWAN	Gothawan	87	2.27	33	0.86	0	0	87	2.27
		GOTHAWAN	Nandaoh	65	2.87	24	0.6	0	0	65	2.87
14	Palhani	ZAFFARPUR	South	186	5.35	69	1.76	0	0	186	5.35
15	Palhna	SHEIKHPURA	Ahopatti	109	4.76	41	1.06	0	0	109	4.76
		SHEIKHPURA	Badhopur	62	1.74	23	0.58	0	0	62	1.74
		KARSARA	Chutara	29	0.73	11	0.28	0	0	29	0.73
		KARSARA	Karsara	154	5.84	57	1.46	0	0	154	5.84
		KARSARA	Bela	42	0.61	15	0.38	0	0	42	0.61

Feederwise DTs

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of Block	Name of 33/11 KV Source Substation	Name of 11 KV or 22 KV Feeder	Existing Distribution Transformer (DTs) as on 31.03.2015		Already sanctioned and under execution in RGGVY/State/Other schemes		DTs proposed to be installed under present scheme		Total DT capacity	
		PALAHANA	Palahana	77	2.48	28	0.7	0	0	77	2.48
		PALAHANA	Lhua	107	4.12	39	0.98	0	0	107	4.12
		BHAWAR NATH	Heera palti	111	2.53	41	1.06	0	0	111	2.53
		BHAWAR NATH	Kandharapur	88	2.11	33	0.86	0	0	88	2.11
		KANDHARPUR	Azampur	75	1.71	28	0.74	0	0	75	1.71
		KANDHARPUR	Kandharpur	69	1.99	25	0.63	0	0	69	1.99
16	Pawai	BAGH BAHAR	Kalan	72	2.34	27	0.71	0	0	72	2.34
		BAGH BAHAR	Sahdulla	68	2.91	25	0.63	0	0	68	2.91
		BAGH BAHAR	Khairuddinpur	82	2.59	31	0.81	0	0	82	2.59
		PAWAI	Mahul Feeder	85	5.22	32	0.84	0	0	85	5.22
		PAWAI	Belwai Feeder	102	4.53	38	0.99	0	0	102	4.53
		PAWAI	Balaipur Feeder	78	4.02	29	0.76	0	0	78	4.02
		PAWAI	Pawai	62	1.41	23	0.58	0	0	62	1.41
17	Phulpur	PHOOLPUR	North	109	2.91	41	1.06	0	0	109	2.91
		PHOOLPUR	West	71	3.03	26	0.65	0	0	71	3.03
		PHOOLPUR	East	71	1.77	26	0.65	0	0	71	1.77
		PHOOLPUR	South	71	1.92	26	0.65	0	0	71	1.92
		GADDO PUR	Palthi	60	3.19	22	0.55	0	0	60	3.19
		GADDO PUR	Gaddo Pur	85	2.86	31	0.78	0	0	85	2.86
		PUSHP NAGAR	Deedarganj	73	2.52	27	0.68	0	0	73	2.52
		PUSHP NAGAR	Sikraura	37	1.27	13	0.33	0	0	37	1.27

Feederwise DTs

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of Block	Name of 33/11 KV Source Substation	Name of 11 KV or 22 KV Feeder	Existing Distribution Transformer (DTs) as on 31.03.2015		Already sanctioned and under execution in RGGVY/State/Other schemes		DTs proposed to be installed under present scheme		Total DT capacity	
18	Rani Ki Sarai	RANI KI SARAI	Rani ki sarai	74	2.16	28	0.74	0	0	74	2.16
		RANI KI SARAI	Sonwara	111	3.76	41	1.06	0	0	111	3.76
		RANI KI SARAI	Vasti	75	2.09	28	0.74	0	0	75	2.09
19	Sathiyaon	MOHABBATPUR	Shahgarh	77	2.09	29	0.76	0	0	77	2.09
		MOHABBATPUR	Bamhaur	91	3.32	34	0.89	0	0	91	3.32
		MUBARAKPUR	Newada Rural	98	3.57	37	0.96	0	0	98	3.57
		MUBARAKPUR	Sthiyaon	79	2.52	30	0.79	0	0	79	2.52
20	Tahbarpur	SOFIPUR	Nizamabad	101	3.82	38	0.99	0	0	101	3.82
		SOFIPUR	Semari	51	1.24	19	0.48	0	0	51	1.24
		SOFIPUR	Nizamabad 2	86	3.37	32	0.84	0	0	86	3.37
		SOFIPUR	Tahbarpur	90	4.36	34	0.89	0	0	90	4.36
		ORA	Ora	75	1.37	28	0.74	0	0	75	1.37
		ORA	Deohatta	35	0.78	13	0.33	0	0	35	0.78
		ORA	Sarai Barkat	30	1.05	11	0.28	0	0	30	1.05
		MANJHARI	Dhania kundi	37	1.01	13	0.33	0	0	37	1.01
		MANJHARI	Manjhari	19	0.27	7	0.18	0	0	19	0.27
		MANJHARI	Kariawar	39	1.22	14	0.35	0	0	39	1.22
21	Tarwa	RASEPUR	Kanchanpur	89	4.11	33	0.86	0	0	89	4.11
		RASEPUR	Sherpur	102	3.86	38	0.99	0	0	102	3.86
		RASEPUR	Bongariya	86	2.73	32	0.84	0	0	86	2.73
		TARWA	Sidhauna	93	2.8	35	0.91	0	0	93	2.8

Feederwise DTs

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of Block	Name of 33/11 KV Source Substation	Name of 11 KV or 22 KV Feeder	Existing Distribution Transformer (DTs) as on 31.03.2015		Already sanctioned and under execution in RGGVY/State/Other schemes		DTs proposed to be installed under present scheme		Total DT capacity	
		TARWA	Meh Nagar	43	0.98	16	0.4	0	0	43	0.98
		TARWA	Mehnajpur	17	0.49	6	0.15	0	0	17	0.49
		MEHNAJPUR	Nath PUR	79	2.66	30	0.79	0	0	79	2.66
		MEHNAJPUR	Rowa para	86	3.03	32	0.84	0	0	86	3.03
		MEHNAJPUR	Mehnaj Pur	84	2.71	32	0.84	0	0	84	2.71
22	Thekma	BARDAH	Bardah	67	2.15	24	0.6	0	0	67	2.15
		BARDAH	Bahadurpur	109	3.82	41	1.06	0	0	109	3.82
		BARDAH	Jiblee	70	2.03	25	0.63	0	0	70	2.03
		THEKMA	Tahbarpur	105	3.14	38	0.95	0	0	105	3.14
		THEKMA	Sarai Mohan	85	2.65	31	0.78	0	0	85	2.65
		THEKMA	Thekma	112	3.98	42	1.09	0	0	112	3.98

Feeder Segregation

State : UTTAR PRADESH

District : Azamgarh

Details of New 11 KV or 22 KV Lines

State : UTTAR PRADESH
District : Azamgarh

S.No.	Name of Block	Name of Emanating Substation	Name of feeder	Section of Feeder		Line Type	Length(k ms.)	Nos of Bay (If required)	Remarks	Line on ABC cable in Forest Area/Populated Area	Length of ABC cable (Kms.)
				From Location	To Location						
1	2	3	4	5	6	7	8	9	10	11	12
1	Ahiraula	AHIRAULA	New Feeder-1	AHIRAULA	New Location	PCC POLES WITH RABBIT CONDUCTOR	15	1			0
		MDIYAPAR	New Feeder-1	Mdiyapar	New Location	PCC POLES WITH RABBIT CONDUCTOR	12	1			0
		MDIYAPAR	New Feeder-2	Mdiyapar	New Location	PCC POLES WITH RABBIT CONDUCTOR	12	1			0
		MAHUL	New Feeder-2	MAHUL	New Loaction	PCC POLES WITH RABBIT CONDUCTOR	24	1			0
2	Atraulia	ATRAULIA	New Feeder-1	Atraulia	New Location	PCC POLES WITH RABBIT CONDUCTOR	11.4	1			0
3	Azmatgarh	AMUWARI NARAINPUR	New Feeder-1	AMUWARI NARAINPUR	New Location	PCC POLES WITH RABBIT CONDUCTOR	20	0			0
		AMUWARI NARAINPUR	New Feeder-2	AMUWARI NARAINPUR	New Location	PCC POLES WITH RABBIT CONDUCTOR	15	0			0
		JIYANPUR	New Feeder-1	JIYANPUR	New Location	PCC POLES WITH RABBIT CONDUCTOR	10	0			0
		JIYANPUR	New Feeder-2	JIYANPUR	New Location	PCC POLES WITH RABBIT CONDUCTOR	14	0			0
		LATGHAT	New Feeder-1	LATGHAT	New Location	PCC POLES WITH RABBIT CONDUCTOR	10	0			0
		LATGHAT	New Feeder-2	LATGHAT	New Location	PCC POLES WITH RABBIT CONDUCTOR	15.13	0			0
4	Bilariyaganj	BILARIYAGANJ	New Feeder-1	BILARIYAG ANJ	New Location	PCC POLES WITH RABBIT CONDUCTOR	13	1			0
		BILARIYAGANJ	New Feeder-2	BILARIYAG ANJ	New Location	PCC POLES WITH RABBIT CONDUCTOR	12	1			0

Details of New 11 KV or 22 KV Lines

State : UTTAR PRADESH
District : Azamgarh

S.No.	Name of Block	Name of Emanating Substation	Name of feeder	Section of Feeder		Line Type	Length(k ms.)	Nos of Bay (If required)	Remarks	Line on ABC cable in Forest Area/Populated Area	Length of ABC cable (Kms.)
				From Location	To Location						
1	2	3	4	5	6	7	8	9	10	11	12
		PATWADH KAUTAK	New Feeder-1	PATWADH KAUTAK	New Location	PCC POLES WITH RABBIT CONDUCTOR	9	1			0
5	Haraiya	RAUNAPUR	New Feeder-1	RAUNAPUR	New Location	PCC POLES WITH RABBIT CONDUCTOR	11	1			0
		MAU KUTUBPUR	New Feeder-1	Mau Kutubpur	New Location	PCC POLES WITH RABBIT CONDUCTOR	16	1			0
6	Jahanaganj	CHANDESHWAR	New Feeder-1	CHANDESHWAR	New Location	PCC POLES WITH RABBIT CONDUCTOR	16	1			0
		CHANDESHWAR	New Feeder-2	CHANDESHWAR	New Location	PCC POLES WITH RABBIT CONDUCTOR	10	1			0
		JAHANGANJ	New Feeder-1	JAHANGANJ	New Location	PCC POLES WITH RABBIT CONDUCTOR	11	1			0
		JAHANGANJ	New Feeder-2	JAHANGANJ	New Location	PCC POLES WITH RABBIT CONDUCTOR	13	1			0
		KANILA	New Feeder-1	KANILA	New Location	PCC POLES WITH RABBIT CONDUCTOR	12	1			0
		SHERPUR	New Feeder-1	SHERPUR	New Location	PCC POLES WITH RABBIT CONDUCTOR	10	1			0
7	Koilsa	GOPALGANJ	New Feeder-1	GOPALGANJ	New Location	PCC POLES WITH RABBIT CONDUCTOR	10	1			0
		RANIPUR	New Feeder-1	RANIPUR	New Location	PCC POLES WITH RABBIT CONDUCTOR	14.4	1			0
		SIKHULA	New Feeder-1	SIKHULA	New Location	PCC POLES WITH RABBIT CONDUCTOR	20	1			0
		TEHSIL BURHANPUR	New Feeder-1	TEHSIL BURHANPUR	New Location	PCC POLES WITH RABBIT CONDUCTOR	11.4	1			0

Details of New 11 KV or 22 KV Lines

State : UTTAR PRADESH
District : Azamgarh

S.No.	Name of Block	Name of Emanating Substation	Name of feeder	Section of Feeder		Line Type	Length(k ms.)	Nos of Bay (If required)	Remarks	Line on ABC cable in Forest Area/Populated Area	Length of ABC cable (Kms.)
				From Location	To Location						
1	2	3	4	5	6	7	8	9	10	11	12
8	Lalganj	DEOGAON	New Feeder-1	DEOGAON	New Location	PCC POLES WITH RABBIT CONDUCTOR	10.74	1			0
		LALGANJ	New Feeder-1	LALGANJ	New Location	PCC POLES WITH RABBIT CONDUCTOR	10	1			0
		LALGANJ	New Feeder-2	LALGANJ	New Location	PCC POLES WITH RABBIT CONDUCTOR	20	1			0
		JIRAKPUR	New Feeder-1	JIRAKPUR	New Location	PCC POLES WITH RABBIT CONDUCTOR	10.2	1			0
		GOSAI KI BAZAR	New Feeder-1	GOSAI KI BAZAR	New Location	PCC POLES WITH RABBIT CONDUCTOR	12	1			0
9	Mahrajanj	MAHRAJGANJ	New Feeder-1	MAHRAJGANJ	New Location	PCC POLES WITH RABBIT CONDUCTOR	13	1			0
		KAPTANGANJ	New Feeder-1	KAPTANGANJ	New Location	PCC POLES WITH RABBIT CONDUCTOR	10.2	1			0
10	Martinganj	MARTINGANJ	New Feeder-1	Martinganj	New Location	PCC POLES WITH RABBIT CONDUCTOR	34	1			0
11	Mehnagar	MEH NAGAR	New Feeder-1	MEH NAGAR	New Location	PCC POLES WITH RABBIT CONDUCTOR	8	1			0
		MEH NAGAR	New Feeder-2	MEH NAGAR	New Location	PCC POLES WITH RABBIT CONDUCTOR	15	1			0
		KHAMARIYA	New Feeder-1	KHAMARIYA	New Location	PCC POLES WITH RABBIT CONDUCTOR	10.2	1			0
12	Mirzapur	DATTATREYA	New Feeder-1	DATTATREYA	New Location	PCC POLES WITH RABBIT CONDUCTOR	14	1			0
		SARAI MEER	New Feeder-1	SARAI MEER	New Location	PCC POLES WITH RABBIT CONDUCTOR	9	1			0

Details of New 11 KV or 22 KV Lines

State : UTTAR PRADESH
District : Azamgarh

S.No.	Name of Block	Name of Emanating Substation	Name of feeder	Section of Feeder		Line Type	Length(k ms.)	Nos of Bay (If required)	Remarks	Line on ABC cable in Forest Area/Populated Area	Length of ABC cable (Kms.)
				From Location	To Location						
1	2	3	4	5	6	7	8	9	10	11	12
		SARAI MEER	New Feeder-2	SARAI MEER	New Location	PCC POLES WITH RABBIT CONDUCTOR	14	1			0
13	Mohammadpur	CHHAU	New Feeder-1	CHHAU	New Location	PCC POLES WITH RABBIT CONDUCTOR	10	1			0
		MUHAMMAD PUR	New Feeder-1	MUHAMMAD PUR	New Location	PCC POLES WITH RABBIT CONDUCTOR	28	1			0
		GOTHAWAN	New Feeder-1	GOTHAWAN	New Location	PCC POLES WITH RABBIT CONDUCTOR	15.3	1			0
14	Palhani	ZAFFARPUR	New Feeder-1	ZAFFARPUR	New Location	PCC POLES WITH RABBIT CONDUCTOR	10	1			0
15	Palhna	SHEIKHPURA	New Feeder-1	Sheikhpura	New Location	PCC POLES WITH RABBIT CONDUCTOR	15	1			0
		KARSARA	New Feeder-1	KARSARA	New Location	PCC POLES WITH RABBIT CONDUCTOR	7.8	1			0
		PALAHANA	New Feeder-1	PALAHANA	New Location	PCC POLES WITH RABBIT CONDUCTOR	10.2	1			0
		BHAWAR NATH	New Feeder-1	BHAWAR NATH	New Location	PCC POLES WITH RABBIT CONDUCTOR	14	1			0
		BHAWAR NATH	New Feeder-2	BHAWAR NATH	New Location	PCC POLES WITH RABBIT CONDUCTOR	17	1			0
		KANDHARPUR	New Feeder-1	KANDHARPUR	New Location	PCC POLES WITH RABBIT CONDUCTOR	10.2	1			0
16	Pawai	BAGH BAHAR	New Feeder-1	Khairuddinpur	New Location	PCC POLES WITH RABBIT CONDUCTOR	20	1			0
		PAWAI	New Feeder-1	Pawai	New Location	PCC POLES WITH RABBIT CONDUCTOR	13	1			0
17	Phulpur	PHOOLPUR	New Feeder-1	PHOOLPUR	New Location	PCC POLES WITH RABBIT CONDUCTOR	24	1			0

Details of New 11 KV or 22 KV Lines

State : UTTAR PRADESH
District : Azamgarh

S.No.	Name of Block	Name of Emanating Substation	Name of feeder	Section of Feeder		Line Type	Length(k ms.)	Nos of Bay (If required)	Remarks	Line on ABC cable in Forest Area/Populated Area	Length of ABC cable (Kms.)
				From Location	To Location						
1	2	3	4	5	6	7	8	9	10	11	12
		PHOOLPUR	New Feeder-2	PHOOLPUR	New Location	PCC POLES WITH RABBIT CONDUCTOR	10	1			0
		GADDO PUR	New Feeder-1	GADDO PUR	New Location	PCC POLES WITH RABBIT CONDUCTOR	15	1			0
		PUSHP NAGAR	New Feeder-1	PUSHP NAGAR	New Location	PCC POLES WITH RABBIT CONDUCTOR	13	1			0
18	Rani Ki Sarai	RANI KI SARAI	New Feeder-1	RANI KI SARAI	New Location	PCC POLES WITH RABBIT CONDUCTOR	11	1			0
		RANI KI SARAI	New Feeder-2	RANI KI SARAI	New Location	PCC POLES WITH RABBIT CONDUCTOR	10	1			0
19	Sathiyaon	MOHABBATPUR	New Feeder-1	MOHABBAT PUR	New Location	PCC POLES WITH RABBIT CONDUCTOR	17	1			0
		MOHABBATPUR	New Feeder-2	MOHABBAT PUR	New Location	PCC POLES WITH RABBIT CONDUCTOR	12	1			0
		MUBARAKPUR	New Feeder-1	MUBARAKPUR	New Location	PCC POLES WITH RABBIT CONDUCTOR	15	1			0
		MUBARAKPUR	New Feeder-2	MUBARAKPUR	New Location	PCC POLES WITH RABBIT CONDUCTOR	18	1			0
20	Tahbarpur	SOFIPUR	New Feeder-1	SOFIPUR	New Location	PCC POLES WITH RABBIT CONDUCTOR	12	1			0
		ORA	New Feeder-1	ORA	New Location	PCC POLES WITH RABBIT CONDUCTOR	16	1			0
		MANJHARI	New Feeder-1	MANJHARI	New Location	PCC POLES WITH RABBIT CONDUCTOR	12	1			0
21	Tarwa	RASEPUR	New Feeder-1	RASEPUR	New Location	PCC POLES WITH RABBIT CONDUCTOR	13	1			0
		TARWA	New feeder-1	TARWA	New Location	PCC POLES WITH RABBIT CONDUCTOR	10.2	1			0

Details of New 11 KV or 22 KV Lines

State : UTTAR PRADESH
 District : Azamgarh

S.No.	Name of Block	Name of Emanating Substation	Name of feeder	Section of Feeder		Line Type	Length(k ms.)	Nos of Bay (If required)	Remarks	Line on ABC cable in Forest Area/Populated Area	Length of ABC cable (Kms.)
				From Location	To Location						
1	2	3	4	5	6	7	8	9	10	11	12
		MEHNAJPUR	New Feeder-1	MEHNAJPUR	New Location	PCC POLES WITH RABBIT CONDUCTOR	20	1			0
22	Thekma	BARDAH	New Feeder-1	BARDAH	New Location	PCC POLES WITH RABBIT CONDUCTOR	32	1			0
		THEKMA	New Feeder-1	THEKMA	New Location	PCC POLES WITH RABBIT CONDUCTOR	10.2	1			0
Total							993.57				0

Works Proposed Under Feeder Separation

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of Block	Name of Emitting SubStation	Name of Feeder	Restricted demand after FS	Feeder Metering
1	Ahiraula	AHIRAULA	Ahiraula	Nil	No
New 11 KV or 22 KV Line :-					
Line Type					
Length(Ckt. Kms.)		0	Railway/Highway Crossing etc		
Proposed Distribution Transformer :-					
Sl.No.	Distribution Transformer			Total No. of DT	
1	10 KVA(1 Ph)			0	
2	SDT-25 KVA			0	
3	SDT-50 KVA			0	
4	SDT-63 KVA			0	
5	SDT-100 KVA			0	
6	SDT-30 AMP			0	
7	10 KVA(3 Ph)			0	
8	16 KVA(3 Ph)			0	
9	25 KVA(3 Ph)			34	
10	40 KVA(3 Ph)			0	
11	63 KVA(3 Ph)			0	
12	100 KVA(3 Ph)			0	
Total				34	
2	Ahiraula	AHIRAULA	Atraulia	225	Yes
New 11 KV or 22 KV Line :-					
Line Type					
Length(Ckt. Kms.)		0	Railway/Highway Crossing etc		

Works Proposed Under Feeder Separation

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of Block	Name of Emitting SubStation	Name of Feeder	Restricted demand after FS	Feeder Metering
Proposed Distribution Transformer :-					
	Sl.No.	Distribution Transformer		Total No. of DT	
	1	10 KVA(1 Ph)		0	
	2	SDT-25 KVA		0	
	3	SDT-50 KVA		0	
	4	SDT-63 KVA		0	
	5	SDT-100 KVA		0	
	6	SDT-30 AMP		0	
	7	10 KVA(3 Ph)		0	
	8	16 KVA(3 Ph)		0	
	9	25 KVA(3 Ph)		19	
	10	40 KVA(3 Ph)		0	
	11	63 KVA(3 Ph)		0	
	12	100 KVA(3 Ph)		0	
	Total				19
3	Ahiraula	AHIRAULA	Kaptanganj	Nil	No
New 11 KV or 22 KV Line :-					
	Line Type				
	Length(Ckt. Kms.)	0	Railway/Highway Crossing etc		
Proposed Distribution Transformer :-					
	Sl.No.	Distribution Transformer		Total No. of DT	
	1	10 KVA(1 Ph)		0	
	2	SDT-25 KVA		0	

Works Proposed Under Feeder Separation

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of Block	Name of Emitting SubStation	Name of Feeder	Restricted demand after FS	Feeder Metering
	3	SDT-50 KVA			0
	4	SDT-63 KVA			0
	5	SDT-100 KVA			0
	6	SDT-30 AMP			0
	7	10 KVA(3 Ph)			0
	8	16 KVA(3 Ph)			0
	9	25 KVA(3 Ph)			13
	10	40 KVA(3 Ph)			0
	11	63 KVA(3 Ph)			0
	12	100 KVA(3 Ph)			0
	Total				13
4	Ahiraula	MDIYAPAR	Karsara	225	Yes
New 11 KV or 22 KV Line :-					
Line Type					
Length(Ckt. Kms.)					
		0	Railway/Highway Crossing etc		
Proposed Distribution Transformer :-					
	Sl.No.	Distribution Transformer		Total No. of DT	
	1	10 KVA(1 Ph)		0	
	2	SDT-25 KVA		0	
	3	SDT-50 KVA		0	
	4	SDT-63 KVA		0	
	5	SDT-100 KVA		0	
	6	SDT-30 AMP		0	

Works Proposed Under Feeder Separation

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of Block	Name of Emitting SubStation	Name of Feeder	Restricted demand after FS	Feeder Metering
	7	10 KVA(3 Ph)			0
	8	16 KVA(3 Ph)			0
	9	25 KVA(3 Ph)			12
	10	40 KVA(3 Ph)			0
	11	63 KVA(3 Ph)			0
	12	100 KVA(3 Ph)			0
	Total				12
5	Ahiraula	MDIYAPAR	Bhedaura	225	Yes
	New 11 KV or 22 KV Line :-				
	Line Type				
	Length(Ckt. Kms.)	0	Railway/Highway Crossing etc		
	Proposed Distribution Transformer :-				
	Sl.No.	Distribution Transformer		Total No. of DT	
	1	10 KVA(1 Ph)			0
	2	SDT-25 KVA			0
	3	SDT-50 KVA			0
	4	SDT-63 KVA			0
	5	SDT-100 KVA			0
	6	SDT-30 AMP			0
	7	10 KVA(3 Ph)			0
	8	16 KVA(3 Ph)			0
	9	25 KVA(3 Ph)			15
	10	40 KVA(3 Ph)			0

Works Proposed Under Feeder Separation

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of Block	Name of Emitting SubStation	Name of Feeder	Restricted demand after FS	Feeder Metering
	11	63 KVA(3 Ph)			0
	12	100 KVA(3 Ph)			0
	Total				15
6	Ahiraula	MDIYAPAR	Badhiya	Nil	No
	New 11 KV or 22 KV Line :-				
	Line Type				
	Length(Ckt. Kms.)	0	Railway/Highway Crossing etc		
	Proposed Distribution Transformer :-				
	Sl.No.	Distribution Transformer		Total No. of DT	
	1	10 KVA(1 Ph)		0	
	2	SDT-25 KVA		0	
	3	SDT-50 KVA		0	
	4	SDT-63 KVA		0	
	5	SDT-100 KVA		0	
	6	SDT-30 AMP		0	
	7	10 KVA(3 Ph)		0	
	8	16 KVA(3 Ph)		0	
	9	25 KVA(3 Ph)		11	
	10	40 KVA(3 Ph)		0	
	11	63 KVA(3 Ph)		0	
	12	100 KVA(3 Ph)		0	
	Total			11	
7	Ahiraula	MAHUL	Bazar Gosai	225	Yes

Works Proposed Under Feeder Separation

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of Block	Name of Emitting SubStation	Name of Feeder	Restricted demand after FS	Feeder Metering
	New 11 KV or 22 KV Line :-				
	Line Type				
	Length(Ckt. Kms.)	0	Railway/Highway Crossing etc		
	Proposed Distribution Transformer :-				
	Sl.No.	Distribution Transformer		Total No. of DT	
	1	10 KVA(1 Ph)		0	
	2	SDT-25 KVA		0	
	3	SDT-50 KVA		0	
	4	SDT-63 KVA		0	
	5	SDT-100 KVA		0	
	6	SDT-30 AMP		0	
	7	10 KVA(3 Ph)		0	
	8	16 KVA(3 Ph)		0	
	9	25 KVA(3 Ph)		10	
	10	40 KVA(3 Ph)		0	
	11	63 KVA(3 Ph)		0	
	12	100 KVA(3 Ph)		0	
	Total			10	
8	Atraulia	ATRAULIA	ATRAULIA	225	Yes
	New 11 KV or 22 KV Line :-				
	Line Type				
	Length(Ckt. Kms.)	0	Railway/Highway Crossing etc		
	Proposed Distribution Transformer :-				

Works Proposed Under Feeder Separation

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of Block	Name of Emitting SubStation	Name of Feeder	Restricted demand after FS	Feeder Metering
	Sl.No.	Distribution Transformer		Total No. of DT	
	1	10 KVA(1 Ph)		0	
	2	SDT-25 KVA		0	
	3	SDT-50 KVA		0	
	4	SDT-63 KVA		0	
	5	SDT-100 KVA		0	
	6	SDT-30 AMP		0	
	7	10 KVA(3 Ph)		0	
	8	16 KVA(3 Ph)		0	
	9	25 KVA(3 Ph)		17	
	10	40 KVA(3 Ph)		0	
	11	63 KVA(3 Ph)		0	
	12	100 KVA(3 Ph)		0	
	Total			17	
9	Atraulia	ATRAULIA	WEST	Nil	No
	New 11 KV or 22 KV Line :-				
	Line Type				
	Length(Ckt. Kms.)	0	Railway/Highway Crossing etc		
	Proposed Distribution Transformer :-				
	Sl.No.	Distribution Transformer		Total No. of DT	
	1	10 KVA(1 Ph)		0	
	2	SDT-25 KVA		0	
	3	SDT-50 KVA		0	

Works Proposed Under Feeder Separation

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of Block	Name of Emitting SubStation	Name of Feeder	Restricted demand after FS	Feeder Metering
	4	SDT-63 KVA			0
	5	SDT-100 KVA			0
	6	SDT-30 AMP			0
	7	10 KVA(3 Ph)			0
	8	16 KVA(3 Ph)			0
	9	25 KVA(3 Ph)			20
	10	40 KVA(3 Ph)			0
	11	63 KVA(3 Ph)			0
	12	100 KVA(3 Ph)			0
	Total				20
10	Atraulia	ATRAULIA	EAST	Nil	No
	New 11 KV or 22 KV Line :-				
	Line Type				
	Length(Ckt. Kms.)	0	Railway/Highway Crossing etc		
	Proposed Distribution Transformer :-				
	Sl.No.	Distribution Transformer		Total No. of DT	
	1	10 KVA(1 Ph)		0	
	2	SDT-25 KVA		0	
	3	SDT-50 KVA		0	
	4	SDT-63 KVA		0	
	5	SDT-100 KVA		0	
	6	SDT-30 AMP		0	
	7	10 KVA(3 Ph)		0	

Works Proposed Under Feeder Separation

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of Block	Name of Emitting SubStation	Name of Feeder	Restricted demand after FS	Feeder Metering
	8	16 KVA(3 Ph)			0
	9	25 KVA(3 Ph)			20
	10	40 KVA(3 Ph)			0
	11	63 KVA(3 Ph)			0
	12	100 KVA(3 Ph)			0
	Total				20
11	Atraulia	ATRAULIA	NORTH	Nil	No
New 11 KV or 22 KV Line :-					
Line Type					
Length(Ckt. Kms.)					
		0	Railway/Highway Crossing etc		
Proposed Distribution Transformer :-					
	Sl.No.	Distribution Transformer		Total No. of DT	
	1	10 KVA(1 Ph)		0	
	2	SDT-25 KVA		0	
	3	SDT-50 KVA		0	
	4	SDT-63 KVA		0	
	5	SDT-100 KVA		0	
	6	SDT-30 AMP		0	
	7	10 KVA(3 Ph)		0	
	8	16 KVA(3 Ph)		0	
	9	25 KVA(3 Ph)		12	
	10	40 KVA(3 Ph)		0	
	11	63 KVA(3 Ph)		0	

Works Proposed Under Feeder Separation

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of Block	Name of Emitting SubStation	Name of Feeder	Restricted demand after FS	Feeder Metering
	12	100 KVA(3 Ph)			0
	Total				12
12	Atraulia	ATRAULIA	West 2	Nil	No
	New 11 KV or 22 KV Line :-				
	Line Type				
	Length(Ckt. Kms.)	0	Railway/Highway Crossing etc		
	Proposed Distribution Transformer :-				
	Sl.No.	Distribution Transformer		Total No. of DT	
	1	10 KVA(1 Ph)		0	
	2	SDT-25 KVA		0	
	3	SDT-50 KVA		0	
	4	SDT-63 KVA		0	
	5	SDT-100 KVA		0	
	6	SDT-30 AMP		0	
	7	10 KVA(3 Ph)		0	
	8	16 KVA(3 Ph)		0	
	9	25 KVA(3 Ph)		22	
	10	40 KVA(3 Ph)		0	
	11	63 KVA(3 Ph)		0	
	12	100 KVA(3 Ph)		0	
	Total				22
13	Azmatgarh	MALTADI	Basgaon	Nil	No
	New 11 KV or 22 KV Line :-				

Works Proposed Under Feeder Separation

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of Block	Name of Emitting SubStation	Name of Feeder	Restricted demand after FS	Feeder Metering
	Line Type				
	Length(Ckt. Kms.)	0	Railway/Highway Crossing etc		
Proposed Distribution Transformer :-					
	Sl.No.	Distribution Transformer		Total No. of DT	
	1	10 KVA(1 Ph)		0	
	2	SDT-25 KVA		0	
	3	SDT-50 KVA		0	
	4	SDT-63 KVA		0	
	5	SDT-100 KVA		0	
	6	SDT-30 AMP		0	
	7	10 KVA(3 Ph)		0	
	8	16 KVA(3 Ph)		0	
	9	25 KVA(3 Ph)		29	
	10	40 KVA(3 Ph)		0	
	11	63 KVA(3 Ph)		0	
	12	100 KVA(3 Ph)		0	
	Total			29	
14	Azmatgarh	MALTADI	North	225	Yes
New 11 KV or 22 KV Line :-					
	Line Type				
	Length(Ckt. Kms.)	0	Railway/Highway Crossing etc		
Proposed Distribution Transformer :-					
	Sl.No.	Distribution Transformer		Total No. of DT	

Works Proposed Under Feeder Separation

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of Block	Name of Emitting SubStation	Name of Feeder	Restricted demand after FS	Feeder Metering
	1	10 KVA(1 Ph)			0
	2	SDT-25 KVA			0
	3	SDT-50 KVA			0
	4	SDT-63 KVA			0
	5	SDT-100 KVA			0
	6	SDT-30 AMP			0
	7	10 KVA(3 Ph)			0
	8	16 KVA(3 Ph)			0
	9	25 KVA(3 Ph)			11
	10	40 KVA(3 Ph)			0
	11	63 KVA(3 Ph)			0
	12	100 KVA(3 Ph)			0
	Total				11
15	Azmatgarh	MALTADI	West	Nil	No
	New 11 KV or 22 KV Line :-				
	Line Type				
	Length(Ckt. Kms.)	0	Railway/Highway Crossing etc		
	Proposed Distribution Transformer :-				
	Sl.No.	Distribution Transformer		Total No. of DT	
	1	10 KVA(1 Ph)		0	
	2	SDT-25 KVA		0	
	3	SDT-50 KVA		0	
	4	SDT-63 KVA		0	

Works Proposed Under Feeder Separation

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of Block	Name of Eminating SubStation	Name of Feeder	Restricted demand after FS	Feeder Metering
	5	SDT-100 KVA			0
	6	SDT-30 AMP			0
	7	10 KVA(3 Ph)			0
	8	16 KVA(3 Ph)			0
	9	25 KVA(3 Ph)			13
	10	40 KVA(3 Ph)			0
	11	63 KVA(3 Ph)			0
	12	100 KVA(3 Ph)			0
	Total				13
16	Azmatgarh	LATGHAT	Kaithauli	225	Yes
	New 11 KV or 22 KV Line :-				
	Line Type				
	Length(Ckt. Kms.)	0	Railway/Highway Crossing etc		
	Proposed Distribution Transformer :-				
	Sl.No.	Distribution Transformer		Total No. of DT	
	1	10 KVA(1 Ph)		0	
	2	SDT-25 KVA		0	
	3	SDT-50 KVA		0	
	4	SDT-63 KVA		0	
	5	SDT-100 KVA		0	
	6	SDT-30 AMP		0	
	7	10 KVA(3 Ph)		0	
	8	16 KVA(3 Ph)		0	

Works Proposed Under Feeder Separation

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of Block	Name of Emitting SubStation	Name of Feeder	Restricted demand after FS	Feeder Metering
	9	25 KVA(3 Ph)			14
	10	40 KVA(3 Ph)			0
	11	63 KVA(3 Ph)			0
	12	100 KVA(3 Ph)			0
	Total				14
17	Azmatgarh	LATGHAT	Mahula	Nil	No
New 11 KV or 22 KV Line :-					
Line Type					
Length(Ckt. Kms.)					
		0	Railway/Highway Crossing etc		
Proposed Distribution Transformer :-					
Sl.No.	Distribution Transformer			Total No. of DT	
1	10 KVA(1 Ph)			0	
2	SDT-25 KVA			0	
3	SDT-50 KVA			0	
4	SDT-63 KVA			0	
5	SDT-100 KVA			0	
6	SDT-30 AMP			0	
7	10 KVA(3 Ph)			0	
8	16 KVA(3 Ph)			0	
9	25 KVA(3 Ph)			16	
10	40 KVA(3 Ph)			0	
11	63 KVA(3 Ph)			0	
12	100 KVA(3 Ph)			0	

Works Proposed Under Feeder Separation

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of Block	Name of Emitting SubStation	Name of Feeder	Restricted demand after FS	Feeder Metering
Total					16
18	Azmatgarh	LATGHAT	Bardeeha	225	Yes
New 11 KV or 22 KV Line :-					
Line Type					
Length(Ckt. Kms.)		0	Railway/Highway Crossing etc		
Proposed Distribution Transformer :-					
Sl.No.	Distribution Transformer			Total No. of DT	
1	10 KVA(1 Ph)			0	
2	SDT-25 KVA			0	
3	SDT-50 KVA			0	
4	SDT-63 KVA			0	
5	SDT-100 KVA			0	
6	SDT-30 AMP			0	
7	10 KVA(3 Ph)			0	
8	16 KVA(3 Ph)			0	
9	25 KVA(3 Ph)			17	
10	40 KVA(3 Ph)			0	
11	63 KVA(3 Ph)			0	
12	100 KVA(3 Ph)			0	
Total					17
19	Azmatgarh	JIIYANPUR	North	Nil	Yes
New 11 KV or 22 KV Line :-					
Line Type					

Works Proposed Under Feeder Separation

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of Block	Name of Emitting SubStation	Name of Feeder	Restricted demand after FS	Feeder Metering
	Length(Ckt. Kms.)	0	Railway/Highway Crossing etc		
Proposed Distribution Transformer :-					
	Sl.No.	Distribution Transformer			Total No. of DT
	1	10 KVA(1 Ph)			0
	2	SDT-25 KVA			0
	3	SDT-50 KVA			0
	4	SDT-63 KVA			0
	5	SDT-100 KVA			0
	6	SDT-30 AMP			0
	7	10 KVA(3 Ph)			0
	8	16 KVA(3 Ph)			0
	9	25 KVA(3 Ph)			17
	10	40 KVA(3 Ph)			0
	11	63 KVA(3 Ph)			0
	12	100 KVA(3 Ph)			0
		Total			17
20	Azmatgarh	JIYANPUR	East	225	Yes
New 11 KV or 22 KV Line :-					
	Line Type				
	Length(Ckt. Kms.)	0	Railway/Highway Crossing etc		
Proposed Distribution Transformer :-					
	Sl.No.	Distribution Transformer			Total No. of DT
	1	10 KVA(1 Ph)			0

Works Proposed Under Feeder Separation

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of Block	Name of Emitting SubStation	Name of Feeder	Restricted demand after FS	Feeder Metering
	2	SDT-25 KVA			0
	3	SDT-50 KVA			0
	4	SDT-63 KVA			0
	5	SDT-100 KVA			0
	6	SDT-30 AMP			0
	7	10 KVA(3 Ph)			0
	8	16 KVA(3 Ph)			0
	9	25 KVA(3 Ph)			18
	10	40 KVA(3 Ph)			0
	11	63 KVA(3 Ph)			0
	12	100 KVA(3 Ph)			0
	Total				18
21	Azmatgarh	JIYANPUR	West	225	Yes
	New 11 KV or 22 KV Line :-				
	Line Type				
	Length(Ckt. Kms.)	0	Railway/Highway Crossing etc		
	Proposed Distribution Transformer :-				
	Sl.No.	Distribution Transformer		Total No. of DT	
	1	10 KVA(1 Ph)		0	
	2	SDT-25 KVA		0	
	3	SDT-50 KVA		0	
	4	SDT-63 KVA		0	
	5	SDT-100 KVA		0	

Works Proposed Under Feeder Separation

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of Block	Name of Emitting SubStation	Name of Feeder	Restricted demand after FS	Feeder Metering
	6	SDT-30 AMP			0
	7	10 KVA(3 Ph)			0
	8	16 KVA(3 Ph)			0
	9	25 KVA(3 Ph)			15
	10	40 KVA(3 Ph)			0
	11	63 KVA(3 Ph)			0
	12	100 KVA(3 Ph)			0
	Total				15
22	Azmatgarh	AMUWARI NARAINPUR	East	Nil	No
	New 11 KV or 22 KV Line :-				
	Line Type				
	Length(Ckt. Kms.)	0	Railway/Highway Crossing etc		
	Proposed Distribution Transformer :-				
	Sl.No.	Distribution Transformer		Total No. of DT	
	1	10 KVA(1 Ph)		0	
	2	SDT-25 KVA		0	
	3	SDT-50 KVA		0	
	4	SDT-63 KVA		0	
	5	SDT-100 KVA		0	
	6	SDT-30 AMP		0	
	7	10 KVA(3 Ph)		0	
	8	16 KVA(3 Ph)		0	
	9	25 KVA(3 Ph)		27	

Works Proposed Under Feeder Separation

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of Block	Name of Emitting SubStation	Name of Feeder	Restricted demand after FS	Feeder Metering
	10	40 KVA(3 Ph)			0
	11	63 KVA(3 Ph)			0
	12	100 KVA(3 Ph)			0
	Total				27
23	Azmatgarh	AMUWARI NARAINPUR	West	225	Yes
New 11 KV or 22 KV Line :-					
Line Type					
Length(Ckt. Kms.)					
		0	Railway/Highway Crossing etc		
Proposed Distribution Transformer :-					
Sl.No.	Distribution Transformer			Total No. of DT	
1	10 KVA(1 Ph)			0	
2	SDT-25 KVA			0	
3	SDT-50 KVA			0	
4	SDT-63 KVA			0	
5	SDT-100 KVA			0	
6	SDT-30 AMP			0	
7	10 KVA(3 Ph)			0	
8	16 KVA(3 Ph)			0	
9	25 KVA(3 Ph)			11	
10	40 KVA(3 Ph)			0	
11	63 KVA(3 Ph)			0	
12	100 KVA(3 Ph)			0	
	Total				11

Works Proposed Under Feeder Separation

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of Block	Name of Emitting SubStation	Name of Feeder	Restricted demand after FS	Feeder Metering
24	Azmatgarh	AMUWARI NARAINPUR	Bhuana	225	Yes
New 11 KV or 22 KV Line :-					
Line Type					
Length(Ckt. Kms.)		0	Railway/Highway Crossing etc		
Proposed Distribution Transformer :-					
Sl.No.	Distribution Transformer			Total No. of DT	
1	10 KVA(1 Ph)			0	
2	SDT-25 KVA			0	
3	SDT-50 KVA			0	
4	SDT-63 KVA			0	
5	SDT-100 KVA			0	
6	SDT-30 AMP			0	
7	10 KVA(3 Ph)			0	
8	16 KVA(3 Ph)			0	
9	25 KVA(3 Ph)			15	
10	40 KVA(3 Ph)			0	
11	63 KVA(3 Ph)			0	
12	100 KVA(3 Ph)			0	
Total				15	
25	Bilariyaganj	BILARIYAGANJ	North	225	Yes
New 11 KV or 22 KV Line :-					
Line Type					
Length(Ckt. Kms.)		0	Railway/Highway Crossing etc		

Works Proposed Under Feeder Separation

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of Block	Name of Emitting SubStation	Name of Feeder	Restricted demand after FS	Feeder Metering
Proposed Distribution Transformer :-					
	Sl.No.	Distribution Transformer		Total No. of DT	
	1	10 KVA(1 Ph)		0	
	2	SDT-25 KVA		0	
	3	SDT-50 KVA		0	
	4	SDT-63 KVA		0	
	5	SDT-100 KVA		0	
	6	SDT-30 AMP		0	
	7	10 KVA(3 Ph)		0	
	8	16 KVA(3 Ph)		0	
	9	25 KVA(3 Ph)		26	
	10	40 KVA(3 Ph)		0	
	11	63 KVA(3 Ph)		0	
	12	100 KVA(3 Ph)		0	
	Total			26	
26	Bilariyaganj	BILARIYAGANJ	East	Nil	No
New 11 KV or 22 KV Line :-					
Line Type					
Length(Ckt. Kms.)		0	Railway/Highway Crossing etc		
Proposed Distribution Transformer :-					
	Sl.No.	Distribution Transformer		Total No. of DT	
	1	10 KVA(1 Ph)		0	
	2	SDT-25 KVA		0	

Works Proposed Under Feeder Separation

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of Block	Name of Emitting SubStation	Name of Feeder	Restricted demand after FS	Feeder Metering
	3	SDT-50 KVA			0
	4	SDT-63 KVA			0
	5	SDT-100 KVA			0
	6	SDT-30 AMP			0
	7	10 KVA(3 Ph)			0
	8	16 KVA(3 Ph)			0
	9	25 KVA(3 Ph)			23
	10	40 KVA(3 Ph)			0
	11	63 KVA(3 Ph)			0
	12	100 KVA(3 Ph)			0
	Total				23
27	Bilariyaganj	BILARIYAGANJ	West	225	Yes
	New 11 KV or 22 KV Line :-				
	Line Type				
	Length(Ckt. Kms.)	0	Railway/Highway Crossing etc		
	Proposed Distribution Transformer :-				
	Sl.No.	Distribution Transformer		Total No. of DT	
	1	10 KVA(1 Ph)		0	
	2	SDT-25 KVA		0	
	3	SDT-50 KVA		0	
	4	SDT-63 KVA		0	
	5	SDT-100 KVA		0	
	6	SDT-30 AMP		0	

Works Proposed Under Feeder Separation

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of Block	Name of Emitting SubStation	Name of Feeder	Restricted demand after FS	Feeder Metering
	7	10 KVA(3 Ph)			0
	8	16 KVA(3 Ph)			0
	9	25 KVA(3 Ph)			27
	10	40 KVA(3 Ph)			0
	11	63 KVA(3 Ph)			0
	12	100 KVA(3 Ph)			0
	Total				27
28	Bilariyaganj	PATWADH KAUTAK	EAST	Nil	No
	New 11 KV or 22 KV Line :-				
	Line Type				
	Length(Ckt. Kms.)	0	Railway/Highway Crossing etc		
	Proposed Distribution Transformer :-				
	Sl.No.	Distribution Transformer			Total No. of DT
	1	10 KVA(1 Ph)			0
	2	SDT-25 KVA			0
	3	SDT-50 KVA			0
	4	SDT-63 KVA			0
	5	SDT-100 KVA			0
	6	SDT-30 AMP			0
	7	10 KVA(3 Ph)			0
	8	16 KVA(3 Ph)			0
	9	25 KVA(3 Ph)			15
	10	40 KVA(3 Ph)			0

Works Proposed Under Feeder Separation

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of Block	Name of Emitting SubStation	Name of Feeder	Restricted demand after FS	Feeder Metering
	11	63 KVA(3 Ph)			0
	12	100 KVA(3 Ph)			0
	Total				15
29	Bilariyaganj	PATWADH KAUTAK	West	Nil	No
	New 11 KV or 22 KV Line :-				
	Line Type				
	Length(Ckt. Kms.)	0	Railway/Highway Crossing etc		
	Proposed Distribution Transformer :-				
	Sl.No.	Distribution Transformer		Total No. of DT	
	1	10 KVA(1 Ph)		0	
	2	SDT-25 KVA		0	
	3	SDT-50 KVA		0	
	4	SDT-63 KVA		0	
	5	SDT-100 KVA		0	
	6	SDT-30 AMP		0	
	7	10 KVA(3 Ph)		0	
	8	16 KVA(3 Ph)		0	
	9	25 KVA(3 Ph)		22	
	10	40 KVA(3 Ph)		0	
	11	63 KVA(3 Ph)		0	
	12	100 KVA(3 Ph)		0	
	Total			22	
30	Bilariyaganj	PATWADH KAUTAK	South	225	Yes

Works Proposed Under Feeder Separation

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of Block	Name of Emitting SubStation	Name of Feeder	Restricted demand after FS	Feeder Metering
	New 11 KV or 22 KV Line :-				
	Line Type				
	Length(Ckt. Kms.)		0	Railway/Highway Crossing etc	
	Proposed Distribution Transformer :-				
	Sl.No.	Distribution Transformer		Total No. of DT	
	1	10 KVA(1 Ph)		0	
	2	SDT-25 KVA		0	
	3	SDT-50 KVA		0	
	4	SDT-63 KVA		0	
	5	SDT-100 KVA		0	
	6	SDT-30 AMP		0	
	7	10 KVA(3 Ph)		0	
	8	16 KVA(3 Ph)		0	
	9	25 KVA(3 Ph)		14	
	10	40 KVA(3 Ph)		0	
	11	63 KVA(3 Ph)		0	
	12	100 KVA(3 Ph)		0	
	Total			14	
31	Haraiya	RAUNAPUR	West	225	Yes
	New 11 KV or 22 KV Line :-				
	Line Type				
	Length(Ckt. Kms.)		0	Railway/Highway Crossing etc	
	Proposed Distribution Transformer :-				

Works Proposed Under Feeder Separation

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of Block	Name of Emitting SubStation	Name of Feeder	Restricted demand after FS	Feeder Metering
	Sl.No.	Distribution Transformer		Total No. of DT	
	1	10 KVA(1 Ph)		0	
	2	SDT-25 KVA		0	
	3	SDT-50 KVA		0	
	4	SDT-63 KVA		0	
	5	SDT-100 KVA		0	
	6	SDT-30 AMP		0	
	7	10 KVA(3 Ph)		0	
	8	16 KVA(3 Ph)		0	
	9	25 KVA(3 Ph)		17	
	10	40 KVA(3 Ph)		0	
	11	63 KVA(3 Ph)		0	
	12	100 KVA(3 Ph)		0	
	Total			17	
32	Haraiya	RAUNAPUR	East	Nil	No
	New 11 KV or 22 KV Line :-				
	Line Type				
	Length(Ckt. Kms.)	0	Railway/Highway Crossing etc		
	Proposed Distribution Transformer :-				
	Sl.No.	Distribution Transformer		Total No. of DT	
	1	10 KVA(1 Ph)		0	
	2	SDT-25 KVA		0	
	3	SDT-50 KVA		0	

Works Proposed Under Feeder Separation

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of Block	Name of Emitting SubStation	Name of Feeder	Restricted demand after FS	Feeder Metering
	4	SDT-63 KVA			0
	5	SDT-100 KVA			0
	6	SDT-30 AMP			0
	7	10 KVA(3 Ph)			0
	8	16 KVA(3 Ph)			0
	9	25 KVA(3 Ph)			19
	10	40 KVA(3 Ph)			0
	11	63 KVA(3 Ph)			0
	12	100 KVA(3 Ph)			0
	Total				19
33	Haraiya	RAUNAPUR	South	Nil	No
	New 11 KV or 22 KV Line :-				
	Line Type				
	Length(Ckt. Kms.)	0	Railway/Highway Crossing etc		
	Proposed Distribution Transformer :-				
	Sl.No.	Distribution Transformer		Total No. of DT	
	1	10 KVA(1 Ph)		0	
	2	SDT-25 KVA		0	
	3	SDT-50 KVA		0	
	4	SDT-63 KVA		0	
	5	SDT-100 KVA		0	
	6	SDT-30 AMP		0	
	7	10 KVA(3 Ph)		0	

Works Proposed Under Feeder Separation

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of Block	Name of Emitting SubStation	Name of Feeder	Restricted demand after FS	Feeder Metering
	8	16 KVA(3 Ph)			0
	9	25 KVA(3 Ph)			26
	10	40 KVA(3 Ph)			0
	11	63 KVA(3 Ph)			0
	12	100 KVA(3 Ph)			0
	Total				26
34	Haraiya	MAU KUTUBPUR	North	Nil	No
New 11 KV or 22 KV Line :-					
Line Type					
Length(Ckt. Kms.)					
		0	Railway/Highway Crossing etc		
Proposed Distribution Transformer :-					
	Sl.No.	Distribution Transformer		Total No. of DT	
	1	10 KVA(1 Ph)		0	
	2	SDT-25 KVA		0	
	3	SDT-50 KVA		0	
	4	SDT-63 KVA		0	
	5	SDT-100 KVA		0	
	6	SDT-30 AMP		0	
	7	10 KVA(3 Ph)		0	
	8	16 KVA(3 Ph)		0	
	9	25 KVA(3 Ph)		14	
	10	40 KVA(3 Ph)		0	
	11	63 KVA(3 Ph)		0	

Works Proposed Under Feeder Separation

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of Block	Name of Emitting SubStation	Name of Feeder	Restricted demand after FS	Feeder Metering
	12	100 KVA(3 Ph)			0
	Total				14
35	Haraiya	MAU KUTUBPUR	West	225	Yes
	New 11 KV or 22 KV Line :-				
	Line Type				
	Length(Ckt. Kms.)	0	Railway/Highway Crossing etc		
	Proposed Distribution Transformer :-				
	Sl.No.	Distribution Transformer		Total No. of DT	
	1	10 KVA(1 Ph)		0	
	2	SDT-25 KVA		0	
	3	SDT-50 KVA		0	
	4	SDT-63 KVA		0	
	5	SDT-100 KVA		0	
	6	SDT-30 AMP		0	
	7	10 KVA(3 Ph)		0	
	8	16 KVA(3 Ph)		0	
	9	25 KVA(3 Ph)		5	
	10	40 KVA(3 Ph)		0	
	11	63 KVA(3 Ph)		0	
	12	100 KVA(3 Ph)		0	
	Total				5
36	Haraiya	MAU KUTUBPUR	Bazar Gosai	Nil	No
	New 11 KV or 22 KV Line :-				

Works Proposed Under Feeder Separation

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of Block	Name of Emitting SubStation	Name of Feeder	Restricted demand after FS	Feeder Metering
	Line Type				
	Length(Ckt. Kms.)	0	Railway/Highway Crossing etc		
Proposed Distribution Transformer :-					
	Sl.No.	Distribution Transformer		Total No. of DT	
	1	10 KVA(1 Ph)		0	
	2	SDT-25 KVA		0	
	3	SDT-50 KVA		0	
	4	SDT-63 KVA		0	
	5	SDT-100 KVA		0	
	6	SDT-30 AMP		0	
	7	10 KVA(3 Ph)		0	
	8	16 KVA(3 Ph)		0	
	9	25 KVA(3 Ph)		24	
	10	40 KVA(3 Ph)		0	
	11	63 KVA(3 Ph)		0	
	12	100 KVA(3 Ph)		0	
	Total			24	
37	Jahanaganj	CHANDESHWAR	Nibi	225	Yes
New 11 KV or 22 KV Line :-					
	Line Type				
	Length(Ckt. Kms.)	0	Railway/Highway Crossing etc		
Proposed Distribution Transformer :-					
	Sl.No.	Distribution Transformer		Total No. of DT	

Works Proposed Under Feeder Separation

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of Block	Name of Emitting SubStation	Name of Feeder	Restricted demand after FS	Feeder Metering
	1	10 KVA(1 Ph)			0
	2	SDT-25 KVA			0
	3	SDT-50 KVA			0
	4	SDT-63 KVA			0
	5	SDT-100 KVA			0
	6	SDT-30 AMP			0
	7	10 KVA(3 Ph)			0
	8	16 KVA(3 Ph)			0
	9	25 KVA(3 Ph)			26
	10	40 KVA(3 Ph)			0
	11	63 KVA(3 Ph)			0
	12	100 KVA(3 Ph)			0
	Total				26
38	Jahanaganj	CHANDESHWAR	Sameda	Nil	No
	New 11 KV or 22 KV Line :-				
	Line Type				
	Length(Ckt. Kms.)	0	Railway/Highway Crossing etc		
	Proposed Distribution Transformer :-				
	Sl.No.	Distribution Transformer		Total No. of DT	
	1	10 KVA(1 Ph)		0	
	2	SDT-25 KVA		0	
	3	SDT-50 KVA		0	
	4	SDT-63 KVA		0	

Works Proposed Under Feeder Separation

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of Block	Name of Eminating SubStation	Name of Feeder	Restricted demand after FS	Feeder Metering
	5	SDT-100 KVA			0
	6	SDT-30 AMP			0
	7	10 KVA(3 Ph)			0
	8	16 KVA(3 Ph)			0
	9	25 KVA(3 Ph)			5
	10	40 KVA(3 Ph)			0
	11	63 KVA(3 Ph)			0
	12	100 KVA(3 Ph)			0
	Total				5
39	Jahanaganj	CHANDESHWAR	Karanpur	225	Yes
	New 11 KV or 22 KV Line :-				
	Line Type				
	Length(Ckt. Kms.)	0	Railway/Highway Crossing etc		
	Proposed Distribution Transformer :-				
	Sl.No.	Distribution Transformer		Total No. of DT	
	1	10 KVA(1 Ph)		0	
	2	SDT-25 KVA		0	
	3	SDT-50 KVA		0	
	4	SDT-63 KVA		0	
	5	SDT-100 KVA		0	
	6	SDT-30 AMP		0	
	7	10 KVA(3 Ph)		0	
	8	16 KVA(3 Ph)		0	

Works Proposed Under Feeder Separation

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of Block	Name of Emitting SubStation	Name of Feeder	Restricted demand after FS	Feeder Metering
	9	25 KVA(3 Ph)			20
	10	40 KVA(3 Ph)			0
	11	63 KVA(3 Ph)			0
	12	100 KVA(3 Ph)			0
	Total				20
40	Jahanaganj	JAHANGANJ	Jahanaganj	225	Yes
	New 11 KV or 22 KV Line :-				
	Line Type				
	Length(Ckt. Kms.)	0	Railway/Highway Crossing etc		
	Proposed Distribution Transformer :-				
	Sl.No.	Distribution Transformer		Total No. of DT	
	1	10 KVA(1 Ph)		0	
	2	SDT-25 KVA		0	
	3	SDT-50 KVA		0	
	4	SDT-63 KVA		0	
	5	SDT-100 KVA		0	
	6	SDT-30 AMP		0	
	7	10 KVA(3 Ph)		0	
	8	16 KVA(3 Ph)		0	
	9	25 KVA(3 Ph)		15	
	10	40 KVA(3 Ph)		0	
	11	63 KVA(3 Ph)		0	
	12	100 KVA(3 Ph)		0	

Works Proposed Under Feeder Separation

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of Block	Name of Emitting SubStation	Name of Feeder	Restricted demand after FS	Feeder Metering	
Total					15	
41	Jahanaganj	JAHANGANJ	Parasi	Nil	No	
	New 11 KV or 22 KV Line :-					
	Line Type					
	Length(Ckt. Kms.)		0	Railway/Highway Crossing etc		
	Proposed Distribution Transformer :-					
	Sl.No.	Distribution Transformer			Total No. of DT	
	1	10 KVA(1 Ph)			0	
	2	SDT-25 KVA			0	
	3	SDT-50 KVA			0	
	4	SDT-63 KVA			0	
	5	SDT-100 KVA			0	
	6	SDT-30 AMP			0	
	7	10 KVA(3 Ph)			0	
	8	16 KVA(3 Ph)			0	
	9	25 KVA(3 Ph)			22	
10	40 KVA(3 Ph)			0		
11	63 KVA(3 Ph)			0		
12	100 KVA(3 Ph)			0		
Total					22	
42	Jahanaganj	JAHANGANJ	Godhawra	Nil	No	
	New 11 KV or 22 KV Line :-					
	Line Type					

Works Proposed Under Feeder Separation

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of Block	Name of Emitting SubStation	Name of Feeder	Restricted demand after FS	Feeder Metering
	Length(Ckt. Kms.)	0	Railway/Highway Crossing etc		
Proposed Distribution Transformer :-					
	Sl.No.	Distribution Transformer			Total No. of DT
	1	10 KVA(1 Ph)			0
	2	SDT-25 KVA			0
	3	SDT-50 KVA			0
	4	SDT-63 KVA			0
	5	SDT-100 KVA			0
	6	SDT-30 AMP			0
	7	10 KVA(3 Ph)			0
	8	16 KVA(3 Ph)			0
	9	25 KVA(3 Ph)			20
	10	40 KVA(3 Ph)			0
	11	63 KVA(3 Ph)			0
	12	100 KVA(3 Ph)			0
	Total				20
43	Jahanaganj	JAHANGANJ	Sumbhi	225	Yes
New 11 KV or 22 KV Line :-					
	Line Type				
	Length(Ckt. Kms.)	0	Railway/Highway Crossing etc		
Proposed Distribution Transformer :-					
	Sl.No.	Distribution Transformer			Total No. of DT
	1	10 KVA(1 Ph)			0

Works Proposed Under Feeder Separation

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of Block	Name of Emitting SubStation	Name of Feeder	Restricted demand after FS	Feeder Metering
	2	SDT-25 KVA			0
	3	SDT-50 KVA			0
	4	SDT-63 KVA			0
	5	SDT-100 KVA			0
	6	SDT-30 AMP			0
	7	10 KVA(3 Ph)			0
	8	16 KVA(3 Ph)			0
	9	25 KVA(3 Ph)			17
	10	40 KVA(3 Ph)			0
	11	63 KVA(3 Ph)			0
	12	100 KVA(3 Ph)			0
	Total				17
44	Jahanaganj	KANILA	Barora	225	Yes
	New 11 KV or 22 KV Line :-				
	Line Type				
	Length(Ckt. Kms.)	0	Railway/Highway Crossing etc		
	Proposed Distribution Transformer :-				
	Sl.No.	Distribution Transformer		Total No. of DT	
	1	10 KVA(1 Ph)		0	
	2	SDT-25 KVA		0	
	3	SDT-50 KVA		0	
	4	SDT-63 KVA		0	
	5	SDT-100 KVA		0	

Works Proposed Under Feeder Separation

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of Block	Name of Emitting SubStation	Name of Feeder	Restricted demand after FS	Feeder Metering
	6	SDT-30 AMP			0
	7	10 KVA(3 Ph)			0
	8	16 KVA(3 Ph)			0
	9	25 KVA(3 Ph)			19
	10	40 KVA(3 Ph)			0
	11	63 KVA(3 Ph)			0
	12	100 KVA(3 Ph)			0
	Total				19
45	Jahanaganj	KANILA	Jigarsandi	Nil	No
	New 11 KV or 22 KV Line :-				
	Line Type				
	Length(Ckt. Kms.)	0	Railway/Highway Crossing etc		
	Proposed Distribution Transformer :-				
	Sl.No.	Distribution Transformer		Total No. of DT	
	1	10 KVA(1 Ph)		0	
	2	SDT-25 KVA		0	
	3	SDT-50 KVA		0	
	4	SDT-63 KVA		0	
	5	SDT-100 KVA		0	
	6	SDT-30 AMP		0	
	7	10 KVA(3 Ph)		0	
	8	16 KVA(3 Ph)		0	
	9	25 KVA(3 Ph)		18	

Works Proposed Under Feeder Separation

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of Block	Name of Emitting SubStation	Name of Feeder	Restricted demand after FS	Feeder Metering
	10	40 KVA(3 Ph)			0
	11	63 KVA(3 Ph)			0
	12	100 KVA(3 Ph)			0
	Total				18
46	Jahanaganj	SHERPUR	Sherpur Kuti	225	Yes
New 11 KV or 22 KV Line :-					
Line Type					
Length(Ckt. Kms.)					
		0	Railway/Highway Crossing etc		
Proposed Distribution Transformer :-					
Sl.No.	Distribution Transformer			Total No. of DT	
1	10 KVA(1 Ph)			0	
2	SDT-25 KVA			0	
3	SDT-50 KVA			0	
4	SDT-63 KVA			0	
5	SDT-100 KVA			0	
6	SDT-30 AMP			0	
7	10 KVA(3 Ph)			0	
8	16 KVA(3 Ph)			0	
9	25 KVA(3 Ph)			8	
10	40 KVA(3 Ph)			0	
11	63 KVA(3 Ph)			0	
12	100 KVA(3 Ph)			0	
	Total				8

Works Proposed Under Feeder Separation

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of Block	Name of Emitting SubStation	Name of Feeder	Restricted demand after FS	Feeder Metering
47	Jahanaganj	SHERPUR	Parsaha	Nil	No
New 11 KV or 22 KV Line :-					
Line Type					
Length(Ckt. Kms.)		0	Railway/Highway Crossing etc		
Proposed Distribution Transformer :-					
Sl.No.	Distribution Transformer			Total No. of DT	
1	10 KVA(1 Ph)			0	
2	SDT-25 KVA			0	
3	SDT-50 KVA			0	
4	SDT-63 KVA			0	
5	SDT-100 KVA			0	
6	SDT-30 AMP			0	
7	10 KVA(3 Ph)			0	
8	16 KVA(3 Ph)			0	
9	25 KVA(3 Ph)			5	
10	40 KVA(3 Ph)			0	
11	63 KVA(3 Ph)			0	
12	100 KVA(3 Ph)			0	
Total				5	
48	Koilsa	GOPALGANJ	Gopalganj	225	Yes
New 11 KV or 22 KV Line :-					
Line Type					
Length(Ckt. Kms.)		0	Railway/Highway Crossing etc		

Works Proposed Under Feeder Separation

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of Block	Name of Eminating SubStation	Name of Feeder	Restricted demand after FS	Feeder Metering
Proposed Distribution Transformer :-					
	Sl.No.	Distribution Transformer		Total No. of DT	
	1	10 KVA(1 Ph)		0	
	2	SDT-25 KVA		0	
	3	SDT-50 KVA		0	
	4	SDT-63 KVA		0	
	5	SDT-100 KVA		0	
	6	SDT-30 AMP		0	
	7	10 KVA(3 Ph)		0	
	8	16 KVA(3 Ph)		0	
	9	25 KVA(3 Ph)		16	
	10	40 KVA(3 Ph)		0	
	11	63 KVA(3 Ph)		0	
	12	100 KVA(3 Ph)		0	
	Total				16
49	Koilsa	GOPALGANJ	Marfora	Nil	No
New 11 KV or 22 KV Line :-					
Line Type					
Length(Ckt. Kms.)		0	Railway/Highway Crossing etc		
Proposed Distribution Transformer :-					
	Sl.No.	Distribution Transformer		Total No. of DT	
	1	10 KVA(1 Ph)		0	
	2	SDT-25 KVA		0	

Works Proposed Under Feeder Separation

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of Block	Name of Emitting SubStation	Name of Feeder	Restricted demand after FS	Feeder Metering
	3	SDT-50 KVA			0
	4	SDT-63 KVA			0
	5	SDT-100 KVA			0
	6	SDT-30 AMP			0
	7	10 KVA(3 Ph)			0
	8	16 KVA(3 Ph)			0
	9	25 KVA(3 Ph)			18
	10	40 KVA(3 Ph)			0
	11	63 KVA(3 Ph)			0
	12	100 KVA(3 Ph)			0
	Total				18
50	Koilsa	RANIPUR	Khatoliya Feeder	225	Yes
New 11 KV or 22 KV Line :-					
Line Type					
Length(Ckt. Kms.)					
		0	Railway/Highway Crossing etc		
Proposed Distribution Transformer :-					
	Sl.No.	Distribution Transformer		Total No. of DT	
	1	10 KVA(1 Ph)		0	
	2	SDT-25 KVA		0	
	3	SDT-50 KVA		0	
	4	SDT-63 KVA		0	
	5	SDT-100 KVA		0	
	6	SDT-30 AMP		0	

Works Proposed Under Feeder Separation

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of Block	Name of Emitting SubStation	Name of Feeder	Restricted demand after FS	Feeder Metering
	7	10 KVA(3 Ph)			0
	8	16 KVA(3 Ph)			0
	9	25 KVA(3 Ph)			4
	10	40 KVA(3 Ph)			0
	11	63 KVA(3 Ph)			0
	12	100 KVA(3 Ph)			0
	Total				4
51	Koilsa	RANIPUR	Tonari Feeder	Nil	No
	New 11 KV or 22 KV Line :-				
	Line Type				
	Length(Ckt. Kms.)	0	Railway/Highway Crossing etc		
	Proposed Distribution Transformer :-				
	Sl.No.	Distribution Transformer		Total No. of DT	
	1	10 KVA(1 Ph)		0	
	2	SDT-25 KVA		0	
	3	SDT-50 KVA		0	
	4	SDT-63 KVA		0	
	5	SDT-100 KVA		0	
	6	SDT-30 AMP		0	
	7	10 KVA(3 Ph)		0	
	8	16 KVA(3 Ph)		0	
	9	25 KVA(3 Ph)		16	
	10	40 KVA(3 Ph)		0	

Works Proposed Under Feeder Separation

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of Block	Name of Emitting SubStation	Name of Feeder	Restricted demand after FS	Feeder Metering
	11	63 KVA(3 Ph)			0
	12	100 KVA(3 Ph)			0
	Total				16
52	Koilsa	RANIPUR	Koilsa Feeder	Nil	Yes
	New 11 KV or 22 KV Line :-				
	Line Type				
	Length(Ckt. Kms.)	0	Railway/Highway Crossing etc		
	Proposed Distribution Transformer :-				
	Sl.No.	Distribution Transformer		Total No. of DT	
	1	10 KVA(1 Ph)		0	
	2	SDT-25 KVA		0	
	3	SDT-50 KVA		0	
	4	SDT-63 KVA		0	
	5	SDT-100 KVA		0	
	6	SDT-30 AMP		0	
	7	10 KVA(3 Ph)		0	
	8	16 KVA(3 Ph)		0	
	9	25 KVA(3 Ph)		17	
	10	40 KVA(3 Ph)		0	
	11	63 KVA(3 Ph)		0	
	12	100 KVA(3 Ph)		0	
	Total			17	
53	Koilsa	SIKHULA	Sultanipuri	225	Yes

Works Proposed Under Feeder Separation

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of Block	Name of Emitting SubStation	Name of Feeder	Restricted demand after FS	Feeder Metering
	New 11 KV or 22 KV Line :-				
	Line Type				
	Length(Ckt. Kms.)	0	Railway/Highway Crossing etc		
	Proposed Distribution Transformer :-				
	Sl.No.	Distribution Transformer		Total No. of DT	
	1	10 KVA(1 Ph)		0	
	2	SDT-25 KVA		0	
	3	SDT-50 KVA		0	
	4	SDT-63 KVA		0	
	5	SDT-100 KVA		0	
	6	SDT-30 AMP		0	
	7	10 KVA(3 Ph)		0	
	8	16 KVA(3 Ph)		0	
	9	25 KVA(3 Ph)		11	
	10	40 KVA(3 Ph)		0	
	11	63 KVA(3 Ph)		0	
	12	100 KVA(3 Ph)		0	
	Total			11	
54	Koilsa	SIKHULA	Chimkuni	Nil	No
	New 11 KV or 22 KV Line :-				
	Line Type				
	Length(Ckt. Kms.)	0	Railway/Highway Crossing etc		
	Proposed Distribution Transformer :-				

Works Proposed Under Feeder Separation

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of Block	Name of Emitting SubStation	Name of Feeder	Restricted demand after FS	Feeder Metering
	Sl.No.	Distribution Transformer		Total No. of DT	
	1	10 KVA(1 Ph)		0	
	2	SDT-25 KVA		0	
	3	SDT-50 KVA		0	
	4	SDT-63 KVA		0	
	5	SDT-100 KVA		0	
	6	SDT-30 AMP		0	
	7	10 KVA(3 Ph)		0	
	8	16 KVA(3 Ph)		0	
	9	25 KVA(3 Ph)		10	
	10	40 KVA(3 Ph)		0	
	11	63 KVA(3 Ph)		0	
	12	100 KVA(3 Ph)		0	
	Total			10	
55	Koilsa	TEHSIL BURHANPUR	Basgan	225	Yes
	New 11 KV or 22 KV Line :-				
	Line Type				
	Length(Ckt. Kms.)	0	Railway/Highway Crossing etc		
	Proposed Distribution Transformer :-				
	Sl.No.	Distribution Transformer		Total No. of DT	
	1	10 KVA(1 Ph)		0	
	2	SDT-25 KVA		0	
	3	SDT-50 KVA		0	

Works Proposed Under Feeder Separation

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of Block	Name of Emitting SubStation	Name of Feeder	Restricted demand after FS	Feeder Metering
	4	SDT-63 KVA			0
	5	SDT-100 KVA			0
	6	SDT-30 AMP			0
	7	10 KVA(3 Ph)			0
	8	16 KVA(3 Ph)			0
	9	25 KVA(3 Ph)			11
	10	40 KVA(3 Ph)			0
	11	63 KVA(3 Ph)			0
	12	100 KVA(3 Ph)			0
	Total				11
56	Koilsa	TEHSIL BURHANPUR	Bheelampur	Nil	No
	New 11 KV or 22 KV Line :-				
	Line Type				
	Length(Ckt. Kms.)	0	Railway/Highway Crossing etc		
	Proposed Distribution Transformer :-				
	Sl.No.	Distribution Transformer		Total No. of DT	
	1	10 KVA(1 Ph)		0	
	2	SDT-25 KVA		0	
	3	SDT-50 KVA		0	
	4	SDT-63 KVA		0	
	5	SDT-100 KVA		0	
	6	SDT-30 AMP		0	
	7	10 KVA(3 Ph)		0	

Works Proposed Under Feeder Separation

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of Block	Name of Emitting SubStation	Name of Feeder	Restricted demand after FS	Feeder Metering
	8	16 KVA(3 Ph)			0
	9	25 KVA(3 Ph)			5
	10	40 KVA(3 Ph)			0
	11	63 KVA(3 Ph)			0
	12	100 KVA(3 Ph)			0
	Total				5
57	Koilsa	TEHSIL BURHANPUR	Makhanaha	Nil	No
New 11 KV or 22 KV Line :-					
Line Type					
Length(Ckt. Kms.)					
		0	Railway/Highway Crossing etc		
Proposed Distribution Transformer :-					
	Sl.No.	Distribution Transformer		Total No. of DT	
	1	10 KVA(1 Ph)		0	
	2	SDT-25 KVA		0	
	3	SDT-50 KVA		0	
	4	SDT-63 KVA		0	
	5	SDT-100 KVA		0	
	6	SDT-30 AMP		0	
	7	10 KVA(3 Ph)		0	
	8	16 KVA(3 Ph)		0	
	9	25 KVA(3 Ph)		23	
	10	40 KVA(3 Ph)		0	
	11	63 KVA(3 Ph)		0	

Works Proposed Under Feeder Separation

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of Block	Name of Emitting SubStation	Name of Feeder	Restricted demand after FS	Feeder Metering
	12	100 KVA(3 Ph)			0
	Total				23
58	Lalganj	DEOGAON	Deogaon	Nil	No
	New 11 KV or 22 KV Line :-				
	Line Type				
	Length(Ckt. Kms.)	0	Railway/Highway Crossing etc		
	Proposed Distribution Transformer :-				
	Sl.No.	Distribution Transformer		Total No. of DT	
	1	10 KVA(1 Ph)		0	
	2	SDT-25 KVA		0	
	3	SDT-50 KVA		0	
	4	SDT-63 KVA		0	
	5	SDT-100 KVA		0	
	6	SDT-30 AMP		0	
	7	10 KVA(3 Ph)		0	
	8	16 KVA(3 Ph)		0	
	9	25 KVA(3 Ph)		20	
	10	40 KVA(3 Ph)		0	
	11	63 KVA(3 Ph)		0	
	12	100 KVA(3 Ph)		0	
	Total			20	
59	Lalganj	DEOGAON	Kanhjit	Nil	No
	New 11 KV or 22 KV Line :-				

Works Proposed Under Feeder Separation

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of Block	Name of Emitting SubStation	Name of Feeder	Restricted demand after FS	Feeder Metering
	Line Type				
	Length(Ckt. Kms.)	0	Railway/Highway Crossing etc		
Proposed Distribution Transformer :-					
	Sl.No.	Distribution Transformer		Total No. of DT	
	1	10 KVA(1 Ph)		0	
	2	SDT-25 KVA		0	
	3	SDT-50 KVA		0	
	4	SDT-63 KVA		0	
	5	SDT-100 KVA		0	
	6	SDT-30 AMP		0	
	7	10 KVA(3 Ph)		0	
	8	16 KVA(3 Ph)		0	
	9	25 KVA(3 Ph)		30	
	10	40 KVA(3 Ph)		0	
	11	63 KVA(3 Ph)		0	
	12	100 KVA(3 Ph)		0	
	Total			30	
60	Lalganj	DEOGAON	Basahi	225	Yes
New 11 KV or 22 KV Line :-					
	Line Type				
	Length(Ckt. Kms.)	0	Railway/Highway Crossing etc		
Proposed Distribution Transformer :-					
	Sl.No.	Distribution Transformer		Total No. of DT	

Works Proposed Under Feeder Separation

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of Block	Name of Emitting SubStation	Name of Feeder	Restricted demand after FS	Feeder Metering
	1	10 KVA(1 Ph)			0
	2	SDT-25 KVA			0
	3	SDT-50 KVA			0
	4	SDT-63 KVA			0
	5	SDT-100 KVA			0
	6	SDT-30 AMP			0
	7	10 KVA(3 Ph)			0
	8	16 KVA(3 Ph)			0
	9	25 KVA(3 Ph)			14
	10	40 KVA(3 Ph)			0
	11	63 KVA(3 Ph)			0
	12	100 KVA(3 Ph)			0
	Total				14
61	Lalganj	LALGANJ	Sonwar	225	Yes
	New 11 KV or 22 KV Line :-				
	Line Type				
	Length(Ckt. Kms.)	0	Railway/Highway Crossing etc		
	Proposed Distribution Transformer :-				
	Sl.No.	Distribution Transformer		Total No. of DT	
	1	10 KVA(1 Ph)		0	
	2	SDT-25 KVA		0	
	3	SDT-50 KVA		0	
	4	SDT-63 KVA		0	

Works Proposed Under Feeder Separation

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of Block	Name of Eminating SubStation	Name of Feeder	Restricted demand after FS	Feeder Metering
	5	SDT-100 KVA			0
	6	SDT-30 AMP			0
	7	10 KVA(3 Ph)			0
	8	16 KVA(3 Ph)			0
	9	25 KVA(3 Ph)			19
	10	40 KVA(3 Ph)			0
	11	63 KVA(3 Ph)			0
	12	100 KVA(3 Ph)			0
	Total				19
62	Lalganj	LALGANJ	Gosai bazar	Nil	No
	New 11 KV or 22 KV Line :-				
	Line Type				
	Length(Ckt. Kms.)	0	Railway/Highway Crossing etc		
	Proposed Distribution Transformer :-				
	Sl.No.	Distribution Transformer		Total No. of DT	
	1	10 KVA(1 Ph)		0	
	2	SDT-25 KVA		0	
	3	SDT-50 KVA		0	
	4	SDT-63 KVA		0	
	5	SDT-100 KVA		0	
	6	SDT-30 AMP		0	
	7	10 KVA(3 Ph)		0	
	8	16 KVA(3 Ph)		0	

Works Proposed Under Feeder Separation

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of Block	Name of Emitting SubStation	Name of Feeder	Restricted demand after FS	Feeder Metering
	9	25 KVA(3 Ph)			21
	10	40 KVA(3 Ph)			0
	11	63 KVA(3 Ph)			0
	12	100 KVA(3 Ph)			0
	Total				21
63	Lalganj	LALGANJ	Devgaon	225	Yes
	New 11 KV or 22 KV Line :-				
	Line Type				
	Length(Ckt. Kms.)	0	Railway/Highway Crossing etc		
	Proposed Distribution Transformer :-				
	Sl.No.	Distribution Transformer		Total No. of DT	
	1	10 KVA(1 Ph)		0	
	2	SDT-25 KVA		0	
	3	SDT-50 KVA		0	
	4	SDT-63 KVA		0	
	5	SDT-100 KVA		0	
	6	SDT-30 AMP		0	
	7	10 KVA(3 Ph)		0	
	8	16 KVA(3 Ph)		0	
	9	25 KVA(3 Ph)		10	
	10	40 KVA(3 Ph)		0	
	11	63 KVA(3 Ph)		0	
	12	100 KVA(3 Ph)		0	

Works Proposed Under Feeder Separation

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of Block	Name of Emitting SubStation	Name of Feeder	Restricted demand after FS	Feeder Metering	
Total					10	
64	Lalganj	LALGANJ	Lumbhua	Nil	No	
	New 11 KV or 22 KV Line :-					
	Line Type					
	Length(Ckt. Kms.)		0	Railway/Highway Crossing etc		
	Proposed Distribution Transformer :-					
	Sl.No.	Distribution Transformer			Total No. of DT	
	1	10 KVA(1 Ph)			0	
	2	SDT-25 KVA			0	
	3	SDT-50 KVA			0	
	4	SDT-63 KVA			0	
	5	SDT-100 KVA			0	
	6	SDT-30 AMP			0	
	7	10 KVA(3 Ph)			0	
	8	16 KVA(3 Ph)			0	
9	25 KVA(3 Ph)			22		
10	40 KVA(3 Ph)			0		
11	63 KVA(3 Ph)			0		
12	100 KVA(3 Ph)			0		
Total					22	
65	Lalganj	JIRAKPUR	Sikraura	Nil	No	
	New 11 KV or 22 KV Line :-					
	Line Type					

Works Proposed Under Feeder Separation

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of Block	Name of Emitting SubStation	Name of Feeder	Restricted demand after FS	Feeder Metering
	Length(Ckt. Kms.)	0	Railway/Highway Crossing etc		
Proposed Distribution Transformer :-					
	Sl.No.	Distribution Transformer			Total No. of DT
	1	10 KVA(1 Ph)			0
	2	SDT-25 KVA			0
	3	SDT-50 KVA			0
	4	SDT-63 KVA			0
	5	SDT-100 KVA			0
	6	SDT-30 AMP			0
	7	10 KVA(3 Ph)			0
	8	16 KVA(3 Ph)			0
	9	25 KVA(3 Ph)			20
	10	40 KVA(3 Ph)			0
	11	63 KVA(3 Ph)			0
	12	100 KVA(3 Ph)			0
		Total			20
66	Lalganj	JIRAKPUR	Agehta	225	Yes
New 11 KV or 22 KV Line :-					
	Line Type				
	Length(Ckt. Kms.)	0	Railway/Highway Crossing etc		
Proposed Distribution Transformer :-					
	Sl.No.	Distribution Transformer			Total No. of DT
	1	10 KVA(1 Ph)			0

Works Proposed Under Feeder Separation

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of Block	Name of Emitting SubStation	Name of Feeder	Restricted demand after FS	Feeder Metering
	2	SDT-25 KVA			0
	3	SDT-50 KVA			0
	4	SDT-63 KVA			0
	5	SDT-100 KVA			0
	6	SDT-30 AMP			0
	7	10 KVA(3 Ph)			0
	8	16 KVA(3 Ph)			0
	9	25 KVA(3 Ph)			17
	10	40 KVA(3 Ph)			0
	11	63 KVA(3 Ph)			0
	12	100 KVA(3 Ph)			0
	Total				17
67	Lalganj	GOSAI KI BAZAR	Ubarpur	225	Yes
	New 11 KV or 22 KV Line :-				
	Line Type				
	Length(Ckt. Kms.)	0	Railway/Highway Crossing etc		
	Proposed Distribution Transformer :-				
	Sl.No.	Distribution Transformer		Total No. of DT	
	1	10 KVA(1 Ph)		0	
	2	SDT-25 KVA		0	
	3	SDT-50 KVA		0	
	4	SDT-63 KVA		0	
	5	SDT-100 KVA		0	

Works Proposed Under Feeder Separation

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of Block	Name of Emitting SubStation	Name of Feeder	Restricted demand after FS	Feeder Metering
	6	SDT-30 AMP			0
	7	10 KVA(3 Ph)			0
	8	16 KVA(3 Ph)			0
	9	25 KVA(3 Ph)			11
	10	40 KVA(3 Ph)			0
	11	63 KVA(3 Ph)			0
	12	100 KVA(3 Ph)			0
	Total				11
68	Lalganj	GOSAI KI BAZAR	Gosai ki Bazar	Nil	No
	New 11 KV or 22 KV Line :-				
	Line Type				
	Length(Ckt. Kms.)	0	Railway/Highway Crossing etc		
	Proposed Distribution Transformer :-				
	Sl.No.	Distribution Transformer		Total No. of DT	
	1	10 KVA(1 Ph)		0	
	2	SDT-25 KVA		0	
	3	SDT-50 KVA		0	
	4	SDT-63 KVA		0	
	5	SDT-100 KVA		0	
	6	SDT-30 AMP		0	
	7	10 KVA(3 Ph)		0	
	8	16 KVA(3 Ph)		0	
	9	25 KVA(3 Ph)		11	

Works Proposed Under Feeder Separation

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of Block	Name of Emitting SubStation	Name of Feeder	Restricted demand after FS	Feeder Metering
	10	40 KVA(3 Ph)			0
	11	63 KVA(3 Ph)			0
	12	100 KVA(3 Ph)			0
	Total				11
69	Lalganj	GOSAI KI BAZAR	Pandaha	Nil	No
	New 11 KV or 22 KV Line :-				
	Line Type				
	Length(Ckt. Kms.)		0	Railway/Highway Crossing etc	
	Proposed Distribution Transformer :-				
	Sl.No.	Distribution Transformer		Total No. of DT	
	1	10 KVA(1 Ph)		0	
	2	SDT-25 KVA		0	
	3	SDT-50 KVA		0	
	4	SDT-63 KVA		0	
	5	SDT-100 KVA		0	
	6	SDT-30 AMP		0	
	7	10 KVA(3 Ph)		0	
	8	16 KVA(3 Ph)		0	
	9	25 KVA(3 Ph)		15	
	10	40 KVA(3 Ph)		0	
	11	63 KVA(3 Ph)		0	
	12	100 KVA(3 Ph)		0	
	Total				15

Works Proposed Under Feeder Separation

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of Block	Name of Emitting SubStation	Name of Feeder	Restricted demand after FS	Feeder Metering
70	Mahrajganj	MAHRAJGANJ	West	Nil	No
New 11 KV or 22 KV Line :-					
Line Type					
Length(Ckt. Kms.)		0	Railway/Highway Crossing etc		
Proposed Distribution Transformer :-					
Sl.No.	Distribution Transformer			Total No. of DT	
1	10 KVA(1 Ph)			0	
2	SDT-25 KVA			0	
3	SDT-50 KVA			0	
4	SDT-63 KVA			0	
5	SDT-100 KVA			0	
6	SDT-30 AMP			0	
7	10 KVA(3 Ph)			0	
8	16 KVA(3 Ph)			0	
9	25 KVA(3 Ph)			22	
10	40 KVA(3 Ph)			0	
11	63 KVA(3 Ph)			0	
12	100 KVA(3 Ph)			0	
Total				22	
71	Mahrajganj	MAHRAJGANJ	East	Nil	No
New 11 KV or 22 KV Line :-					
Line Type					
Length(Ckt. Kms.)		0	Railway/Highway Crossing etc		

Works Proposed Under Feeder Separation

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of Block	Name of Emitting SubStation	Name of Feeder	Restricted demand after FS	Feeder Metering
Proposed Distribution Transformer :-					
	Sl.No.	Distribution Transformer		Total No. of DT	
	1	10 KVA(1 Ph)		0	
	2	SDT-25 KVA		0	
	3	SDT-50 KVA		0	
	4	SDT-63 KVA		0	
	5	SDT-100 KVA		0	
	6	SDT-30 AMP		0	
	7	10 KVA(3 Ph)		0	
	8	16 KVA(3 Ph)		0	
	9	25 KVA(3 Ph)		36	
	10	40 KVA(3 Ph)		0	
	11	63 KVA(3 Ph)		0	
	12	100 KVA(3 Ph)		0	
	Total			36	
72	Mahrajganj	MAHRAJGANJ	North	Nil	No
New 11 KV or 22 KV Line :-					
Line Type					
Length(Ckt. Kms.)		0	Railway/Highway Crossing etc		
Proposed Distribution Transformer :-					
	Sl.No.	Distribution Transformer		Total No. of DT	
	1	10 KVA(1 Ph)		0	
	2	SDT-25 KVA		0	

Works Proposed Under Feeder Separation

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of Block	Name of Emitting SubStation	Name of Feeder	Restricted demand after FS	Feeder Metering
	3	SDT-50 KVA			0
	4	SDT-63 KVA			0
	5	SDT-100 KVA			0
	6	SDT-30 AMP			0
	7	10 KVA(3 Ph)			0
	8	16 KVA(3 Ph)			0
	9	25 KVA(3 Ph)			19
	10	40 KVA(3 Ph)			0
	11	63 KVA(3 Ph)			0
	12	100 KVA(3 Ph)			0
	Total				19
73	Mahrajganj	MAHRAJGANJ	World bank	225	Yes
	New 11 KV or 22 KV Line :-				
	Line Type				
	Length(Ckt. Kms.)	0	Railway/Highway Crossing etc		
	Proposed Distribution Transformer :-				
	Sl.No.	Distribution Transformer		Total No. of DT	
	1	10 KVA(1 Ph)		0	
	2	SDT-25 KVA		0	
	3	SDT-50 KVA		0	
	4	SDT-63 KVA		0	
	5	SDT-100 KVA		0	
	6	SDT-30 AMP		0	

Works Proposed Under Feeder Separation

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of Block	Name of Eminating SubStation	Name of Feeder	Restricted demand after FS	Feeder Metering
	7	10 KVA(3 Ph)			0
	8	16 KVA(3 Ph)			0
	9	25 KVA(3 Ph)			14
	10	40 KVA(3 Ph)			0
	11	63 KVA(3 Ph)			0
	12	100 KVA(3 Ph)			0
	Total				14
74	Mahrajanj	KAPTANGANJ	Bhawanpur	Nil	No
	New 11 KV or 22 KV Line :-				
	Line Type				
	Length(Ckt. Kms.)	0	Railway/Highway Crossing etc		
	Proposed Distribution Transformer :-				
	Sl.No.	Distribution Transformer		Total No. of DT	
	1	10 KVA(1 Ph)		0	
	2	SDT-25 KVA		0	
	3	SDT-50 KVA		0	
	4	SDT-63 KVA		0	
	5	SDT-100 KVA		0	
	6	SDT-30 AMP		0	
	7	10 KVA(3 Ph)		0	
	8	16 KVA(3 Ph)		0	
	9	25 KVA(3 Ph)		15	
	10	40 KVA(3 Ph)		0	

Works Proposed Under Feeder Separation

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of Block	Name of Emitting SubStation	Name of Feeder	Restricted demand after FS	Feeder Metering
	11	63 KVA(3 Ph)			0
	12	100 KVA(3 Ph)			0
	Total				15
75	Mahrajganj	KAPTANGANJ	kaptanganj	Nil	No
	New 11 KV or 22 KV Line :-				
	Line Type				
	Length(Ckt. Kms.)	0	Railway/Highway Crossing etc		
	Proposed Distribution Transformer :-				
	Sl.No.	Distribution Transformer		Total No. of DT	
	1	10 KVA(1 Ph)		0	
	2	SDT-25 KVA		0	
	3	SDT-50 KVA		0	
	4	SDT-63 KVA		0	
	5	SDT-100 KVA		0	
	6	SDT-30 AMP		0	
	7	10 KVA(3 Ph)		0	
	8	16 KVA(3 Ph)		0	
	9	25 KVA(3 Ph)		14	
	10	40 KVA(3 Ph)		0	
	11	63 KVA(3 Ph)		0	
	12	100 KVA(3 Ph)		0	
	Total				14
76	Mahrajganj	KAPTANGANJ	Deoria	225	Yes

Works Proposed Under Feeder Separation

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of Block	Name of Emitting SubStation	Name of Feeder	Restricted demand after FS	Feeder Metering
	New 11 KV or 22 KV Line :-				
	Line Type				
	Length(Ckt. Kms.)	0	Railway/Highway Crossing etc		
	Proposed Distribution Transformer :-				
	Sl.No.	Distribution Transformer		Total No. of DT	
	1	10 KVA(1 Ph)		0	
	2	SDT-25 KVA		0	
	3	SDT-50 KVA		0	
	4	SDT-63 KVA		0	
	5	SDT-100 KVA		0	
	6	SDT-30 AMP		0	
	7	10 KVA(3 Ph)		0	
	8	16 KVA(3 Ph)		0	
	9	25 KVA(3 Ph)		11	
	10	40 KVA(3 Ph)		0	
	11	63 KVA(3 Ph)		0	
	12	100 KVA(3 Ph)		0	
	Total			11	
77	Mahrajanj	KAPTANGANJ	Mehmauni	Nil	No
	New 11 KV or 22 KV Line :-				
	Line Type				
	Length(Ckt. Kms.)	0	Railway/Highway Crossing etc		
	Proposed Distribution Transformer :-				

Works Proposed Under Feeder Separation

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of Block	Name of Emitting SubStation	Name of Feeder	Restricted demand after FS	Feeder Metering
	Sl.No.	Distribution Transformer		Total No. of DT	
	1	10 KVA(1 Ph)		0	
	2	SDT-25 KVA		0	
	3	SDT-50 KVA		0	
	4	SDT-63 KVA		0	
	5	SDT-100 KVA		0	
	6	SDT-30 AMP		0	
	7	10 KVA(3 Ph)		0	
	8	16 KVA(3 Ph)		0	
	9	25 KVA(3 Ph)		10	
	10	40 KVA(3 Ph)		0	
	11	63 KVA(3 Ph)		0	
	12	100 KVA(3 Ph)		0	
	Total			10	
78	Martinganj	MARTINGANJ	Bakhara Feeder	Nil	No
	New 11 KV or 22 KV Line :-				
	Line Type				
	Length(Ckt. Kms.)	0	Railway/Highway Crossing etc		
	Proposed Distribution Transformer :-				
	Sl.No.	Distribution Transformer		Total No. of DT	
	1	10 KVA(1 Ph)		0	
	2	SDT-25 KVA		0	
	3	SDT-50 KVA		0	

Works Proposed Under Feeder Separation

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of Block	Name of Eminating SubStation	Name of Feeder	Restricted demand after FS	Feeder Metering
	4	SDT-63 KVA			0
	5	SDT-100 KVA			0
	6	SDT-30 AMP			0
	7	10 KVA(3 Ph)			0
	8	16 KVA(3 Ph)			0
	9	25 KVA(3 Ph)			24
	10	40 KVA(3 Ph)			0
	11	63 KVA(3 Ph)			0
	12	100 KVA(3 Ph)			0
	Total				24
79	Martinganj	MARTINGANJ	Siswara Feeder	Nil	No
	New 11 KV or 22 KV Line :-				
	Line Type				
	Length(Ckt. Kms.)	0	Railway/Highway Crossing etc		
	Proposed Distribution Transformer :-				
	Sl.No.	Distribution Transformer		Total No. of DT	
	1	10 KVA(1 Ph)		0	
	2	SDT-25 KVA		0	
	3	SDT-50 KVA		0	
	4	SDT-63 KVA		0	
	5	SDT-100 KVA		0	
	6	SDT-30 AMP		0	
	7	10 KVA(3 Ph)		0	

Works Proposed Under Feeder Separation

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of Block	Name of Emitting SubStation	Name of Feeder	Restricted demand after FS	Feeder Metering
	8	16 KVA(3 Ph)			0
	9	25 KVA(3 Ph)			14
	10	40 KVA(3 Ph)			0
	11	63 KVA(3 Ph)			0
	12	100 KVA(3 Ph)			0
	Total				14
80	Martinganj	MARTINGANJ	Belwana Feeder	225	Yes
New 11 KV or 22 KV Line :-					
Line Type					
Length(Ckt. Kms.)					
		0	Railway/Highway Crossing etc		
Proposed Distribution Transformer :-					
	Sl.No.	Distribution Transformer		Total No. of DT	
	1	10 KVA(1 Ph)		0	
	2	SDT-25 KVA		0	
	3	SDT-50 KVA		0	
	4	SDT-63 KVA		0	
	5	SDT-100 KVA		0	
	6	SDT-30 AMP		0	
	7	10 KVA(3 Ph)		0	
	8	16 KVA(3 Ph)		0	
	9	25 KVA(3 Ph)		29	
	10	40 KVA(3 Ph)		0	
	11	63 KVA(3 Ph)		0	

Works Proposed Under Feeder Separation

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of Block	Name of Emitting SubStation	Name of Feeder	Restricted demand after FS	Feeder Metering
	12	100 KVA(3 Ph)			0
	Total				29
81	Mehnagar	MEH NAGAR	Laudah	225	Yes
	New 11 KV or 22 KV Line :-				
	Line Type				
	Length(Ckt. Kms.)	0	Railway/Highway Crossing etc		
	Proposed Distribution Transformer :-				
	Sl.No.	Distribution Transformer		Total No. of DT	
	1	10 KVA(1 Ph)		0	
	2	SDT-25 KVA		0	
	3	SDT-50 KVA		0	
	4	SDT-63 KVA		0	
	5	SDT-100 KVA		0	
	6	SDT-30 AMP		0	
	7	10 KVA(3 Ph)		0	
	8	16 KVA(3 Ph)		0	
	9	25 KVA(3 Ph)		12	
	10	40 KVA(3 Ph)		0	
	11	63 KVA(3 Ph)		0	
	12	100 KVA(3 Ph)		0	
	Total				12
82	Mehnagar	MEH NAGAR	Chakwara	Nil	No
	New 11 KV or 22 KV Line :-				

Works Proposed Under Feeder Separation

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of Block	Name of Emitting SubStation	Name of Feeder	Restricted demand after FS	Feeder Metering
	Line Type				
	Length(Ckt. Kms.)	0	Railway/Highway Crossing etc		
Proposed Distribution Transformer :-					
	Sl.No.	Distribution Transformer		Total No. of DT	
	1	10 KVA(1 Ph)		0	
	2	SDT-25 KVA		0	
	3	SDT-50 KVA		0	
	4	SDT-63 KVA		0	
	5	SDT-100 KVA		0	
	6	SDT-30 AMP		0	
	7	10 KVA(3 Ph)		0	
	8	16 KVA(3 Ph)		0	
	9	25 KVA(3 Ph)		16	
	10	40 KVA(3 Ph)		0	
	11	63 KVA(3 Ph)		0	
	12	100 KVA(3 Ph)		0	
	Total			16	
83	Mehnagar	MEH NAGAR	Kharag Pur	225	Yes
New 11 KV or 22 KV Line :-					
	Line Type				
	Length(Ckt. Kms.)	0	Railway/Highway Crossing etc		
Proposed Distribution Transformer :-					
	Sl.No.	Distribution Transformer		Total No. of DT	

Works Proposed Under Feeder Separation

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of Block	Name of Emitting SubStation	Name of Feeder	Restricted demand after FS	Feeder Metering
	1	10 KVA(1 Ph)			0
	2	SDT-25 KVA			0
	3	SDT-50 KVA			0
	4	SDT-63 KVA			0
	5	SDT-100 KVA			0
	6	SDT-30 AMP			0
	7	10 KVA(3 Ph)			0
	8	16 KVA(3 Ph)			0
	9	25 KVA(3 Ph)			13
	10	40 KVA(3 Ph)			0
	11	63 KVA(3 Ph)			0
	12	100 KVA(3 Ph)			0
	Total				13
84	Mehnagar	KHAMARIYA	Khatahan	225	Yes
	New 11 KV or 22 KV Line :-				
	Line Type				
	Length(Ckt. Kms.)	0	Railway/Highway Crossing etc		
	Proposed Distribution Transformer :-				
	Sl.No.	Distribution Transformer		Total No. of DT	
	1	10 KVA(1 Ph)		0	
	2	SDT-25 KVA		0	
	3	SDT-50 KVA		0	
	4	SDT-63 KVA		0	

Works Proposed Under Feeder Separation

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of Block	Name of Emitting SubStation	Name of Feeder	Restricted demand after FS	Feeder Metering
	5	SDT-100 KVA			0
	6	SDT-30 AMP			0
	7	10 KVA(3 Ph)			0
	8	16 KVA(3 Ph)			0
	9	25 KVA(3 Ph)			21
	10	40 KVA(3 Ph)			0
	11	63 KVA(3 Ph)			0
	12	100 KVA(3 Ph)			0
	Total				21
85	Mehnagar	KHAMARIYA	Kamharia	Nil	No
	New 11 KV or 22 KV Line :-				
	Line Type				
	Length(Ckt. Kms.)	0	Railway/Highway Crossing etc		
	Proposed Distribution Transformer :-				
	Sl.No.	Distribution Transformer		Total No. of DT	
	1	10 KVA(1 Ph)		0	
	2	SDT-25 KVA		0	
	3	SDT-50 KVA		0	
	4	SDT-63 KVA		0	
	5	SDT-100 KVA		0	
	6	SDT-30 AMP		0	
	7	10 KVA(3 Ph)		0	
	8	16 KVA(3 Ph)		0	

Works Proposed Under Feeder Separation

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of Block	Name of Emitting SubStation	Name of Feeder	Restricted demand after FS	Feeder Metering
	9	25 KVA(3 Ph)			26
	10	40 KVA(3 Ph)			0
	11	63 KVA(3 Ph)			0
	12	100 KVA(3 Ph)			0
	Total				26
86	Mirzapur	DATTATREYA	Nizamabad	Nil	No
	New 11 KV or 22 KV Line :-				
	Line Type				
	Length(Ckt. Kms.)	0	Railway/Highway Crossing etc		
	Proposed Distribution Transformer :-				
	Sl.No.	Distribution Transformer		Total No. of DT	
	1	10 KVA(1 Ph)		0	
	2	SDT-25 KVA		0	
	3	SDT-50 KVA		0	
	4	SDT-63 KVA		0	
	5	SDT-100 KVA		0	
	6	SDT-30 AMP		0	
	7	10 KVA(3 Ph)		0	
	8	16 KVA(3 Ph)		0	
	9	25 KVA(3 Ph)		17	
	10	40 KVA(3 Ph)		0	
	11	63 KVA(3 Ph)		0	
	12	100 KVA(3 Ph)		0	

Works Proposed Under Feeder Separation

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of Block	Name of Emitting SubStation	Name of Feeder	Restricted demand after FS	Feeder Metering	
Total					17	
87	Mirzapur	DATTATREYA	Mirzapur	Nil	No	
	New 11 KV or 22 KV Line :-					
	Line Type					
	Length(Ckt. Kms.)		0	Railway/Highway Crossing etc		
	Proposed Distribution Transformer :-					
	Sl.No.	Distribution Transformer			Total No. of DT	
	1	10 KVA(1 Ph)			0	
	2	SDT-25 KVA			0	
	3	SDT-50 KVA			0	
	4	SDT-63 KVA			0	
	5	SDT-100 KVA			0	
	6	SDT-30 AMP			0	
	7	10 KVA(3 Ph)			0	
	8	16 KVA(3 Ph)			0	
	9	25 KVA(3 Ph)			19	
10	40 KVA(3 Ph)			0		
11	63 KVA(3 Ph)			0		
12	100 KVA(3 Ph)			0		
Total					19	
88	Mirzapur	DATTATREYA	Mohnathpur	225	Yes	
	New 11 KV or 22 KV Line :-					
	Line Type					

Works Proposed Under Feeder Separation

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of Block	Name of Emitting SubStation	Name of Feeder	Restricted demand after FS	Feeder Metering
	Length(Ckt. Kms.)	0	Railway/Highway Crossing etc		
Proposed Distribution Transformer :-					
	Sl.No.	Distribution Transformer			Total No. of DT
	1	10 KVA(1 Ph)			0
	2	SDT-25 KVA			0
	3	SDT-50 KVA			0
	4	SDT-63 KVA			0
	5	SDT-100 KVA			0
	6	SDT-30 AMP			0
	7	10 KVA(3 Ph)			0
	8	16 KVA(3 Ph)			0
	9	25 KVA(3 Ph)			19
	10	40 KVA(3 Ph)			0
	11	63 KVA(3 Ph)			0
	12	100 KVA(3 Ph)			0
		Total			19
89	Mirzapur	SARAI MEER	Basti	225	Yes
New 11 KV or 22 KV Line :-					
	Line Type				
	Length(Ckt. Kms.)	0	Railway/Highway Crossing etc		
Proposed Distribution Transformer :-					
	Sl.No.	Distribution Transformer			Total No. of DT
	1	10 KVA(1 Ph)			0

Works Proposed Under Feeder Separation

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of Block	Name of Emitting SubStation	Name of Feeder	Restricted demand after FS	Feeder Metering
	2	SDT-25 KVA			0
	3	SDT-50 KVA			0
	4	SDT-63 KVA			0
	5	SDT-100 KVA			0
	6	SDT-30 AMP			0
	7	10 KVA(3 Ph)			0
	8	16 KVA(3 Ph)			0
	9	25 KVA(3 Ph)			11
	10	40 KVA(3 Ph)			0
	11	63 KVA(3 Ph)			0
	12	100 KVA(3 Ph)			0
	Total				11
90	Mirzapur	SARAI MEER	Nandau	225	Yes
	New 11 KV or 22 KV Line :-				
	Line Type				
	Length(Ckt. Kms.)	0	Railway/Highway Crossing etc		
	Proposed Distribution Transformer :-				
	Sl.No.	Distribution Transformer		Total No. of DT	
	1	10 KVA(1 Ph)		0	
	2	SDT-25 KVA		0	
	3	SDT-50 KVA		0	
	4	SDT-63 KVA		0	
	5	SDT-100 KVA		0	

Works Proposed Under Feeder Separation

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of Block	Name of Eminating SubStation	Name of Feeder	Restricted demand after FS	Feeder Metering
	6	SDT-30 AMP			0
	7	10 KVA(3 Ph)			0
	8	16 KVA(3 Ph)			0
	9	25 KVA(3 Ph)			20
	10	40 KVA(3 Ph)			0
	11	63 KVA(3 Ph)			0
	12	100 KVA(3 Ph)			0
	Total				20
91	Mohammadpur	CHHAU	Belu	Nil	No
	New 11 KV or 22 KV Line :-				
	Line Type				
	Length(Ckt. Kms.)	0	Railway/Highway Crossing etc		
	Proposed Distribution Transformer :-				
	Sl.No.	Distribution Transformer		Total No. of DT	
	1	10 KVA(1 Ph)		0	
	2	SDT-25 KVA		0	
	3	SDT-50 KVA		0	
	4	SDT-63 KVA		0	
	5	SDT-100 KVA		0	
	6	SDT-30 AMP		0	
	7	10 KVA(3 Ph)		0	
	8	16 KVA(3 Ph)		0	
	9	25 KVA(3 Ph)		34	

Works Proposed Under Feeder Separation

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of Block	Name of Emitting SubStation	Name of Feeder	Restricted demand after FS	Feeder Metering
	10	40 KVA(3 Ph)			0
	11	63 KVA(3 Ph)			0
	12	100 KVA(3 Ph)			0
	Total				34
92	Mohammadpur	CHHAU	Chhau	225	Yes
New 11 KV or 22 KV Line :-					
Line Type					
Length(Ckt. Kms.)					
		0	Railway/Highway Crossing etc		
Proposed Distribution Transformer :-					
Sl.No.	Distribution Transformer			Total No. of DT	
1	10 KVA(1 Ph)			0	
2	SDT-25 KVA			0	
3	SDT-50 KVA			0	
4	SDT-63 KVA			0	
5	SDT-100 KVA			0	
6	SDT-30 AMP			0	
7	10 KVA(3 Ph)			0	
8	16 KVA(3 Ph)			0	
9	25 KVA(3 Ph)			10	
10	40 KVA(3 Ph)			0	
11	63 KVA(3 Ph)			0	
12	100 KVA(3 Ph)			0	
	Total				10

Works Proposed Under Feeder Separation

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of Block	Name of Emitting SubStation	Name of Feeder	Restricted demand after FS	Feeder Metering	
93	Mohammadpur	CHHAU	Gambhirpur	Nil	No	
	New 11 KV or 22 KV Line :-					
	Line Type					
	Length(Ckt. Kms.)		0	Railway/Highway Crossing etc		
	Proposed Distribution Transformer :-					
	Sl.No.	Distribution Transformer			Total No. of DT	
	1	10 KVA(1 Ph)			0	
	2	SDT-25 KVA			0	
	3	SDT-50 KVA			0	
	4	SDT-63 KVA			0	
	5	SDT-100 KVA			0	
	6	SDT-30 AMP			0	
	7	10 KVA(3 Ph)			0	
	8	16 KVA(3 Ph)			0	
	9	25 KVA(3 Ph)			14	
10	40 KVA(3 Ph)			0		
11	63 KVA(3 Ph)			0		
12	100 KVA(3 Ph)			0		
Total				14		
94	Mohammadpur	MUHAMMAD PUR	North	Nil	No	
	New 11 KV or 22 KV Line :-					
	Line Type					
	Length(Ckt. Kms.)		0	Railway/Highway Crossing etc		

Works Proposed Under Feeder Separation

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of Block	Name of Emitting SubStation	Name of Feeder	Restricted demand after FS	Feeder Metering
Proposed Distribution Transformer :-					
	Sl.No.	Distribution Transformer		Total No. of DT	
	1	10 KVA(1 Ph)		0	
	2	SDT-25 KVA		0	
	3	SDT-50 KVA		0	
	4	SDT-63 KVA		0	
	5	SDT-100 KVA		0	
	6	SDT-30 AMP		0	
	7	10 KVA(3 Ph)		0	
	8	16 KVA(3 Ph)		0	
	9	25 KVA(3 Ph)		14	
	10	40 KVA(3 Ph)		0	
	11	63 KVA(3 Ph)		0	
	12	100 KVA(3 Ph)		0	
	Total			14	
95	Mohammadpur	MUHAMMAD PUR	South	225	Yes
New 11 KV or 22 KV Line :-					
Line Type					
Length(Ckt. Kms.)		0	Railway/Highway Crossing etc		
Proposed Distribution Transformer :-					
	Sl.No.	Distribution Transformer		Total No. of DT	
	1	10 KVA(1 Ph)		0	
	2	SDT-25 KVA		0	

Works Proposed Under Feeder Separation

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of Block	Name of Emitting SubStation	Name of Feeder	Restricted demand after FS	Feeder Metering
	3	SDT-50 KVA			0
	4	SDT-63 KVA			0
	5	SDT-100 KVA			0
	6	SDT-30 AMP			0
	7	10 KVA(3 Ph)			0
	8	16 KVA(3 Ph)			0
	9	25 KVA(3 Ph)			23
	10	40 KVA(3 Ph)			0
	11	63 KVA(3 Ph)			0
	12	100 KVA(3 Ph)			0
	Total				23
96	Mohammadpur	MUHAMMAD PUR	Rowa	Nil	No
New 11 KV or 22 KV Line :-					
Line Type					
Length(Ckt. Kms.)					
		0	Railway/Highway Crossing etc		
Proposed Distribution Transformer :-					
	Sl.No.	Distribution Transformer		Total No. of DT	
	1	10 KVA(1 Ph)		0	
	2	SDT-25 KVA		0	
	3	SDT-50 KVA		0	
	4	SDT-63 KVA		0	
	5	SDT-100 KVA		0	
	6	SDT-30 AMP		0	

Works Proposed Under Feeder Separation

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of Block	Name of Emitting SubStation	Name of Feeder	Restricted demand after FS	Feeder Metering
	7	10 KVA(3 Ph)			0
	8	16 KVA(3 Ph)			0
	9	25 KVA(3 Ph)			18
	10	40 KVA(3 Ph)			0
	11	63 KVA(3 Ph)			0
	12	100 KVA(3 Ph)			0
	Total				18
97	Mohammadpur	MUHAMMAD PUR	Bindra Bazar	Nil	No
	New 11 KV or 22 KV Line :-				
	Line Type				
	Length(Ckt. Kms.)	0	Railway/Highway Crossing etc		
	Proposed Distribution Transformer :-				
	Sl.No.	Distribution Transformer		Total No. of DT	
	1	10 KVA(1 Ph)		0	
	2	SDT-25 KVA		0	
	3	SDT-50 KVA		0	
	4	SDT-63 KVA		0	
	5	SDT-100 KVA		0	
	6	SDT-30 AMP		0	
	7	10 KVA(3 Ph)		0	
	8	16 KVA(3 Ph)		0	
	9	25 KVA(3 Ph)		6	
	10	40 KVA(3 Ph)		0	

Works Proposed Under Feeder Separation

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of Block	Name of Emitting SubStation	Name of Feeder	Restricted demand after FS	Feeder Metering
	11	63 KVA(3 Ph)			0
	12	100 KVA(3 Ph)			0
	Total				6
98	Mohammadpur	GOTHAWAN	Gothawan	225	Yes
	New 11 KV or 22 KV Line :-				
	Line Type				
	Length(Ckt. Kms.)	0	Railway/Highway Crossing etc		
	Proposed Distribution Transformer :-				
	Sl.No.	Distribution Transformer		Total No. of DT	
	1	10 KVA(1 Ph)		0	
	2	SDT-25 KVA		0	
	3	SDT-50 KVA		0	
	4	SDT-63 KVA		0	
	5	SDT-100 KVA		0	
	6	SDT-30 AMP		0	
	7	10 KVA(3 Ph)		0	
	8	16 KVA(3 Ph)		0	
	9	25 KVA(3 Ph)		14	
	10	40 KVA(3 Ph)		0	
	11	63 KVA(3 Ph)		0	
	12	100 KVA(3 Ph)		0	
	Total			14	
99	Mohammadpur	GOTHAWAN	Nandaoh	Nil	No

Works Proposed Under Feeder Separation

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of Block	Name of Emitting SubStation	Name of Feeder	Restricted demand after FS	Feeder Metering
	New 11 KV or 22 KV Line :-				
	Line Type				
	Length(Ckt. Kms.)	0	Railway/Highway Crossing etc		
	Proposed Distribution Transformer :-				
	Sl.No.	Distribution Transformer		Total No. of DT	
	1	10 KVA(1 Ph)		0	
	2	SDT-25 KVA		0	
	3	SDT-50 KVA		0	
	4	SDT-63 KVA		0	
	5	SDT-100 KVA		0	
	6	SDT-30 AMP		0	
	7	10 KVA(3 Ph)		0	
	8	16 KVA(3 Ph)		0	
	9	25 KVA(3 Ph)		19	
	10	40 KVA(3 Ph)		0	
	11	63 KVA(3 Ph)		0	
	12	100 KVA(3 Ph)		0	
	Total			19	
100	Palhani	ZAFFARPUR	South	225	Yes
	New 11 KV or 22 KV Line :-				
	Line Type				
	Length(Ckt. Kms.)	0	Railway/Highway Crossing etc		
	Proposed Distribution Transformer :-				

Works Proposed Under Feeder Separation

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of Block	Name of Emitting SubStation	Name of Feeder	Restricted demand after FS	Feeder Metering
	Sl.No.	Distribution Transformer		Total No. of DT	
	1	10 KVA(1 Ph)		0	
	2	SDT-25 KVA		0	
	3	SDT-50 KVA		0	
	4	SDT-63 KVA		0	
	5	SDT-100 KVA		0	
	6	SDT-30 AMP		0	
	7	10 KVA(3 Ph)		0	
	8	16 KVA(3 Ph)		0	
	9	25 KVA(3 Ph)		36	
	10	40 KVA(3 Ph)		0	
	11	63 KVA(3 Ph)		0	
	12	100 KVA(3 Ph)		0	
	Total			36	
101	Palhna	SHEIKHPURA	Ahopatti	Nil	No
	New 11 KV or 22 KV Line :-				
	Line Type				
	Length(Ckt. Kms.)	0	Railway/Highway Crossing etc		
	Proposed Distribution Transformer :-				
	Sl.No.	Distribution Transformer		Total No. of DT	
	1	10 KVA(1 Ph)		0	
	2	SDT-25 KVA		0	
	3	SDT-50 KVA		0	

Works Proposed Under Feeder Separation

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of Block	Name of Emitting SubStation	Name of Feeder	Restricted demand after FS	Feeder Metering
	4	SDT-63 KVA			0
	5	SDT-100 KVA			0
	6	SDT-30 AMP			0
	7	10 KVA(3 Ph)			0
	8	16 KVA(3 Ph)			0
	9	25 KVA(3 Ph)			32
	10	40 KVA(3 Ph)			0
	11	63 KVA(3 Ph)			0
	12	100 KVA(3 Ph)			0
	Total				32
102	Palhna	SHEIKHPURA	Badhopur	225	Yes
	New 11 KV or 22 KV Line :-				
	Line Type				
	Length(Ckt. Kms.)	0	Railway/Highway Crossing etc		
	Proposed Distribution Transformer :-				
	Sl.No.	Distribution Transformer		Total No. of DT	
	1	10 KVA(1 Ph)		0	
	2	SDT-25 KVA		0	
	3	SDT-50 KVA		0	
	4	SDT-63 KVA		0	
	5	SDT-100 KVA		0	
	6	SDT-30 AMP		0	
	7	10 KVA(3 Ph)		0	

Works Proposed Under Feeder Separation

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of Block	Name of Emitting SubStation	Name of Feeder	Restricted demand after FS	Feeder Metering
	8	16 KVA(3 Ph)			0
	9	25 KVA(3 Ph)			10
	10	40 KVA(3 Ph)			0
	11	63 KVA(3 Ph)			0
	12	100 KVA(3 Ph)			0
	Total				10
103	Palhna	KARSARA	Chutara	225	Yes
New 11 KV or 22 KV Line :-					
Line Type					
Length(Ckt. Kms.)					
		0	Railway/Highway Crossing etc		
Proposed Distribution Transformer :-					
	Sl.No.	Distribution Transformer		Total No. of DT	
	1	10 KVA(1 Ph)		0	
	2	SDT-25 KVA		0	
	3	SDT-50 KVA		0	
	4	SDT-63 KVA		0	
	5	SDT-100 KVA		0	
	6	SDT-30 AMP		0	
	7	10 KVA(3 Ph)		0	
	8	16 KVA(3 Ph)		0	
	9	25 KVA(3 Ph)		8	
	10	40 KVA(3 Ph)		0	
	11	63 KVA(3 Ph)		0	

Works Proposed Under Feeder Separation

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of Block	Name of Emitting SubStation	Name of Feeder	Restricted demand after FS	Feeder Metering
	12	100 KVA(3 Ph)			0
	Total				8
104	Palhna	KARSARA	Karsara	Nil	No
	New 11 KV or 22 KV Line :-				
	Line Type				
	Length(Ckt. Kms.)	0	Railway/Highway Crossing etc		
	Proposed Distribution Transformer :-				
	Sl.No.	Distribution Transformer		Total No. of DT	
	1	10 KVA(1 Ph)		0	
	2	SDT-25 KVA		0	
	3	SDT-50 KVA		0	
	4	SDT-63 KVA		0	
	5	SDT-100 KVA		0	
	6	SDT-30 AMP		0	
	7	10 KVA(3 Ph)		0	
	8	16 KVA(3 Ph)		0	
	9	25 KVA(3 Ph)		37	
	10	40 KVA(3 Ph)		0	
	11	63 KVA(3 Ph)		0	
	12	100 KVA(3 Ph)		0	
	Total				37
105	Palhna	KARSARA	Bela	Nil	No
	New 11 KV or 22 KV Line :-				

Works Proposed Under Feeder Separation

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of Block	Name of Emitting SubStation	Name of Feeder	Restricted demand after FS	Feeder Metering
	Line Type				
	Length(Ckt. Kms.)	0	Railway/Highway Crossing etc		
Proposed Distribution Transformer :-					
	Sl.No.	Distribution Transformer		Total No. of DT	
	1	10 KVA(1 Ph)		0	
	2	SDT-25 KVA		0	
	3	SDT-50 KVA		0	
	4	SDT-63 KVA		0	
	5	SDT-100 KVA		0	
	6	SDT-30 AMP		0	
	7	10 KVA(3 Ph)		0	
	8	16 KVA(3 Ph)		0	
	9	25 KVA(3 Ph)		5	
	10	40 KVA(3 Ph)		0	
	11	63 KVA(3 Ph)		0	
	12	100 KVA(3 Ph)		0	
	Total				5
106	Palhna	PALAHANA	Palahana	Nil	No
New 11 KV or 22 KV Line :-					
	Line Type				
	Length(Ckt. Kms.)	0	Railway/Highway Crossing etc		
Proposed Distribution Transformer :-					
	Sl.No.	Distribution Transformer		Total No. of DT	

Works Proposed Under Feeder Separation

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of Block	Name of Emitting SubStation	Name of Feeder	Restricted demand after FS	Feeder Metering
	1	10 KVA(1 Ph)			0
	2	SDT-25 KVA			0
	3	SDT-50 KVA			0
	4	SDT-63 KVA			0
	5	SDT-100 KVA			0
	6	SDT-30 AMP			0
	7	10 KVA(3 Ph)			0
	8	16 KVA(3 Ph)			0
	9	25 KVA(3 Ph)			26
	10	40 KVA(3 Ph)			0
	11	63 KVA(3 Ph)			0
	12	100 KVA(3 Ph)			0
	Total				26
107	Palhna	PALAHANA	Lhua	225	Yes
	New 11 KV or 22 KV Line :-				
	Line Type				
	Length(Ckt. Kms.)	0	Railway/Highway Crossing etc		
	Proposed Distribution Transformer :-				
	Sl.No.	Distribution Transformer		Total No. of DT	
	1	10 KVA(1 Ph)		0	
	2	SDT-25 KVA		0	
	3	SDT-50 KVA		0	
	4	SDT-63 KVA		0	

Works Proposed Under Feeder Separation

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of Block	Name of Emitting SubStation	Name of Feeder	Restricted demand after FS	Feeder Metering
	5	SDT-100 KVA			0
	6	SDT-30 AMP			0
	7	10 KVA(3 Ph)			0
	8	16 KVA(3 Ph)			0
	9	25 KVA(3 Ph)			27
	10	40 KVA(3 Ph)			0
	11	63 KVA(3 Ph)			0
	12	100 KVA(3 Ph)			0
	Total				27
108	Palhna	BHAWAR NATH	Heera palti	225	Yes
	New 11 KV or 22 KV Line :-				
	Line Type				
	Length(Ckt. Kms.)	0	Railway/Highway Crossing etc		
	Proposed Distribution Transformer :-				
	Sl.No.	Distribution Transformer		Total No. of DT	
	1	10 KVA(1 Ph)		0	
	2	SDT-25 KVA		0	
	3	SDT-50 KVA		0	
	4	SDT-63 KVA		0	
	5	SDT-100 KVA		0	
	6	SDT-30 AMP		0	
	7	10 KVA(3 Ph)		0	
	8	16 KVA(3 Ph)		0	

Works Proposed Under Feeder Separation

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of Block	Name of Emitting SubStation	Name of Feeder	Restricted demand after FS	Feeder Metering
	9	25 KVA(3 Ph)			17
	10	40 KVA(3 Ph)			0
	11	63 KVA(3 Ph)			0
	12	100 KVA(3 Ph)			0
	Total				17
109	Palhna	BHAWAR NATH	Kandharapur	225	Yes
	New 11 KV or 22 KV Line :-				
	Line Type				
	Length(Ckt. Kms.)	0	Railway/Highway Crossing etc		
	Proposed Distribution Transformer :-				
	Sl.No.	Distribution Transformer		Total No. of DT	
	1	10 KVA(1 Ph)		0	
	2	SDT-25 KVA		0	
	3	SDT-50 KVA		0	
	4	SDT-63 KVA		0	
	5	SDT-100 KVA		0	
	6	SDT-30 AMP		0	
	7	10 KVA(3 Ph)		0	
	8	16 KVA(3 Ph)		0	
	9	25 KVA(3 Ph)		14	
	10	40 KVA(3 Ph)		0	
	11	63 KVA(3 Ph)		0	
	12	100 KVA(3 Ph)		0	

Works Proposed Under Feeder Separation

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of Block	Name of Emitting SubStation	Name of Feeder	Restricted demand after FS	Feeder Metering	
Total					14	
110	Palhna	KANDHARPUR	Azampur	Nil	No	
	New 11 KV or 22 KV Line :-					
	Line Type					
	Length(Ckt. Kms.)		0	Railway/Highway Crossing etc		
	Proposed Distribution Transformer :-					
	Sl.No.	Distribution Transformer			Total No. of DT	
	1	10 KVA(1 Ph)			0	
	2	SDT-25 KVA			0	
	3	SDT-50 KVA			0	
	4	SDT-63 KVA			0	
	5	SDT-100 KVA			0	
	6	SDT-30 AMP			0	
	7	10 KVA(3 Ph)			0	
	8	16 KVA(3 Ph)			0	
	9	25 KVA(3 Ph)			9	
10	40 KVA(3 Ph)			0		
11	63 KVA(3 Ph)			0		
12	100 KVA(3 Ph)			0		
Total					9	
111	Palhna	KANDHARPUR	Kandharpur	225	Yes	
	New 11 KV or 22 KV Line :-					
	Line Type					

Works Proposed Under Feeder Separation

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of Block	Name of Emitting SubStation	Name of Feeder	Restricted demand after FS	Feeder Metering
	Length(Ckt. Kms.)	0	Railway/Highway Crossing etc		
Proposed Distribution Transformer :-					
	Sl.No.	Distribution Transformer			Total No. of DT
	1	10 KVA(1 Ph)			0
	2	SDT-25 KVA			0
	3	SDT-50 KVA			0
	4	SDT-63 KVA			0
	5	SDT-100 KVA			0
	6	SDT-30 AMP			0
	7	10 KVA(3 Ph)			0
	8	16 KVA(3 Ph)			0
	9	25 KVA(3 Ph)			13
	10	40 KVA(3 Ph)			0
	11	63 KVA(3 Ph)			0
	12	100 KVA(3 Ph)			0
	Total				13
112	Pawai	PAWAI	Mahul Feeder	Nil	No
New 11 KV or 22 KV Line :-					
	Line Type				
	Length(Ckt. Kms.)	0	Railway/Highway Crossing etc		
Proposed Distribution Transformer :-					
	Sl.No.	Distribution Transformer			Total No. of DT
	1	10 KVA(1 Ph)			0

Works Proposed Under Feeder Separation

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of Block	Name of Emitting SubStation	Name of Feeder	Restricted demand after FS	Feeder Metering
	2	SDT-25 KVA			0
	3	SDT-50 KVA			0
	4	SDT-63 KVA			0
	5	SDT-100 KVA			0
	6	SDT-30 AMP			0
	7	10 KVA(3 Ph)			0
	8	16 KVA(3 Ph)			0
	9	25 KVA(3 Ph)			32
	10	40 KVA(3 Ph)			0
	11	63 KVA(3 Ph)			0
	12	100 KVA(3 Ph)			0
	Total				32
113	Pawai	PAWAI	Belwai Feeder	Nil	No
	New 11 KV or 22 KV Line :-				
	Line Type				
	Length(Ckt. Kms.)	0	Railway/Highway Crossing etc		
	Proposed Distribution Transformer :-				
	Sl.No.	Distribution Transformer		Total No. of DT	
	1	10 KVA(1 Ph)		0	
	2	SDT-25 KVA		0	
	3	SDT-50 KVA		0	
	4	SDT-63 KVA		0	
	5	SDT-100 KVA		0	

Works Proposed Under Feeder Separation

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of Block	Name of Emitting SubStation	Name of Feeder	Restricted demand after FS	Feeder Metering
	6	SDT-30 AMP			0
	7	10 KVA(3 Ph)			0
	8	16 KVA(3 Ph)			0
	9	25 KVA(3 Ph)			28
	10	40 KVA(3 Ph)			0
	11	63 KVA(3 Ph)			0
	12	100 KVA(3 Ph)			0
	Total				28
114	Pawai	PAWAI	Balaipur Feeder	Nil	No
	New 11 KV or 22 KV Line :-				
	Line Type				
	Length(Ckt. Kms.)	0	Railway/Highway Crossing etc		
	Proposed Distribution Transformer :-				
	Sl.No.	Distribution Transformer		Total No. of DT	
	1	10 KVA(1 Ph)		0	
	2	SDT-25 KVA		0	
	3	SDT-50 KVA		0	
	4	SDT-63 KVA		0	
	5	SDT-100 KVA		0	
	6	SDT-30 AMP		0	
	7	10 KVA(3 Ph)		0	
	8	16 KVA(3 Ph)		0	
	9	25 KVA(3 Ph)		29	

Works Proposed Under Feeder Separation

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of Block	Name of Emitting SubStation	Name of Feeder	Restricted demand after FS	Feeder Metering
	10	40 KVA(3 Ph)			0
	11	63 KVA(3 Ph)			0
	12	100 KVA(3 Ph)			0
	Total				29
115	Pawai	PAWAI	Pawai	225	Yes
	New 11 KV or 22 KV Line :-				
	Line Type				
	Length(Ckt. Kms.)	0	Railway/Highway Crossing etc		
	Proposed Distribution Transformer :-				
	Sl.No.	Distribution Transformer		Total No. of DT	
	1	10 KVA(1 Ph)		0	
	2	SDT-25 KVA		0	
	3	SDT-50 KVA		0	
	4	SDT-63 KVA		0	
	5	SDT-100 KVA		0	
	6	SDT-30 AMP		0	
	7	10 KVA(3 Ph)		0	
	8	16 KVA(3 Ph)		0	
	9	25 KVA(3 Ph)		10	
	10	40 KVA(3 Ph)		0	
	11	63 KVA(3 Ph)		0	
	12	100 KVA(3 Ph)		0	
	Total				10

Works Proposed Under Feeder Separation

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of Block	Name of Emitting SubStation	Name of Feeder	Restricted demand after FS	Feeder Metering
116	Pawai	BAGH BAHAR	Kalan	Nil	No
New 11 KV or 22 KV Line :-					
Line Type					
Length(Ckt. Kms.)		0	Railway/Highway Crossing etc		
Proposed Distribution Transformer :-					
Sl.No.	Distribution Transformer			Total No. of DT	
1	10 KVA(1 Ph)			0	
2	SDT-25 KVA			0	
3	SDT-50 KVA			0	
4	SDT-63 KVA			0	
5	SDT-100 KVA			0	
6	SDT-30 AMP			0	
7	10 KVA(3 Ph)			0	
8	16 KVA(3 Ph)			0	
9	25 KVA(3 Ph)			13	
10	40 KVA(3 Ph)			0	
11	63 KVA(3 Ph)			0	
12	100 KVA(3 Ph)			0	
Total				13	
117	Pawai	BAGH BAHAR	Sahdulla	Nil	No
New 11 KV or 22 KV Line :-					
Line Type					
Length(Ckt. Kms.)		0	Railway/Highway Crossing etc		

Works Proposed Under Feeder Separation

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of Block	Name of Emitting SubStation	Name of Feeder	Restricted demand after FS	Feeder Metering
Proposed Distribution Transformer :-					
	Sl.No.	Distribution Transformer		Total No. of DT	
	1	10 KVA(1 Ph)		0	
	2	SDT-25 KVA		0	
	3	SDT-50 KVA		0	
	4	SDT-63 KVA		0	
	5	SDT-100 KVA		0	
	6	SDT-30 AMP		0	
	7	10 KVA(3 Ph)		0	
	8	16 KVA(3 Ph)		0	
	9	25 KVA(3 Ph)		19	
	10	40 KVA(3 Ph)		0	
	11	63 KVA(3 Ph)		0	
	12	100 KVA(3 Ph)		0	
	Total			19	
118	Pawai	BAGH BAHAR	Khairuddinpur	225	Yes
New 11 KV or 22 KV Line :-					
Line Type					
Length(Ckt. Kms.)		0	Railway/Highway Crossing etc		
Proposed Distribution Transformer :-					
	Sl.No.	Distribution Transformer		Total No. of DT	
	1	10 KVA(1 Ph)		0	
	2	SDT-25 KVA		0	

Works Proposed Under Feeder Separation

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of Block	Name of Eminating SubStation	Name of Feeder	Restricted demand after FS	Feeder Metering
	3	SDT-50 KVA			0
	4	SDT-63 KVA			0
	5	SDT-100 KVA			0
	6	SDT-30 AMP			0
	7	10 KVA(3 Ph)			0
	8	16 KVA(3 Ph)			0
	9	25 KVA(3 Ph)			11
	10	40 KVA(3 Ph)			0
	11	63 KVA(3 Ph)			0
	12	100 KVA(3 Ph)			0
	Total				11
119	Phulpur	PHOOLPUR	North	Nil	No
New 11 KV or 22 KV Line :-					
Line Type					
Length(Ckt. Kms.)					
		0	Railway/Highway Crossing etc		
Proposed Distribution Transformer :-					
	Sl.No.	Distribution Transformer		Total No. of DT	
	1	10 KVA(1 Ph)		0	
	2	SDT-25 KVA		0	
	3	SDT-50 KVA		0	
	4	SDT-63 KVA		0	
	5	SDT-100 KVA		0	
	6	SDT-30 AMP		0	

Works Proposed Under Feeder Separation

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of Block	Name of Emitting SubStation	Name of Feeder	Restricted demand after FS	Feeder Metering
	7	10 KVA(3 Ph)			0
	8	16 KVA(3 Ph)			0
	9	25 KVA(3 Ph)			20
	10	40 KVA(3 Ph)			0
	11	63 KVA(3 Ph)			0
	12	100 KVA(3 Ph)			0
	Total				20
120	Phulpur	PHOOLPUR	West	225	Yes
	New 11 KV or 22 KV Line :-				
	Line Type				
	Length(Ckt. Kms.)	0	Railway/Highway Crossing etc		
	Proposed Distribution Transformer :-				
	Sl.No.	Distribution Transformer			Total No. of DT
	1	10 KVA(1 Ph)			0
	2	SDT-25 KVA			0
	3	SDT-50 KVA			0
	4	SDT-63 KVA			0
	5	SDT-100 KVA			0
	6	SDT-30 AMP			0
	7	10 KVA(3 Ph)			0
	8	16 KVA(3 Ph)			0
	9	25 KVA(3 Ph)			23
	10	40 KVA(3 Ph)			0

Works Proposed Under Feeder Separation

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of Block	Name of Emitting SubStation	Name of Feeder	Restricted demand after FS	Feeder Metering
	11	63 KVA(3 Ph)			0
	12	100 KVA(3 Ph)			0
	Total				23
121	Phulpur	PHOOLPUR	East	225	Yes
	New 11 KV or 22 KV Line :-				
	Line Type				
	Length(Ckt. Kms.)	0	Railway/Highway Crossing etc		
	Proposed Distribution Transformer :-				
	Sl.No.	Distribution Transformer		Total No. of DT	
	1	10 KVA(1 Ph)		0	
	2	SDT-25 KVA		0	
	3	SDT-50 KVA		0	
	4	SDT-63 KVA		0	
	5	SDT-100 KVA		0	
	6	SDT-30 AMP		0	
	7	10 KVA(3 Ph)		0	
	8	16 KVA(3 Ph)		0	
	9	25 KVA(3 Ph)		10	
	10	40 KVA(3 Ph)		0	
	11	63 KVA(3 Ph)		0	
	12	100 KVA(3 Ph)		0	
	Total			10	
122	Phulpur	PHOOLPUR	South	Nil	No

Works Proposed Under Feeder Separation

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of Block	Name of Emitting SubStation	Name of Feeder	Restricted demand after FS	Feeder Metering
	New 11 KV or 22 KV Line :-				
	Line Type				
	Length(Ckt. Kms.)	0	Railway/Highway Crossing etc		
	Proposed Distribution Transformer :-				
	Sl.No.	Distribution Transformer		Total No. of DT	
	1	10 KVA(1 Ph)		0	
	2	SDT-25 KVA		0	
	3	SDT-50 KVA		0	
	4	SDT-63 KVA		0	
	5	SDT-100 KVA		0	
	6	SDT-30 AMP		0	
	7	10 KVA(3 Ph)		0	
	8	16 KVA(3 Ph)		0	
	9	25 KVA(3 Ph)		11	
	10	40 KVA(3 Ph)		0	
	11	63 KVA(3 Ph)		0	
	12	100 KVA(3 Ph)		0	
	Total			11	
123	Phulpur	GADDO PUR	Palthi	Nil	No
	New 11 KV or 22 KV Line :-				
	Line Type				
	Length(Ckt. Kms.)	0	Railway/Highway Crossing etc		
	Proposed Distribution Transformer :-				

Works Proposed Under Feeder Separation

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of Block	Name of Emitting SubStation	Name of Feeder	Restricted demand after FS	Feeder Metering
	Sl.No.	Distribution Transformer		Total No. of DT	
	1	10 KVA(1 Ph)		0	
	2	SDT-25 KVA		0	
	3	SDT-50 KVA		0	
	4	SDT-63 KVA		0	
	5	SDT-100 KVA		0	
	6	SDT-30 AMP		0	
	7	10 KVA(3 Ph)		0	
	8	16 KVA(3 Ph)		0	
	9	25 KVA(3 Ph)		20	
	10	40 KVA(3 Ph)		0	
	11	63 KVA(3 Ph)		0	
	12	100 KVA(3 Ph)		0	
	Total			20	
124	Phulpur	GADDO PUR	Gaddo Pur	225	Yes
	New 11 KV or 22 KV Line :-				
	Line Type				
	Length(Ckt. Kms.)	0	Railway/Highway Crossing etc		
	Proposed Distribution Transformer :-				
	Sl.No.	Distribution Transformer		Total No. of DT	
	1	10 KVA(1 Ph)		0	
	2	SDT-25 KVA		0	
	3	SDT-50 KVA		0	

Works Proposed Under Feeder Separation

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of Block	Name of Emitting SubStation	Name of Feeder	Restricted demand after FS	Feeder Metering
	4	SDT-63 KVA			0
	5	SDT-100 KVA			0
	6	SDT-30 AMP			0
	7	10 KVA(3 Ph)			0
	8	16 KVA(3 Ph)			0
	9	25 KVA(3 Ph)			20
	10	40 KVA(3 Ph)			0
	11	63 KVA(3 Ph)			0
	12	100 KVA(3 Ph)			0
	Total				20
125	Phulpur	PUSHP NAGAR	Deedarganj	225	Yes
	New 11 KV or 22 KV Line :-				
	Line Type				
	Length(Ckt. Kms.)	0	Railway/Highway Crossing etc		
	Proposed Distribution Transformer :-				
	Sl.No.	Distribution Transformer		Total No. of DT	
	1	10 KVA(1 Ph)		0	
	2	SDT-25 KVA		0	
	3	SDT-50 KVA		0	
	4	SDT-63 KVA		0	
	5	SDT-100 KVA		0	
	6	SDT-30 AMP		0	
	7	10 KVA(3 Ph)		0	

Works Proposed Under Feeder Separation

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of Block	Name of Emitting SubStation	Name of Feeder	Restricted demand after FS	Feeder Metering
	8	16 KVA(3 Ph)			0
	9	25 KVA(3 Ph)			16
	10	40 KVA(3 Ph)			0
	11	63 KVA(3 Ph)			0
	12	100 KVA(3 Ph)			0
	Total				16
126	Phulpur	PUSHP NAGAR	Sikraura	Nil	No
New 11 KV or 22 KV Line :-					
Line Type					
Length(Ckt. Kms.)					
		0	Railway/Highway Crossing etc		
Proposed Distribution Transformer :-					
Sl.No.	Distribution Transformer			Total No. of DT	
1	10 KVA(1 Ph)			0	
2	SDT-25 KVA			0	
3	SDT-50 KVA			0	
4	SDT-63 KVA			0	
5	SDT-100 KVA			0	
6	SDT-30 AMP			0	
7	10 KVA(3 Ph)			0	
8	16 KVA(3 Ph)			0	
9	25 KVA(3 Ph)			14	
10	40 KVA(3 Ph)			0	
11	63 KVA(3 Ph)			0	

Works Proposed Under Feeder Separation

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of Block	Name of Emitting SubStation	Name of Feeder	Restricted demand after FS	Feeder Metering
	12	100 KVA(3 Ph)			0
	Total				14
127	Rani Ki Sarai	RANI KI SARAI	Rani ki sarai	225	Yes
	New 11 KV or 22 KV Line :-				
	Line Type				
	Length(Ckt. Kms.)	0	Railway/Highway Crossing etc		
	Proposed Distribution Transformer :-				
	Sl.No.	Distribution Transformer			Total No. of DT
	1	10 KVA(1 Ph)			0
	2	SDT-25 KVA			0
	3	SDT-50 KVA			0
	4	SDT-63 KVA			0
	5	SDT-100 KVA			0
	6	SDT-30 AMP			0
	7	10 KVA(3 Ph)			0
	8	16 KVA(3 Ph)			0
	9	25 KVA(3 Ph)			14
	10	40 KVA(3 Ph)			0
	11	63 KVA(3 Ph)			0
	12	100 KVA(3 Ph)			0
	Total				14
128	Rani Ki Sarai	RANI KI SARAI	Sonwara	Nil	No
	New 11 KV or 22 KV Line :-				

Works Proposed Under Feeder Separation

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of Block	Name of Emitting SubStation	Name of Feeder	Restricted demand after FS	Feeder Metering
	Line Type				
	Length(Ckt. Kms.)	0	Railway/Highway Crossing etc		
Proposed Distribution Transformer :-					
	Sl.No.	Distribution Transformer		Total No. of DT	
	1	10 KVA(1 Ph)		0	
	2	SDT-25 KVA		0	
	3	SDT-50 KVA		0	
	4	SDT-63 KVA		0	
	5	SDT-100 KVA		0	
	6	SDT-30 AMP		0	
	7	10 KVA(3 Ph)		0	
	8	16 KVA(3 Ph)		0	
	9	25 KVA(3 Ph)		17	
	10	40 KVA(3 Ph)		0	
	11	63 KVA(3 Ph)		0	
	12	100 KVA(3 Ph)		0	
	Total				17
129	Rani Ki Sarai	RANI KI SARAI	Vasti	225	Yes
New 11 KV or 22 KV Line :-					
	Line Type				
	Length(Ckt. Kms.)	0	Railway/Highway Crossing etc		
Proposed Distribution Transformer :-					
	Sl.No.	Distribution Transformer		Total No. of DT	

Works Proposed Under Feeder Separation

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of Block	Name of Emitting SubStation	Name of Feeder	Restricted demand after FS	Feeder Metering
	1	10 KVA(1 Ph)			0
	2	SDT-25 KVA			0
	3	SDT-50 KVA			0
	4	SDT-63 KVA			0
	5	SDT-100 KVA			0
	6	SDT-30 AMP			0
	7	10 KVA(3 Ph)			0
	8	16 KVA(3 Ph)			0
	9	25 KVA(3 Ph)			11
	10	40 KVA(3 Ph)			0
	11	63 KVA(3 Ph)			0
	12	100 KVA(3 Ph)			0
	Total				11
130	Sathiyaon	MOHABBATPUR	Shahgarh	225	Yes
	New 11 KV or 22 KV Line :-				
	Line Type				
	Length(Ckt. Kms.)	0	Railway/Highway Crossing etc		
	Proposed Distribution Transformer :-				
	Sl.No.	Distribution Transformer		Total No. of DT	
	1	10 KVA(1 Ph)		0	
	2	SDT-25 KVA		0	
	3	SDT-50 KVA		0	
	4	SDT-63 KVA		0	

Works Proposed Under Feeder Separation

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of Block	Name of Emitting SubStation	Name of Feeder	Restricted demand after FS	Feeder Metering
	5	SDT-100 KVA			0
	6	SDT-30 AMP			0
	7	10 KVA(3 Ph)			0
	8	16 KVA(3 Ph)			0
	9	25 KVA(3 Ph)			14
	10	40 KVA(3 Ph)			0
	11	63 KVA(3 Ph)			0
	12	100 KVA(3 Ph)			0
	Total				14
131	Sathiyaon	MOHABBATPUR	Bamhaur	225	Yes
	New 11 KV or 22 KV Line :-				
	Line Type				
	Length(Ckt. Kms.)	0	Railway/Highway Crossing etc		
	Proposed Distribution Transformer :-				
	Sl.No.	Distribution Transformer		Total No. of DT	
	1	10 KVA(1 Ph)		0	
	2	SDT-25 KVA		0	
	3	SDT-50 KVA		0	
	4	SDT-63 KVA		0	
	5	SDT-100 KVA		0	
	6	SDT-30 AMP		0	
	7	10 KVA(3 Ph)		0	
	8	16 KVA(3 Ph)		0	

Works Proposed Under Feeder Separation

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of Block	Name of Emitting SubStation	Name of Feeder	Restricted demand after FS	Feeder Metering
	9	25 KVA(3 Ph)			18
	10	40 KVA(3 Ph)			0
	11	63 KVA(3 Ph)			0
	12	100 KVA(3 Ph)			0
	Total				18
132	Sathiyaon	MUBARAKPUR	Newada Rural	225	Yes
New 11 KV or 22 KV Line :-					
Line Type					
Length(Ckt. Kms.)					
		0	Railway/Highway Crossing etc		
Proposed Distribution Transformer :-					
	Sl.No.	Distribution Transformer		Total No. of DT	
	1	10 KVA(1 Ph)		0	
	2	SDT-25 KVA		0	
	3	SDT-50 KVA		0	
	4	SDT-63 KVA		0	
	5	SDT-100 KVA		0	
	6	SDT-30 AMP		0	
	7	10 KVA(3 Ph)		0	
	8	16 KVA(3 Ph)		0	
	9	25 KVA(3 Ph)		23	
	10	40 KVA(3 Ph)		0	
	11	63 KVA(3 Ph)		0	
	12	100 KVA(3 Ph)		0	

Works Proposed Under Feeder Separation

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of Block	Name of Emitting SubStation	Name of Feeder	Restricted demand after FS	Feeder Metering	
Total					23	
133	Sathiyaon	MUBARAKPUR	Sthiyaon	225	Yes	
	New 11 KV or 22 KV Line :-					
	Line Type					
	Length(Ckt. Kms.)		0	Railway/Highway Crossing etc		
	Proposed Distribution Transformer :-					
	Sl.No.	Distribution Transformer			Total No. of DT	
	1	10 KVA(1 Ph)			0	
	2	SDT-25 KVA			0	
	3	SDT-50 KVA			0	
	4	SDT-63 KVA			0	
	5	SDT-100 KVA			0	
	6	SDT-30 AMP			0	
	7	10 KVA(3 Ph)			0	
	8	16 KVA(3 Ph)			0	
9	25 KVA(3 Ph)			18		
10	40 KVA(3 Ph)			0		
11	63 KVA(3 Ph)			0		
12	100 KVA(3 Ph)			0		
Total					18	
134	Tahbarpur	SOFIPUR	Nizamabad	Nil	No	
	New 11 KV or 22 KV Line :-					
Line Type						

Works Proposed Under Feeder Separation

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of Block	Name of Emitting SubStation	Name of Feeder	Restricted demand after FS	Feeder Metering
	Length(Ckt. Kms.)	0	Railway/Highway Crossing etc		
Proposed Distribution Transformer :-					
	Sl.No.	Distribution Transformer			Total No. of DT
	1	10 KVA(1 Ph)			0
	2	SDT-25 KVA			0
	3	SDT-50 KVA			0
	4	SDT-63 KVA			0
	5	SDT-100 KVA			0
	6	SDT-30 AMP			0
	7	10 KVA(3 Ph)			0
	8	16 KVA(3 Ph)			0
	9	25 KVA(3 Ph)			16
	10	40 KVA(3 Ph)			0
	11	63 KVA(3 Ph)			0
	12	100 KVA(3 Ph)			0
		Total			16
135	Tahbarpur	SOFIPUR	Semari	225	Yes
New 11 KV or 22 KV Line :-					
	Line Type				
	Length(Ckt. Kms.)	0	Railway/Highway Crossing etc		
Proposed Distribution Transformer :-					
	Sl.No.	Distribution Transformer			Total No. of DT
	1	10 KVA(1 Ph)			0

Works Proposed Under Feeder Separation

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of Block	Name of Emitting SubStation	Name of Feeder	Restricted demand after FS	Feeder Metering
	2	SDT-25 KVA			0
	3	SDT-50 KVA			0
	4	SDT-63 KVA			0
	5	SDT-100 KVA			0
	6	SDT-30 AMP			0
	7	10 KVA(3 Ph)			0
	8	16 KVA(3 Ph)			0
	9	25 KVA(3 Ph)			5
	10	40 KVA(3 Ph)			0
	11	63 KVA(3 Ph)			0
	12	100 KVA(3 Ph)			0
	Total				5
136	Tahbarpur	SOFIPUR	Nizamabad 2	Nil	No
	New 11 KV or 22 KV Line :-				
	Line Type				
	Length(Ckt. Kms.)	0	Railway/Highway Crossing etc		
	Proposed Distribution Transformer :-				
	Sl.No.	Distribution Transformer		Total No. of DT	
	1	10 KVA(1 Ph)		0	
	2	SDT-25 KVA		0	
	3	SDT-50 KVA		0	
	4	SDT-63 KVA		0	
	5	SDT-100 KVA		0	

Works Proposed Under Feeder Separation

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of Block	Name of Emitting SubStation	Name of Feeder	Restricted demand after FS	Feeder Metering
	6	SDT-30 AMP			0
	7	10 KVA(3 Ph)			0
	8	16 KVA(3 Ph)			0
	9	25 KVA(3 Ph)			29
	10	40 KVA(3 Ph)			0
	11	63 KVA(3 Ph)			0
	12	100 KVA(3 Ph)			0
	Total				29
137	Tahbarpur	SOFIPUR	Tahbarpur	Nil	No
	New 11 KV or 22 KV Line :-				
	Line Type				
	Length(Ckt. Kms.)	0	Railway/Highway Crossing etc		
	Proposed Distribution Transformer :-				
	Sl.No.	Distribution Transformer		Total No. of DT	
	1	10 KVA(1 Ph)		0	
	2	SDT-25 KVA		0	
	3	SDT-50 KVA		0	
	4	SDT-63 KVA		0	
	5	SDT-100 KVA		0	
	6	SDT-30 AMP		0	
	7	10 KVA(3 Ph)		0	
	8	16 KVA(3 Ph)		0	
	9	25 KVA(3 Ph)		23	

Works Proposed Under Feeder Separation

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of Block	Name of Emitting SubStation	Name of Feeder	Restricted demand after FS	Feeder Metering
	10	40 KVA(3 Ph)			0
	11	63 KVA(3 Ph)			0
	12	100 KVA(3 Ph)			0
	Total				23
138	Tahbarpur	ORA	Ora	Nil	No
	New 11 KV or 22 KV Line :-				
	Line Type				
	Length(Ckt. Kms.)	0	Railway/Highway Crossing etc		
	Proposed Distribution Transformer :-				
	Sl.No.	Distribution Transformer		Total No. of DT	
	1	10 KVA(1 Ph)		0	
	2	SDT-25 KVA		0	
	3	SDT-50 KVA		0	
	4	SDT-63 KVA		0	
	5	SDT-100 KVA		0	
	6	SDT-30 AMP		0	
	7	10 KVA(3 Ph)		0	
	8	16 KVA(3 Ph)		0	
	9	25 KVA(3 Ph)		6	
	10	40 KVA(3 Ph)		0	
	11	63 KVA(3 Ph)		0	
	12	100 KVA(3 Ph)		0	
	Total				6

Works Proposed Under Feeder Separation

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of Block	Name of Emitting SubStation	Name of Feeder	Restricted demand after FS	Feeder Metering
139	Tahbarpur	ORA	Deohatta	225	Yes
New 11 KV or 22 KV Line :-					
Line Type					
Length(Ckt. Kms.)		0	Railway/Highway Crossing etc		
Proposed Distribution Transformer :-					
Sl.No.	Distribution Transformer			Total No. of DT	
1	10 KVA(1 Ph)			0	
2	SDT-25 KVA			0	
3	SDT-50 KVA			0	
4	SDT-63 KVA			0	
5	SDT-100 KVA			0	
6	SDT-30 AMP			0	
7	10 KVA(3 Ph)			0	
8	16 KVA(3 Ph)			0	
9	25 KVA(3 Ph)			5	
10	40 KVA(3 Ph)			0	
11	63 KVA(3 Ph)			0	
12	100 KVA(3 Ph)			0	
Total				5	
140	Tahbarpur	ORA	Sarai Barkat	Nil	No
New 11 KV or 22 KV Line :-					
Line Type					
Length(Ckt. Kms.)		0	Railway/Highway Crossing etc		

Works Proposed Under Feeder Separation

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of Block	Name of Emitting SubStation	Name of Feeder	Restricted demand after FS	Feeder Metering
Proposed Distribution Transformer :-					
	Sl.No.	Distribution Transformer		Total No. of DT	
	1	10 KVA(1 Ph)		0	
	2	SDT-25 KVA		0	
	3	SDT-50 KVA		0	
	4	SDT-63 KVA		0	
	5	SDT-100 KVA		0	
	6	SDT-30 AMP		0	
	7	10 KVA(3 Ph)		0	
	8	16 KVA(3 Ph)		0	
	9	25 KVA(3 Ph)		6	
	10	40 KVA(3 Ph)		0	
	11	63 KVA(3 Ph)		0	
	12	100 KVA(3 Ph)		0	
	Total			6	
141	Tahbarpur	MANJHARI	Dhania kundi	Nil	No
New 11 KV or 22 KV Line :-					
	Line Type				
	Length(Ckt. Kms.)	0	Railway/Highway Crossing etc		
Proposed Distribution Transformer :-					
	Sl.No.	Distribution Transformer		Total No. of DT	
	1	10 KVA(1 Ph)		0	
	2	SDT-25 KVA		0	

Works Proposed Under Feeder Separation

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of Block	Name of Emitting SubStation	Name of Feeder	Restricted demand after FS	Feeder Metering
	3	SDT-50 KVA			0
	4	SDT-63 KVA			0
	5	SDT-100 KVA			0
	6	SDT-30 AMP			0
	7	10 KVA(3 Ph)			0
	8	16 KVA(3 Ph)			0
	9	25 KVA(3 Ph)			5
	10	40 KVA(3 Ph)			0
	11	63 KVA(3 Ph)			0
	12	100 KVA(3 Ph)			0
	Total				5
142	Tahbarpur	MANJHARI	Manjhari	Nil	No
New 11 KV or 22 KV Line :-					
Line Type					
Length(Ckt. Kms.)					
		0	Railway/Highway Crossing etc		
Proposed Distribution Transformer :-					
	Sl.No.	Distribution Transformer		Total No. of DT	
	1	10 KVA(1 Ph)		0	
	2	SDT-25 KVA		0	
	3	SDT-50 KVA		0	
	4	SDT-63 KVA		0	
	5	SDT-100 KVA		0	
	6	SDT-30 AMP		0	

Works Proposed Under Feeder Separation

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of Block	Name of Emitting SubStation	Name of Feeder	Restricted demand after FS	Feeder Metering
	7	10 KVA(3 Ph)			0
	8	16 KVA(3 Ph)			0
	9	25 KVA(3 Ph)			5
	10	40 KVA(3 Ph)			0
	11	63 KVA(3 Ph)			0
	12	100 KVA(3 Ph)			0
	Total				5
143	Tahbarpur	MANJHARI	Kariawar	225	Yes
	New 11 KV or 22 KV Line :-				
	Line Type				
	Length(Ckt. Kms.)	0	Railway/Highway Crossing etc		
	Proposed Distribution Transformer :-				
	Sl.No.	Distribution Transformer		Total No. of DT	
	1	10 KVA(1 Ph)		0	
	2	SDT-25 KVA		0	
	3	SDT-50 KVA		0	
	4	SDT-63 KVA		0	
	5	SDT-100 KVA		0	
	6	SDT-30 AMP		0	
	7	10 KVA(3 Ph)		0	
	8	16 KVA(3 Ph)		0	
	9	25 KVA(3 Ph)		8	
	10	40 KVA(3 Ph)		0	

Works Proposed Under Feeder Separation

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of Block	Name of Emitting SubStation	Name of Feeder	Restricted demand after FS	Feeder Metering
	11	63 KVA(3 Ph)			0
	12	100 KVA(3 Ph)			0
	Total				8
144	Tarwa	RASEPUR	Kanchanpur	Nil	No
	New 11 KV or 22 KV Line :-				
	Line Type				
	Length(Ckt. Kms.)	0	Railway/Highway Crossing etc		
	Proposed Distribution Transformer :-				
	Sl.No.	Distribution Transformer		Total No. of DT	
	1	10 KVA(1 Ph)		0	
	2	SDT-25 KVA		0	
	3	SDT-50 KVA		0	
	4	SDT-63 KVA		0	
	5	SDT-100 KVA		0	
	6	SDT-30 AMP		0	
	7	10 KVA(3 Ph)		0	
	8	16 KVA(3 Ph)		0	
	9	25 KVA(3 Ph)		27	
	10	40 KVA(3 Ph)		0	
	11	63 KVA(3 Ph)		0	
	12	100 KVA(3 Ph)		0	
	Total				27
145	Tarwa	RASEPUR	Sherpur	Nil	No

Works Proposed Under Feeder Separation

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of Block	Name of Emitting SubStation	Name of Feeder	Restricted demand after FS	Feeder Metering
	New 11 KV or 22 KV Line :-				
	Line Type				
	Length(Ckt. Kms.)	0	Railway/Highway Crossing etc		
	Proposed Distribution Transformer :-				
	Sl.No.	Distribution Transformer		Total No. of DT	
	1	10 KVA(1 Ph)		0	
	2	SDT-25 KVA		0	
	3	SDT-50 KVA		0	
	4	SDT-63 KVA		0	
	5	SDT-100 KVA		0	
	6	SDT-30 AMP		0	
	7	10 KVA(3 Ph)		0	
	8	16 KVA(3 Ph)		0	
	9	25 KVA(3 Ph)		22	
	10	40 KVA(3 Ph)		0	
	11	63 KVA(3 Ph)		0	
	12	100 KVA(3 Ph)		0	
	Total			22	
146	Tarwa	RASEPUR	Bongariya	225	Yes
	New 11 KV or 22 KV Line :-				
	Line Type				
	Length(Ckt. Kms.)	0	Railway/Highway Crossing etc		
	Proposed Distribution Transformer :-				

Works Proposed Under Feeder Separation

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of Block	Name of Emitting SubStation	Name of Feeder	Restricted demand after FS	Feeder Metering
	Sl.No.	Distribution Transformer		Total No. of DT	
	1	10 KVA(1 Ph)		0	
	2	SDT-25 KVA		0	
	3	SDT-50 KVA		0	
	4	SDT-63 KVA		0	
	5	SDT-100 KVA		0	
	6	SDT-30 AMP		0	
	7	10 KVA(3 Ph)		0	
	8	16 KVA(3 Ph)		0	
	9	25 KVA(3 Ph)		17	
	10	40 KVA(3 Ph)		0	
	11	63 KVA(3 Ph)		0	
	12	100 KVA(3 Ph)		0	
	Total			17	
147	Tarwa	TARWA	Sidhauna	Nil	No
	New 11 KV or 22 KV Line :-				
	Line Type				
	Length(Ckt. Kms.)	0	Railway/Highway Crossing etc		
	Proposed Distribution Transformer :-				
	Sl.No.	Distribution Transformer		Total No. of DT	
	1	10 KVA(1 Ph)		0	
	2	SDT-25 KVA		0	
	3	SDT-50 KVA		0	

Works Proposed Under Feeder Separation

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of Block	Name of Emitting SubStation	Name of Feeder	Restricted demand after FS	Feeder Metering
	4	SDT-63 KVA			0
	5	SDT-100 KVA			0
	6	SDT-30 AMP			0
	7	10 KVA(3 Ph)			0
	8	16 KVA(3 Ph)			0
	9	25 KVA(3 Ph)			14
	10	40 KVA(3 Ph)			0
	11	63 KVA(3 Ph)			0
	12	100 KVA(3 Ph)			0
	Total				14
148	Tarwa	TARWA	Meh Nagar	Nil	No
	New 11 KV or 22 KV Line :-				
	Line Type				
	Length(Ckt. Kms.)	0	Railway/Highway Crossing etc		
	Proposed Distribution Transformer :-				
	Sl.No.	Distribution Transformer		Total No. of DT	
	1	10 KVA(1 Ph)		0	
	2	SDT-25 KVA		0	
	3	SDT-50 KVA		0	
	4	SDT-63 KVA		0	
	5	SDT-100 KVA		0	
	6	SDT-30 AMP		0	
	7	10 KVA(3 Ph)		0	

Works Proposed Under Feeder Separation

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of Block	Name of Emitting SubStation	Name of Feeder	Restricted demand after FS	Feeder Metering
	8	16 KVA(3 Ph)			0
	9	25 KVA(3 Ph)			12
	10	40 KVA(3 Ph)			0
	11	63 KVA(3 Ph)			0
	12	100 KVA(3 Ph)			0
	Total				12
149	Tarwa	TARWA	Mehnajpur	225	Yes
New 11 KV or 22 KV Line :-					
Line Type					
Length(Ckt. Kms.)					
		0	Railway/Highway Crossing etc		
Proposed Distribution Transformer :-					
Sl.No.	Distribution Transformer			Total No. of DT	
1	10 KVA(1 Ph)			0	
2	SDT-25 KVA			0	
3	SDT-50 KVA			0	
4	SDT-63 KVA			0	
5	SDT-100 KVA			0	
6	SDT-30 AMP			0	
7	10 KVA(3 Ph)			0	
8	16 KVA(3 Ph)			0	
9	25 KVA(3 Ph)			14	
10	40 KVA(3 Ph)			0	
11	63 KVA(3 Ph)			0	

Works Proposed Under Feeder Separation

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of Block	Name of Emitting SubStation	Name of Feeder	Restricted demand after FS	Feeder Metering
	12	100 KVA(3 Ph)			0
	Total				14
150	Tarwa	MEHNAJPUR	Nath PUR	Nil	No
	New 11 KV or 22 KV Line :-				
	Line Type				
	Length(Ckt. Kms.)	0	Railway/Highway Crossing etc		
	Proposed Distribution Transformer :-				
	Sl.No.	Distribution Transformer		Total No. of DT	
	1	10 KVA(1 Ph)		0	
	2	SDT-25 KVA		0	
	3	SDT-50 KVA		0	
	4	SDT-63 KVA		0	
	5	SDT-100 KVA		0	
	6	SDT-30 AMP		0	
	7	10 KVA(3 Ph)		0	
	8	16 KVA(3 Ph)		0	
	9	25 KVA(3 Ph)		21	
	10	40 KVA(3 Ph)		0	
	11	63 KVA(3 Ph)		0	
	12	100 KVA(3 Ph)		0	
	Total				21
151	Tarwa	MEHNAJPUR	Rowa para	Nil	No
	New 11 KV or 22 KV Line :-				

Works Proposed Under Feeder Separation

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of Block	Name of Emitting SubStation	Name of Feeder	Restricted demand after FS	Feeder Metering
	Line Type				
	Length(Ckt. Kms.)	0	Railway/Highway Crossing etc		
Proposed Distribution Transformer :-					
	Sl.No.	Distribution Transformer		Total No. of DT	
	1	10 KVA(1 Ph)		0	
	2	SDT-25 KVA		0	
	3	SDT-50 KVA		0	
	4	SDT-63 KVA		0	
	5	SDT-100 KVA		0	
	6	SDT-30 AMP		0	
	7	10 KVA(3 Ph)		0	
	8	16 KVA(3 Ph)		0	
	9	25 KVA(3 Ph)		21	
	10	40 KVA(3 Ph)		0	
	11	63 KVA(3 Ph)		0	
	12	100 KVA(3 Ph)		0	
	Total			21	
152	Tarwa	MEHNAJPUR	Mehnaj Pur	225	Yes
New 11 KV or 22 KV Line :-					
	Line Type				
	Length(Ckt. Kms.)	0	Railway/Highway Crossing etc		
Proposed Distribution Transformer :-					
	Sl.No.	Distribution Transformer		Total No. of DT	

Works Proposed Under Feeder Separation

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of Block	Name of Emitting SubStation	Name of Feeder	Restricted demand after FS	Feeder Metering
	1	10 KVA(1 Ph)			0
	2	SDT-25 KVA			0
	3	SDT-50 KVA			0
	4	SDT-63 KVA			0
	5	SDT-100 KVA			0
	6	SDT-30 AMP			0
	7	10 KVA(3 Ph)			0
	8	16 KVA(3 Ph)			0
	9	25 KVA(3 Ph)			14
	10	40 KVA(3 Ph)			0
	11	63 KVA(3 Ph)			0
	12	100 KVA(3 Ph)			0
	Total				14
153	Thekma	BARDAH	Bardah	Nil	No
	New 11 KV or 22 KV Line :-				
	Line Type				
	Length(Ckt. Kms.)	0	Railway/Highway Crossing etc		
	Proposed Distribution Transformer :-				
	Sl.No.	Distribution Transformer		Total No. of DT	
	1	10 KVA(1 Ph)		0	
	2	SDT-25 KVA		0	
	3	SDT-50 KVA		0	
	4	SDT-63 KVA		0	

Works Proposed Under Feeder Separation

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of Block	Name of Emitting SubStation	Name of Feeder	Restricted demand after FS	Feeder Metering
	5	SDT-100 KVA			0
	6	SDT-30 AMP			0
	7	10 KVA(3 Ph)			0
	8	16 KVA(3 Ph)			0
	9	25 KVA(3 Ph)			22
	10	40 KVA(3 Ph)			0
	11	63 KVA(3 Ph)			0
	12	100 KVA(3 Ph)			0
	Total				22
154	Thekma	BARDAH	Bahadurpur	225	Yes
	New 11 KV or 22 KV Line :-				
	Line Type				
	Length(Ckt. Kms.)	0	Railway/Highway Crossing etc		
	Proposed Distribution Transformer :-				
	Sl.No.	Distribution Transformer		Total No. of DT	
	1	10 KVA(1 Ph)		0	
	2	SDT-25 KVA		0	
	3	SDT-50 KVA		0	
	4	SDT-63 KVA		0	
	5	SDT-100 KVA		0	
	6	SDT-30 AMP		0	
	7	10 KVA(3 Ph)		0	
	8	16 KVA(3 Ph)		0	

Works Proposed Under Feeder Separation

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of Block	Name of Emitting SubStation	Name of Feeder	Restricted demand after FS	Feeder Metering
	9	25 KVA(3 Ph)			19
	10	40 KVA(3 Ph)			0
	11	63 KVA(3 Ph)			0
	12	100 KVA(3 Ph)			0
	Total				19
155	Thekma	BARDAH	Jiblee	Nil	No
	New 11 KV or 22 KV Line :-				
	Line Type				
	Length(Ckt. Kms.)	0	Railway/Highway Crossing etc		
	Proposed Distribution Transformer :-				
	Sl.No.	Distribution Transformer		Total No. of DT	
	1	10 KVA(1 Ph)		0	
	2	SDT-25 KVA		0	
	3	SDT-50 KVA		0	
	4	SDT-63 KVA		0	
	5	SDT-100 KVA		0	
	6	SDT-30 AMP		0	
	7	10 KVA(3 Ph)		0	
	8	16 KVA(3 Ph)		0	
	9	25 KVA(3 Ph)		14	
	10	40 KVA(3 Ph)		0	
	11	63 KVA(3 Ph)		0	
	12	100 KVA(3 Ph)		0	

Works Proposed Under Feeder Separation

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of Block	Name of Emitting SubStation	Name of Feeder	Restricted demand after FS	Feeder Metering	
Total					14	
156	Thekma	THEKMA	Tahbarpur	225	Yes	
	New 11 KV or 22 KV Line :-					
	Line Type					
	Length(Ckt. Kms.)		0	Railway/Highway Crossing etc		
	Proposed Distribution Transformer :-					
	Sl.No.	Distribution Transformer			Total No. of DT	
	1	10 KVA(1 Ph)			0	
	2	SDT-25 KVA			0	
	3	SDT-50 KVA			0	
	4	SDT-63 KVA			0	
	5	SDT-100 KVA			0	
	6	SDT-30 AMP			0	
	7	10 KVA(3 Ph)			0	
	8	16 KVA(3 Ph)			0	
9	25 KVA(3 Ph)			22		
10	40 KVA(3 Ph)			0		
11	63 KVA(3 Ph)			0		
12	100 KVA(3 Ph)			0		
Total					22	
157	Thekma	THEKMA	Sarai Mohan	Nil	No	
	New 11 KV or 22 KV Line :-					
Line Type						

Works Proposed Under Feeder Separation

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of Block	Name of Emitting SubStation	Name of Feeder	Restricted demand after FS	Feeder Metering
	Length(Ckt. Kms.)	0	Railway/Highway Crossing etc		
Proposed Distribution Transformer :-					
	Sl.No.	Distribution Transformer			Total No. of DT
	1	10 KVA(1 Ph)			0
	2	SDT-25 KVA			0
	3	SDT-50 KVA			0
	4	SDT-63 KVA			0
	5	SDT-100 KVA			0
	6	SDT-30 AMP			0
	7	10 KVA(3 Ph)			0
	8	16 KVA(3 Ph)			0
	9	25 KVA(3 Ph)			17
	10	40 KVA(3 Ph)			0
	11	63 KVA(3 Ph)			0
	12	100 KVA(3 Ph)			0
		Total			17
158	Thekma	THEKMA	Thekma	Nil	No
New 11 KV or 22 KV Line :-					
	Line Type				
	Length(Ckt. Kms.)	0	Railway/Highway Crossing etc		
Proposed Distribution Transformer :-					
	Sl.No.	Distribution Transformer			Total No. of DT
	1	10 KVA(1 Ph)			0

Works Proposed Under Feeder Separation

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of Block	Name of Eminating SubStation	Name of Feeder	Restricted demand after FS	Feeder Metering
	2	SDT-25 KVA			0
	3	SDT-50 KVA			0
	4	SDT-63 KVA			0
	5	SDT-100 KVA			0
	6	SDT-30 AMP			0
	7	10 KVA(3 Ph)			0
	8	16 KVA(3 Ph)			0
	9	25 KVA(3 Ph)			21
	10	40 KVA(3 Ph)			0
	11	63 KVA(3 Ph)			0
	12	100 KVA(3 Ph)			0
	Total				21

Connecting unconnected RHHs

State : UTTAR PRADESH

District : Azamgarh

Block-wise coverage of villages

State : UTTAR PRADESH
District : Azamgarh

S.No.	Name of Block	Total no. of villages as per census	Villages proposed under present scheme	Habitations proposed under present scheme	Total RHhs (Incl. BPL Hhs)	No of RHhs already electrified upto 31.03.15	% Electrification as on 31.03.15	RHhs(Incl. BPL) Already sanctioned and under execution in erstwhile RGGVY/State/ other schemes	Balance to be electrified	RHhs Proposed under present scheme	BPL Proposed under present scheme
1	2	3	4	5	6	7	8	9	10	11	12
1	Ahiraula	218	4	4	300	147	49	0	153	153	9
2	Atraulia	173	5	5	346	169	48.84	0	177	177	10
3	Azmatgarh	292	7	7	487	238	48.87	0	249	249	12
4	Bilariyaganj	233	4	4	341	168	49.27	0	173	173	10
5	Haraiya	190	6	6	500	180	36	0	320	320	14
6	Jahanaganj	211	15	17	4122	1928	46.77	0	2194	2194	119
7	Koilsa	162	8	8	883	432	48.92	0	451	451	24
8	Lalganj	219	6	9	1879	634	33.74	0	1245	1245	58
9	Mahrajganj	258	7	7	450	220	48.89	0	230	230	12
10	Martinganj	104	14	15	1245	608	48.84	0	637	637	38
11	Mehnagar	155	10	12	739	288	38.97	0	451	451	21
12	Mirzapur	192	12	13	1868	916	49.04	0	952	952	54
13	Mohammadpur	147	5	5	413	203	49.15	0	210	210	12
14	Palhani	182	4	4	500	244	48.8	0	256	256	14
15	Palhna	92	14	17	2392	1173	49.04	0	1219	1219	69
16	Pawai	181	6	7	812	350	43.1	0	462	462	24
17	Phulpur	176	4	4	248	122	49.19	0	126	126	7
18	Rani Ki Sarai	207	22	22	3255	1594	48.97	0	1661	1661	93
19	Sathiyaon	147	4	4	455	223	49.01	0	232	232	13
20	Tahbarpur	185	15	15	1120	549	49.02	0	571	571	32

Block-wise coverage of villages

State : UTTAR PRADESH
District : Azamgarh

S.No.	Name of Block	Total no. of villages as per census	Villages proposed under present scheme	Habitations proposed under present scheme	Total RHhs (Incl. BPL Hhs)	No of RHhs already electrified upto 31.03.15	% Electrification as on 31.03.15	RHhs(Incl. BPL) Already sanctioned and under execution in erstwhile RGGVY/State/ other schemes	Balance to be electrified	RHhs Proposed under present scheme	BPL Proposed under present scheme
1	2	3	4	5	6	7	8	9	10	11	12
21	Tarwa	219	5	5	303	122	40.26	0	181	181	8
22	Thekma	165	5	5	530	260	49.06	0	270	270	16
Total		4108	182	195	23188	10768	46.44	0	12420	12420	669

Villagewise/Habitation wise coverage

State : UTTAR PRADESH
District : Azamgarh

Sl.No. (Vill.)	Name of Village (all villages as per census)	Census Code (2011)	Name of Habitation including main villages	Habitation Code	Total No. of RHs	No of RHhs electrified as on 31.03.2015	Balance Nos. of RHH to be electrified as on 31.03.2015	Total BPL already sanctioned under execution in erstwhile RGGVY/State/Ce ntral Scheme as on 31/3/2015	No of RHhs proposed to be electrified including BPL	No of BPL Hhs proposed to be electrified
1	2	3	4	5	6	7	8	9	10	11
Block :: Ahiraula										
1	Bilari Lakhanpur	192432	THAKURANA	192432-009	53	26	27	0	27	1
2	Pakhanpur	194845	KUMHAR BASTI	194845-002	57	28	29	0	29	2
3	Pahijan Rampur	194847	RAMPUR	194847-002	92	45	47	0	47	3
4	Khuraso	194889	KUMHAR BASTI	194889-004	98	48	50	0	50	3
Total - Ahiraula					300	147	153	0	153	9
Block :: Atraulia										
1	Lohra	191955	DIHWA	191955-027	86	42	44	0	44	2
2	Bhikh Pur	191971	NORTH KA PURA	191971-002	70	34	36	0	36	2
3	Dhaurahra	192015	YB	192015-004	55	27	28	0	28	2
4	Ataraulia	192039	YB	192039-006	66	32	34	0	34	2
5	Selhra Patti	192057	YB	192057-005	69	34	35	0	35	2
Total - Atraulia					346	169	177	0	177	10
Block :: Azmatgarh										
1	Bankatiya	193185	KOIRANA	193185-003	53	26	27	0	27	1
2	Meghai Khas	193242	YB	193242-005	53	26	27	0	27	1
3	Chunugpar	193260	YB	193260-004	78	38	40	0	40	2
4	Anjan Shaheed	193313	BAZAR	193313-002	105	51	54	0	54	3

Villagewise/Habitation wise coverage

State : UTTAR PRADESH
District : Azamgarh

Sl.No. (Vill.)	Name of Village (all villages as per census)	Census Code (2011)	Name of Habitation including main villages	Habitation Code	Total No. of RHhs	No of RHhs electrified as on 31.03.2015	Balance Nos. of RHH to be electrified as on 31.03.2015	Total BPL already sanctioned under execution in erstwhile RGGVY/State/Ce ntral Scheme as on 31/3/2015	No of RHhs proposed to be electrified including BPL	No of BPL Hhs proposed to be electrified
1	2	3	4	5	6	7	8	9	10	11
5	Chhattarpur Khushhal	193325	YB	193325-003	53	26	27	0	27	1
6	Shahpur Newada	193332	YB	193332-003	79	39	40	0	40	2
7	Mahawatgarh	193392	YB	193392-006	66	32	34	0	34	2
Total - Azmatgarh					487	238	249	0	249	12
Block :: Bilariyaganj										
1	Jagmalpur	192936	HB E	192936-001	93	46	47	0	47	3
2	Madhnapar	193001	RAMPUR	193001-005	98	48	50	0	50	3
3	Bindwal	193021	BAZAR	193021-001	71	35	36	0	36	2
4	Jolhapur	193044	SONKAR BASTI	193044-009	79	39	40	0	40	2
Total - Bilariyaganj					341	168	173	0	173	10
Block :: Haraiya										
1	Turkauli	192763	YADAV BASTI	192763-006	52	25	27	0	27	1
2	Khetapur	192790	YADAV BASTI	192790-005	121	59	62	0	62	3
3	Parsiya	192797	YADAV BASTI	192797-004	74	36	38	0	38	2
4	Bardiha	192805	H B EAST	192805-002	73	0	73	0	73	2
5	Bankata Urf Bazargosain	192839	YADAV BASTI	192839-006	123	60	63	0	63	4
6	Harraiya	192840	H B EAST	192840-006	57	0	57	0	57	2
Total - Haraiya					500	180	320	0	320	14

Villagewise/Habitation wise coverage

State : UTTAR PRADESH
District : Azamgarh

Sl.No. (Vill.)	Name of Village (all villages as per census)	Census Code (2011)	Name of Habitation including main villages	Habitation Code	Total No. of RHs	No of RHs electrified as on 31.03.2015	Balance Nos. of RHH to be electrified as on 31.03.2015	Total BPL already sanctioned under execution in erstwhile RGGVY/State/Ce ntral Scheme as on 31/3/2015	No of RHs proposed to be electrified including BPL	No of BPL Hhs proposed to be electrified
1	2	3	4	5	6	7	8	9	10	11
Block :: Jahanaganj										
1	Koilarai Khurd	193877	KHODADPUR	193877-001	130	64	66	0	66	4
2	Karaut	193901	HB NORTH	193901-005	98	48	50	0	50	3
3	Mittupur	193919	CHAUHAN BASTI	193919-001	241	118	123	0	123	7
4	Sevata	193923	SAREEKAT CHAK KHASH	193923-001	191	94	97	0	97	5
5	Zahid Chak	193930	MATTIYANA	193930-003	101	0	101	0	101	3
			GAURSAR	193930-004	88	0	88	0	88	3
6	Kannayala Karanhat	193954	YB	193954-004	126	62	64	0	64	4
7	Dharawara	193959	HB NORTH	193959-003	144	71	73	0	73	4
8	Jogapur	193986	Jogapur	193986-001	148	73	75	0	75	4
9	Laxmipur	193999	LAKHANTAND	193999-001	145	71	74	0	74	4
10	Badasar Or Kadasar	194022	BAHAUDDINPU R	194022-001	123	60	63	0	63	4
11	Masuba	194027	MAMARKHAPU R KHASH	194027-001	221	108	113	0	113	6
12	Khanpur	194028	KATGHAR ISMAILE	194028-001	160	78	82	0	82	5
13	Haripur Khurd Or Serpur Khurd	194068	CHAUHAN BASTI	194068-001	88	43	45	0	45	3

Villagewise/Habitation wise coverage

State : UTTAR PRADESH
District : Azamgarh

Sl.No. (Vill.)	Name of Village (all villages as per census)	Census Code (2011)	Name of Habitation including main villages	Habitation Code	Total No. of RHhs	No of RHhs electrified as on 31.03.2015	Balance Nos. of RHH to be electrified as on 31.03.2015	Total BPL already sanctioned under execution in erstwhile RGGVY/State/Ce ntral Scheme as on 31/3/2015	No of RHhs proposed to be electrified including BPL	No of BPL Hhs proposed to be electrified
1	2	3	4	5	6	7	8	9	10	11
14	Telahua Chakvali	194081	SURAJPUR	194081-001	246	121	125	0	125	7
15	Barahatir Jagdishpur (CT)	194085	BAJAR	194085-001	1705	835	870	0	870	48
			CHAUHAN BASTI	194085-003	167	82	85	0	85	5
Total - Jahanaganj					4122	1928	2194	0	2194	119
Block :: Koilsa										
1	Baragaon	192153	PANDAY KA PURA	192153-003	52	25	27	0	27	1
2	Bhilampur Chhapara	192158	MUSLIM BASTI	192158-006	134	66	68	0	68	4
3	Burhanpur	192194	BAZAR	192194-001	131	64	67	0	67	4
4	Koilsa	192199	MUSLIM BASTI	192199-003	60	29	31	0	31	2
5	Ishwarpur Pawni	192200	BAZAR	192200-001	337	165	172	0	172	9
6	Ekdangi	192216	MUSLIM BASTI	192216-003	53	26	27	0	27	1
7	Bhedaura	192242	TAKIYA	192242-006	51	25	26	0	26	1
8	Bhimakol	192277	PANDAY KA PURA	192277-007	65	32	33	0	33	2
Total - Koilsa					883	432	451	0	451	24
Block :: Lalganj										
1	Tikar Garh	195359	MUSLIM BASTI	195359-002	107	52	55	0	55	3

Villagewise/Habitation wise coverage

State : UTTAR PRADESH
District : Azamgarh

Sl.No. (Vill.)	Name of Village (all villages as per census)	Census Code (2011)	Name of Habitation including main villages	Habitation Code	Total No. of RHs	No of RHs electrified as on 31.03.2015	Balance Nos. of RHH to be electrified as on 31.03.2015	Total BPL already sanctioned under execution in erstwhile RGGVY/State/Central Scheme as on 31/3/2015	No of RHs proposed to be electrified including BPL	No of BPL Hhs proposed to be electrified
1	2	3	4	5	6	7	8	9	10	11
2	Mehnazpur	195385	MEHNAJPUR	195385-001	908	445	463	0	463	26
3	Narayanpur Nevada	195494	MUSLIM BASTI	195494-003	91	45	46	0	46	3
4	Zirikpur	195513	CHAUHAN	195513-006	106	0	106	0	106	4
			H B	195513-007	153	0	153	0	153	5
			NONIPUR	195513-008	217	0	217	0	217	7
			YADAV BASTI	195513-009	108	0	108	0	108	4
5	Srikantpur	195515	YB	195515-004	101	49	52	0	52	3
6	Agahata	195523	YB	195523-005	88	43	45	0	45	3
Total - Lalganj					1879	634	1245	0	1245	58
Block :: Mahrajganj										
1	Dewara Kadim	192453	KHANGERPUR	192453-003	145	71	74	0	74	4
2	Barauli	192564	RAJBHAR BASTI	192564-002	51	25	26	0	26	1
3	Narottampur Suryman	192633	RAJBHAR BASTI	192633-002	56	27	29	0	29	2
4	Mirpur Navey	192646	MEERPUR NAVE	192646-001	49	24	25	0	25	1
5	Bhitehara	192653	RAJBHAR BASTI	192653-004	45	22	23	0	23	1
6	Baidra	192655	RAJBHAR BASTI	192655-001	60	29	31	0	31	2
7	Chandpur Bhataura	192689	RAJBHAR BASTI	192689-004	44	22	22	0	22	1

Villagewise/Habitation wise coverage

State : UTTAR PRADESH
District : Azamgarh

Sl.No. (Vill.)	Name of Village (all villages as per census)	Census Code (2011)	Name of Habitation including main villages	Habitation Code	Total No. of RHhs	No of RHhs electrified as on 31.03.2015	Balance Nos. of RHH to be electrified as on 31.03.2015	Total BPL already sanctioned under execution in erstwhile RGGVY/State/Ce ntral Scheme as on 31/3/2015	No of RHhs proposed to be electrified including BPL	No of BPL Hhs proposed to be electrified
1	2	3	4	5	6	7	8	9	10	11
Total - Mahrajganj					450	220	230	0	230	12
Block :: Martinganj										
1	Pipraula	195077	YB	195077-005	56	27	29	0	29	2
2	Karuie	195078	BANPURWA	195078-001	67	33	34	0	34	2
3	Purandarpur	195088	YB	195088-008	58	28	30	0	30	2
4	Para	195105	RAJBHAR 2	195105-005	71	35	36	0	36	2
5	Basti Kapuri	195115	YB	195115-009	60	29	31	0	31	2
6	Narwey	195117	YADAV BASTI	195117-006	75	37	38	0	38	2
7	Nikasipur	195127	YB	195127-004	56	27	29	0	29	2
8	Bangaon	195131	RAJBHAR BASTI SOUTH	195131-004	231	113	118	0	118	7
			YB	195131-005	68	33	35	0	35	2
9	Sonhara	195135	YB	195135-003	71	35	36	0	36	2
10	Ajaur	195136	YB	195136-005	60	29	31	0	31	2
11	Barauna	195144	YB	195144-007	54	26	28	0	28	2
12	Lasara Khurd	195167	YB	195167-006	101	49	52	0	52	3
13	Khrauli	195171	YB	195171-007	81	40	41	0	41	2
14	Kumbha	195175	YB	195175-006	136	67	69	0	69	4
Total - Martinganj					1245	608	637	0	637	38

Villagewise/Habitation wise coverage

State : UTTAR PRADESH
District : Azamgarh

Sl.No. (Vill.)	Name of Village (all villages as per census)	Census Code (2011)	Name of Habitation including main villages	Habitation Code	Total No. of RHhs	No of RHhs electrified as on 31.03.2015	Balance Nos. of RHH to be electrified as on 31.03.2015	Total BPL already sanctioned under execution in erstwhile RGGVY/State/Ce ntral Scheme as on 31/3/2015	No of RHhs proposed to be electrified including BPL	No of BPL Hhs proposed to be electrified
1	2	3	4	5	6	7	8	9	10	11
Block :: Mehnagar										
1	Supnahr Rudrapur	195772	USRAYIYA	195772-011	52	25	27	0	27	1
2	Pakaria Ranipur	195785	BHARAUTY	195785-002	56	27	29	0	29	2
3	Ganjor	195826	KOHRAN	195826-005	59	29	30	0	30	2
4	Ghurehtha	195884	EAST HB	195884-001	60	29	31	0	31	2
5	Usama Patti	195911	FATEPUR BHATOULI	195911-005	58	0	58	0	58	2
			REDDA	195911-009	88	0	88	0	88	3
6	Amari	195927	CHAUHAN BASTI	195927-002	67	33	34	0	34	2
			GOSAI PURA	195927-003	51	25	26	0	26	1
7	Gopalpur	195935	SARYA	195935-006	86	42	44	0	44	2
8	Kishundaspur	195954	BHARAUTY	195954-001	58	28	30	0	30	2
9	Pitthu Patti	195955	BHARAUTY	195955-001	52	25	27	0	27	1
10	Roshanpur	195956	BHARAUTY	195956-001	52	25	27	0	27	1
Total - Mehnagar					739	288	451	0	451	21
Block :: Mirzapur										
1	Mudiyar	194259	BHARAITI	194259-001	99	49	50	0	50	3
2	Bakspur	194271	HARIJAN BASTI	194271-002	85	42	43	0	43	2

Villagewise/Habitation wise coverage

State : UTTAR PRADESH
District : Azamgarh

Sl.No. (Vill.)	Name of Village (all villages as per census)	Census Code (2011)	Name of Habitation including main villages	Habitation Code	Total No. of RHhs	No of RHhs electrified as on 31.03.2015	Balance Nos. of RHH to be electrified as on 31.03.2015	Total BPL already sanctioned under execution in erstwhile RGGVY/State/Ce ntral Scheme as on 31/3/2015	No of RHhs proposed to be electrified including BPL	No of BPL Hhs proposed to be electrified
1	2	3	4	5	6	7	8	9	10	11
3	Chak Kamarali	194275	PANDIT BASTI	194275-004	86	42	44	0	44	2
4	Niyauj	194288	YADAV BASTI	194288-006	377	185	192	0	192	11
5	Mirjapur	194294	H.B	194294-001	164	80	84	0	84	5
			YADAV BASTI	194294-004	92	45	47	0	47	3
6	Gauspur	194322	YADAV BASTI	194322-003	114	56	58	0	58	3
7	Sidha Sultanpur	194335	HARIJAN BASTI	194335-001	184	90	94	0	94	5
8	Ahiripur	194349	YADAV BASTI	194349-002	160	78	82	0	82	5
9	Tikariya Maddhu Khan	194351	HARIJAN BASTI	194351-002	114	56	58	0	58	3
10	Kaudiya	194352	YADAV BASTI	194352-004	161	79	82	0	82	5
11	Pavailadpur	194382	HARIJAN BASTI	194382-001	108	53	55	0	55	3
12	Newada	194424	H.B	194424-001	124	61	63	0	63	4
Total - Mirzapur					1868	916	952	0	952	54
Block :: Mohammadpur										
1	Parsurampur	194560	CHAUHAN BASTI	194560-002	93	46	47	0	47	3
2	Nagawan	194575	CHAUHAN BASTI	194575-002	51	25	26	0	26	1
3	Masud Patti	194616	CHAUHAN BASTI	194616-001	128	63	65	0	65	4
4	Avak	194649	RAJBHAR BASTI	194649-006	75	37	38	0	38	2

Villagewise/Habitation wise coverage

State : UTTAR PRADESH
District : Azamgarh

Sl.No. (Vill.)	Name of Village (all villages as per census)	Census Code (2011)	Name of Habitation including main villages	Habitation Code	Total No. of RHhs	No of RHhs electrified as on 31.03.2015	Balance Nos. of RHH to be electrified as on 31.03.2015	Total BPL already sanctioned under execution in erstwhile RGGVY/State/Central Scheme as on 31/3/2015	No of RHhs proposed to be electrified including BPL	No of BPL Hhs proposed to be electrified
1	2	3	4	5	6	7	8	9	10	11
5	Koilari Bujurg	195760	CHAUHAN BASTI	195760-002	66	32	34	0	34	2
Total - Mohammadpur					413	203	210	0	210	12
Block :: Palhani										
1	Bodhpur Or Godpur	193552	` GODHPUR	193552-001	139	68	71	0	71	4
2	Aho Patti	193645	YB	193645-004	113	55	58	0	58	3
3	Karimuddinpur	193647	GENRAL BASTI	193647-003	143	70	73	0	73	4
4	Belnadih	193670	RAJBHAR BASTI	193670-003	105	51	54	0	54	3
Total - Palhani					500	244	256	0	256	14
Block :: Palhna										
1	Narsingh Pur	195413	HB	195413-002	100	49	51	0	51	3
2	Bhojpur	195418	BHAROUTI	195418-001	142	70	72	0	72	4
3	Sarai Khursu	195419	BHAROUTI	195419-001	102	50	52	0	52	3
4	Tarak Dih	195421	HB	195421-001	128	63	65	0	65	4
			TADAKDIH	195421-002	61	30	31	0	31	2
5	Lahuwa Kalan	195428	HB	195428-003	359	176	183	0	183	10
6	Kota Khurd	195431	HB	195431-003	99	49	50	0	50	3
7	Avani	195606	BHAROUTI	195606-002	100	49	51	0	51	3
8	Karsara	195610	BHAROUTI	195610-001	103	50	53	0	53	3

Villagewise/Habitation wise coverage

State : UTTAR PRADESH
District : Azamgarh

Sl.No. (Vill.)	Name of Village (all villages as per census)	Census Code (2011)	Name of Habitation including main villages	Habitation Code	Total No. of RHhs	No of RHhs electrified as on 31.03.2015	Balance Nos. of RHH to be electrified as on 31.03.2015	Total BPL already sanctioned under execution in erstwhile RGGVY/State/Ce ntral Scheme as on 31/3/2015	No of RHhs proposed to be electrified including BPL	No of BPL Hhs proposed to be electrified
1	2	3	4	5	6	7	8	9	10	11
9	Katai	195828	HB	195828-001	153	75	78	0	78	4
10	Pauni Kalan	195832	HB	195832-001	270	132	138	0	138	8
11	Khajuri	195833	BHAROUTI	195833-001	191	94	97	0	97	5
			HB	195833-002	94	46	48	0	48	3
12	Singhpur	195944	BHAROUTI	195944-002	100	49	51	0	51	3
13	Kahutara	195951	HB SOUTH	195951-003	147	72	75	0	75	4
14	Ismailpur Bharathipur	196061	BHAROUTI	196061-001	149	73	76	0	76	4
			HB	196061-002	94	46	48	0	48	3
Total - Palhna					2392	1173	1219	0	1219	69
Block :: Pawai										
1	Nizampur	194713	BHARAUTI	194713-002	168	82	86	0	86	5
			H.B.P	194713-003	89	44	45	0	45	3
2	Jaldipur	194771	KAWATAN	194771-009	189	93	96	0	96	5
3	Jafarpur Kathakan	194799	BHAR BASTI	194799-001	89	44	45	0	45	3
4	Gondhana	194801	KALAN	194801-006	99	0	99	0	99	3
5	Ambari	194807	BAZAR	194807-002	94	46	48	0	48	3
6	Kushaha	194821	BHARAUTI	194821-001	84	41	43	0	43	2
Total - Pawai					812	350	462	0	462	24

Villagewise/Habitation wise coverage

State : UTTAR PRADESH
District : Azamgarh

Sl.No. (Vill.)	Name of Village (all villages as per census)	Census Code (2011)	Name of Habitation including main villages	Habitation Code	Total No. of RHhs	No of RHhs electrified as on 31.03.2015	Balance Nos. of RHH to be electrified as on 31.03.2015	Total BPL already sanctioned under execution in erstwhile RGGVY/State/Ce ntral Scheme as on 31/3/2015	No of RHhs proposed to be electrified including BPL	No of BPL Hhs proposed to be electrified
1	2	3	4	5	6	7	8	9	10	11
Block :: Phulpur										
1	Gandi	194979	AHIRAN	194979-001	67	33	34	0	34	2
2	Dighiya	194983	AHIRAN	194983-001	69	34	35	0	35	2
3	Palthi	195016	AHIRAN	195016-001	53	26	27	0	27	1
4	Kharsahan Khurd	195050	KOTIYA	195050-003	59	29	30	0	30	2
Total - Phulpur					248	122	126	0	126	7
Block :: Rani Ki Sarai										
1	Hamidpur	193459	HAMEEDPUR	193459-001	91	45	46	0	46	3
2	Chuhaipur	193482	CHOOHAN PATTI	193482-001	105	51	54	0	54	3
3	Saifpur	193489	SAIFPUR	193489-002	249	122	127	0	127	7
4	Shambhu Ayeema Or Shambhopu Ay	193496	MUSHER BASTI	193496-002	206	101	105	0	105	6
5	Daudpur	193510	MUSLIM BASTI	193510-003	122	60	62	0	62	3
6	Deoka Patti	193512	DEWKAPATTI H BASTI	193512-001	63	31	32	0	32	2
7	Khaira	193517	YB	193517-003	107	52	55	0	55	3
8	Dharm Daspur	193518	DHARMDAS PUR	193518-001	123	60	63	0	63	4
9	Behta Lachhirampur Or Behta	193522	MUSLIM BASTI	193522-003	96	47	49	0	49	3

Villagewise/Habitation wise coverage

State : UTTAR PRADESH
District : Azamgarh

Sl.No. (Vill.)	Name of Village (all villages as per census)	Census Code (2011)	Name of Habitation including main villages	Habitation Code	Total No. of RHs	No of RHs electrified as on 31.03.2015	Balance Nos. of RHH to be electrified as on 31.03.2015	Total BPL already sanctioned under execution in erstwhile RGGVY/State/Ce ntral Scheme as on 31/3/2015	No of RHs proposed to be electrified including BPL	No of BPL Hhs proposed to be electrified
1	2	3	4	5	6	7	8	9	10	11
10	Jalaipur	193524	JALAIPUR	193524-002	208	102	106	0	106	6
11	Shahi Garha	193537	MAURYA BASTI	193537-002	199	98	101	0	101	6
12	Marantpur Kashi Ali	194444	MARUKHPUR KASHIMALI	194444-001	156	76	80	0	80	4
13	Kotwalipur	194449	KOHAR BASTI	194449-001	102	50	52	0	52	3
14	Dodopur	194456	BHUNKI H BASTI	194456-001	151	74	77	0	77	4
15	Telipur	194458	TELLI PUR	194458-002	96	47	49	0	49	3
16	Isapur	194480	ISHAPUR	194480-001	143	70	73	0	73	4
17	Fariya	194495	FARIHA SARHEDPAR H BASTI	194495-004	235	115	120	0	120	7
18	Gandhuvai	194498	MUSHAR BASTI	194498-003	253	124	129	0	129	7
19	Khawajapur	194518	KHATIKAN	194518-002	143	70	73	0	73	4
20	Katghar Babul	194522	KATGHAR BABOOL	194522-001	131	64	67	0	67	4
21	Jamin Katghar	194527	HB SOUTH	194527-002	117	57	60	0	60	3
22	Sheewli	194536	UTTARI MUSLIM BASTI	194536-005	159	78	81	0	81	4
Total - Rani Ki Sarai					3255	1594	1661	0	1661	93

Block :: Sathiyaon

Villagewise/Habitation wise coverage

State : UTTAR PRADESH
District : Azamgarh

Sl.No. (Vill.)	Name of Village (all villages as per census)	Census Code (2011)	Name of Habitation including main villages	Habitation Code	Total No. of RHhs	No of RHhs electrified as on 31.03.2015	Balance Nos. of RHH to be electrified as on 31.03.2015	Total BPL already sanctioned under execution in erstwhile RGGVY/State/Ce ntral Scheme as on 31/3/2015	No of RHhs proposed to be electrified including BPL	No of BPL Hhs proposed to be electrified
1	2	3	4	5	6	7	8	9	10	11
1	Bhamahaur	193805	HARIJAN BASTI SOUTH	193805-002	80	39	41	0	41	2
2	Gagahara	193810	MUSHAR BASTI	193810-007	77	38	39	0	39	2
3	Khemaupur	193843	HARIJAN BASTI EAST	193843-001	175	86	89	0	89	5
4	Naizarpur	193853	RAJBHAR BASTI	193853-002	123	60	63	0	63	4
Total - Sathiyaon					455	223	232	0	232	13
Block :: Tahbarpur										
1	Madya Or Garya	193417	AHIRAN	193417-001	59	29	30	0	30	2
2	Bhurramaq Bulpur Or Mori Makdu	193418	H BASTI NORTH	193418-004	80	39	41	0	41	2
3	Ekma	193429	H BASTI	193429-003	95	47	48	0	48	3
4	Nasiruddinpur	193431	H BASTI	193431-001	82	40	42	0	42	2
5	Garhwa	194098	LOHRAUTI	194098-005	53	26	27	0	27	1
6	Ohani	194111	H BASTI	194111-001	102	50	52	0	52	3
7	Govindpur	194125	H BASTI	194125-003	88	43	45	0	45	3
8	Kariyabar	194130	Y BASTI NORTH	194130-008	67	33	34	0	34	2
9	Deoria	194147	FAKIRANA	194147-002	53	26	27	0	27	1
10	Badsara Khalsa	194150	H BASTI	194150-002	84	41	43	0	43	2
11	Merhi	194191	KAVTANA	194191-003	59	29	30	0	30	2

Villagewise/Habitation wise coverage

State : UTTAR PRADESH
District : Azamgarh

Sl.No. (Vill.)	Name of Village (all villages as per census)	Census Code (2011)	Name of Habitation including main villages	Habitation Code	Total No. of RHhs	No of RHhs electrified as on 31.03.2015	Balance Nos. of RHH to be electrified as on 31.03.2015	Total BPL already sanctioned under execution in erstwhile RGGVY/State/Ce ntral Scheme as on 31/3/2015	No of RHhs proposed to be electrified including BPL	No of BPL Hhs proposed to be electrified
1	2	3	4	5	6	7	8	9	10	11
12	Madhsiya	194196	CHAUHAN BASTI	194196-002	67	33	34	0	34	2
13	Chakbari	194197	WEST PURA	194197-004	100	49	51	0	51	3
14	Bhilauli Khalsa	194226	FAKIRANA	194226-002	63	31	32	0	32	2
15	Chak Majnu	194229	MOTIDEH	194229-003	68	33	35	0	35	2
Total - Tahbarpur					1120	549	571	0	571	32
Block :: Tarwa										
1	Barawa	195643	YADAV BASTI	195643-004	112	55	57	0	57	3
2	Bahlolpur	195728	BHARAVATI	195728-002	49	24	25	0	25	1
3	Zoova	196002	MAROBPUR	196002-003	55	0	55	0	55	2
4	Bairodih	196026	YADAV BASTI	196026-002	45	22	23	0	23	1
5	Titara	196039	PANDETAN	196039-005	42	21	21	0	21	1
Total - Tarwa					303	122	181	0	181	8
Block :: Thekma										
1	Belau	195178	HB.EAST	195178-003	133	65	68	0	68	4
2	Gopalpur	195210	GOPALPUR	195210-001	107	52	55	0	55	3
3	Para	195304	THAKUR BASTI	195304-008	87	43	44	0	44	3
4	Bheera	195307	CHAUHAN BASTI	195307-003	99	49	50	0	50	3
5	Chhattar Pur	195309	MUSLIM BASTI	195309-004	104	51	53	0	53	3

Villagewise/Habitation wise coverage

State : UTTAR PRADESH
District : Azamgarh

Sl.No. (Vill.)	Name of Village (all villages as per census)	Census Code (2011)	Name of Habitation including main villages	Habitation Code	Total No. of RHhs	No of RHhs electrified as on 31.03.2015	Balance Nos. of RHH to be electrified as on 31.03.2015	Total BPL already sanctioned under execution in erstwhile RGGVY/State/Ce ntral Scheme as on 31/3/2015	No of RHhs proposed to be electrified including BPL	No of BPL Hhs proposed to be electrified
1	2	3	4	5	6	7	8	9	10	11
Total - Thekma					530	260	270	0	270	16
Summary										
Ahiraula					300	147	153	0	153	9
Atraulia					346	169	177	0	177	10
Azmatgarh					487	238	249	0	249	12
Bilariyaganj					341	168	173	0	173	10
Haraiya					500	180	320	0	320	14
Jahanaganj					4122	1928	2194	0	2194	119
Koilsa					883	432	451	0	451	24
Lalganj					1879	634	1245	0	1245	58
Mahrajganj					450	220	230	0	230	12
Martinganj					1245	608	637	0	637	38
Mehnagar					739	288	451	0	451	21
Mirzapur					1868	916	952	0	952	54
Mohammadpur					413	203	210	0	210	12
Palhani					500	244	256	0	256	14
Palhna					2392	1173	1219	0	1219	69
Pawai					812	350	462	0	462	24
Phulpur					248	122	126	0	126	7

Villagewise/Habitation wise coverage

State : UTTAR PRADESH
District : Azamgarh

Sl.No. (Vill.)	Name of Village (all villages as per census)	Census Code (2011)	Name of Habitation including main villages	Habitation Code	Total No. of RHs	No of RHs electrified as on 31.03.2015	Balance Nos. of RHH to be electrified as on 31.03.2015	Total BPL already sanctioned under execution in erstwhile RGGVY/State/Ce ntral Scheme as on 31/3/2015	No of RHs proposed to be electrified including BPL	No of BPL Hhs proposed to be electrified
1	2	3	4	5	6	7	8	9	10	11
	Rani Ki Sarai				3255	1594	1661	0	1661	93
	Sathiyaon				455	223	232	0	232	13
	Tahbarpur				1120	549	571	0	571	32
	Tarwa				303	122	181	0	181	8
	Thekma				530	260	270	0	270	16
	Grand Total				23188	10768	12420	0	12420	669

Existing Habitation Wise Infrastructure

State : UTTAR PRADESH
District : Azamgarh

Sl.No. (Vill.)	Name of Village (all villages as per census)	Census Code (2011)	Name of Habitation including main villages	Habitation Code	Existing LT Networks (in Kms)				Existing Distribution Transformers (DT)	Total (DT)
					Overhead	AB cable	Overhead	AB cable		
1	2	3	4	5	6	7	8	9	10	11
Block :: Ahiraula										
1	Bilari Lakhanpur	192432	THAKURANA	192432-009	0	0.69	0	0.37		0
2	Pakhanpur	194845	KUMHAR BASTI	194845-002	0	0.74	0	0.4		0
3	Pahijan Rampur	194847	RAMPUR	194847-002	0	1.2	0	0.64	1 * (10 KVA (1 Ph))	1
4	Khuraso	194889	KUMHAR BASTI	194889-004	0	1.27	0	0.69	1 * (10 KVA (1 Ph))	1
Total - Ahiraula					0	3.9	0	2.1		
Block :: Atraulia										
1	Lohra	191955	DIHWA	191955-027	0	1.12	0	0.6	1 * (10 KVA (1 Ph)) + 1 * (16 KVA (1 Ph))	2
2	Bhikh Pur	191971	NORTH KA PURA	191971-002	0	0.91	0	0.49	1 * (10 KVA (1 Ph))	1
3	Dhaurahra	192015	YB	192015-004	0	0.72	0	0.39		0
4	Ataraulia	192039	YB	192039-006	0	0.86	0	0.46	1 * (10 KVA (1 Ph))	1
5	Selhra Patti	192057	YB	192057-005	0	0.9	0	0.48	1 * (10 KVA (1 Ph))	1
Total - Atraulia					0	4.51	0	2.42		
Block :: Azmatgarh										
1	Bankatiya	193185	KOIRANA	193185-003	0	0.69	0	0.37	1 * (10 KVA (1 Ph))	1
2	Meghai Khas	193242	YB	193242-005	0	0.69	0	0.37	1 * (10 KVA (1 Ph))	1
3	Chunugpar	193260	YB	193260-004	0	1.01	0	0.55	2 * (10 KVA (1 Ph))	2
4	Anjan Shaheed	193313	BAZAR	193313-002	0	1.37	0	0.74	1 * (10 KVA (1 Ph)) + 1 * (16 KVA (1 Ph))	2

Existing Habitation Wise Infrastructure

State : UTTAR PRADESH
District : Azamgarh

Sl.No. (Vill.)	Name of Village (all villages as per census)	Census Code (2011)	Name of Habitation including main villages	Habitation Code	Existing LT Networks (in Kms)				Existing Distribution Transformers (DT)	Total (DT)
					Overhead	AB cable	Overhead	AB cable		
1	2	3	4	5	6	7	8	9	10	11
5	Chhattarpur Khushhal	193325	YB	193325-003	0	0.69	0	0.37	1 * (10 KVA (1 Ph))	1
6	Shahpur Newada	193332	YB	193332-003	0	1.03	0	0.55	1 * (10 KVA (1 Ph))	1
7	Mahawatgarh	193392	YB	193392-006	0	0.86	0	0.46	1 * (10 KVA (1 Ph))	1
Total - Azmatgarh					0	6.34	0	3.41		
Block :: Bilariyaganj										
1	Jagmalpur	192936	HB E	192936-001	0	1.21	0	0.65	1 * (10 KVA (1 Ph))	1
2	Madhnapar	193001	RAMPUR	193001-005	0	1.27	0	0.69	1 * (10 KVA (1 Ph))	1
3	Bindwal	193021	BAZAR	193021-001	0	0.92	0	0.5		0
4	Jolhapur	193044	SONKAR BASTI	193044-009	0	1.03	0	0.55	1 * (10 KVA (1 Ph))	1
Total - Bilariyaganj					0	4.43	0	2.39		
Block :: Haraiya										
1	Turkauli	192763	YADAV BASTI	192763-006	0	0.68	0	0.36		0
2	Khetapur	192790	YADAV BASTI	192790-005	0	1.57	0	0.85	1 * (10 KVA (1 Ph)) + 1 * (16 KVA (1 Ph))	2
3	Parsiya	192797	YADAV BASTI	192797-004	0	0.96	0	0.52		0
4	Bardiha	192805	H B EAST	192805-002	0	0	0	0		0
5	Bankata Urf Bazargosain	192839	YADAV BASTI	192839-006	0	1.6	0	0.86	1 * (10 KVA (1 Ph))	1
6	Harraiya	192840	H B EAST	192840-006	0	0	0	0		0
Total - Haraiya					0	4.81	0	2.59		

Existing Habitation Wise Infrastructure

State : UTTAR PRADESH
District : Azamgarh

Sl.No. (Vill.)	Name of Village (all villages as per census)	Census Code (2011)	Name of Habitation including main villages	Habitation Code	Existing LT Networks (in Kms)				Existing Distribution Transformers (DT)	Total (DT)
					Overhead	AB cable	Overhead	AB cable		
1	2	3	4	5	6	7	8	9	10	11
Block :: Jahanaganj										
1	Koilarai Khurd	193877	KHODADPUR	193877-001	0	1.69	0	0.91	1 * (10 KVA (1 Ph)) + 1 * (16 KVA (1 Ph))	2
2	Karaut	193901	HB NORTH	193901-005	0	1.27	0	0.69	1 * (10 KVA (1 Ph)) + 1 * (16 KVA (1 Ph))	2
3	Mittupur	193919	CHAUHAN BASTI	193919-001	0	3.13	0	1.69	1 * (10 KVA (1 Ph)) + 1 * (16 KVA (1 Ph))	2
4	Sevata	193923	SAREEKAT CHAK KHASH	193923-001	0	2.48	0	1.34	1 * (10 KVA (1 Ph)) + 1 * (16 KVA (1 Ph))	2
5	Zahid Chak	193930	MATIYANA	193930-003	0	0	0	0		0
			GAURSAR	193930-004	0	0	0	0		0
6	Kannayala Karanhat	193954	YB	193954-004	0	1.64	0	0.88	1 * (10 KVA (1 Ph)) + 1 * (16 KVA (1 Ph))	2
7	Dharawara	193959	HB NORTH	193959-003	0	1.87	0	1.01	1 * (10 KVA (1 Ph)) + 1 * (16 KVA (1 Ph))	2
8	Jogapur	193986	Jogapur	193986-001	0	1.92	0	1.04	1 * (10 KVA (1 Ph)) + 1 * (16 KVA (1 Ph))	2
9	Laxmipur	193999	LAKHANTAND	193999-001	0	1.89	0	1.02	1 * (10 KVA (1 Ph)) + 1 * (16 KVA (1 Ph))	2
10	Badasar Or Kadasar	194022	BAHAUDDINP UR	194022-001	0	1.6	0	0.86	1 * (10 KVA (1 Ph)) + 1 * (16 KVA (1 Ph))	2
11	Masuba	194027	MAMARKHAP UR KHASH	194027-001	0	2.87	0	1.55	1 * (10 KVA (1 Ph)) + 1 * (16 KVA (1 Ph))	2
12	Khanpur	194028	KATGHAR ISMAILE	194028-001	0	2.08	0	1.12	1 * (10 KVA (1 Ph)) + 1 * (16 KVA (1 Ph))	2
13	Haripur Khurd Or Serpur Khurd	194068	CHAUHAN BASTI	194068-001	0	1.14	0	0.62	1 * (10 KVA (1 Ph)) + 1 * (16 KVA (1 Ph))	2
14	Telahua Chakvali	194081	SURAJPUR	194081-001	0	3.2	0	1.72	1 * (10 KVA (1 Ph)) + 1 * (16 KVA (1 Ph))	2

Existing Habitation Wise Infrastructure

State : UTTAR PRADESH
District : Azamgarh

Sl.No. (Vill.)	Name of Village (all villages as per census)	Census Code (2011)	Name of Habitation including main villages	Habitation Code	Existing LT Networks (in Kms)				Existing Distribution Transformers (DT)	Total (DT)
					Overhead	AB cable	Overhead	AB cable		
1	2	3	4	5	6	7	8	9	10	11
15	Barahatir Jagdishpur (CT)	194085	BAJAR	194085-001	0	22.17	0	11.94	1 * (10 KVA (1 Ph)) + 5 * (16 KVA (1 Ph)) + 2 * (100 KVA (3 Ph)) + 1 * (250 KVA (3 Ph)) + 2 * (315 KVA (3 Ph))	11
			CHAUHAN BASTI	194085-003	0	2.17	0	1.17	1 * (10 KVA (1 Ph)) + 1 * (16 KVA (1 Ph))	2
Total - Jahanaganj					0	51.12	0	27.56		
Block :: Koilsa										
1	Baragaon	192153	PANDAY KA PURA	192153-003	0	0.68	0	0.36		0
2	Bhilampur Chhapara	192158	MUSLIM BASTI	192158-006	0	1.74	0	0.94	1 * (10 KVA (1 Ph)) + 1 * (16 KVA (1 Ph))	2
3	Burhanpur	192194	BAZAR	192194-001	0	1.7	0	0.92	1 * (10 KVA (1 Ph)) + 1 * (16 KVA (1 Ph))	2
4	Koilsa	192199	MUSLIM BASTI	192199-003	0	0.78	0	0.42	1 * (10 KVA (1 Ph))	1
5	Ishwarpur Pawni	192200	BAZAR	192200-001	0	4.38	0	2.36	1 * (10 KVA (1 Ph)) + 1 * (16 KVA (1 Ph))	2
6	Ekdangi	192216	MUSLIM BASTI	192216-003	0	0.69	0	0.37		0
7	Bhedaura	192242	TAKIYA	192242-006	0	0.66	0	0.36		0
8	Bhimakol	192277	PANDAY KA PURA	192277-007	0	0.85	0	0.46	1 * (10 KVA (1 Ph))	1
Total - Koilsa					0	11.48	0	6.19		
Block :: Lalganj										
1	Tikar Garh	195359	MUSLIM BASTI	195359-002	0	1.39	0	0.75	1 * (10 KVA (1 Ph)) + 1 * (16 KVA (1 Ph))	2
2	Mehnazpur	195385	MEHNAJPUR	195385-001	0	11.8	0	6.36	1 * (10 KVA (1 Ph)) + 5 * (16 KVA (1 Ph)) + 1 * (100 KVA (3 Ph)) + 1 * (250 KVA (3 Ph)) + 1 * (315 KVA (3 Ph))	9

Existing Habitation Wise Infrastructure

State : UTTAR PRADESH
District : Azamgarh

Sl.No. (Vill.)	Name of Village (all villages as per census)	Census Code (2011)	Name of Habitation including main villages	Habitation Code	Existing LT Networks (in Kms)				Existing Distribution Transformers (DT)	Total (DT)
					Overhead	AB cable	Overhead	AB cable		
1	2	3	4	5	6	7	8	9	10	11
3	Narayanpur Nevada	195494	MUSLIM BASTI	195494-003	0	1.18	0	0.64	1 * (10 KVA (1 Ph))	1
4	Zirikpur	195513	CHAUHAN	195513-006	0	0	0	0		0
			H B	195513-007	0	0	0	0		0
			NONIPUR	195513-008	0	0	0	0		0
			YADAV BASTI	195513-009	0	0	0	0		0
5	Srikantpur	195515	YB	195515-004	0	1.31	0	0.71	1 * (10 KVA (1 Ph))	1
6	Agahata	195523	YB	195523-005	0	1.14	0	0.62	1 * (10 KVA (1 Ph))	1
Total - Lalganj					0	16.82	0	9.08		
Block :: Mahrajganj										
1	Dewara Kadim	192453	KHANGERPUR	192453-003	0	1.89	0	1.02	1 * (10 KVA (1 Ph)) + 1 * (16 KVA (1 Ph))	2
2	Barauli	192564	RAJBHAR BASTI	192564-002	0	0.66	0	0.36		0
3	Narottampur Suryman	192633	RAJBHAR BASTI	192633-002	0	0.73	0	0.39		0
4	Mirpur Navey	192646	MEERPUR NAVE	192646-001	0	0.64	0	0.34		0
5	Bhitehara	192653	RAJBHAR BASTI	192653-004	0	0.59	0	0.32		0
6	Baidra	192655	RAJBHAR BASTI	192655-001	0	0.78	0	0.42		0
7	Chandpur Bhataura	192689	RAJBHAR BASTI	192689-004	0	0.57	0	0.31		0

Existing Habitation Wise Infrastructure

State : UTTAR PRADESH
District : Azamgarh

Sl.No. (Vill.)	Name of Village (all villages as per census)	Census Code (2011)	Name of Habitation including main villages	Habitation Code	Existing LT Networks (in Kms)				Existing Distribution Transformers (DT)	Total (DT)
					Overhead	AB cable	Overhead	AB cable		
1	2	3	4	5	6	7	8	9	10	11
Total - Mahrajanj					0	5.86	0	3.16		
Block :: Martinganj										
1	Pipraula	195077	YB	195077-005	0	0.73	0	0.39		0
2	Karuie	195078	BANPURWA	195078-001	0	0.87	0	0.47		0
3	Purandarpur	195088	YB	195088-008	0	0.75	0	0.41		0
4	Para	195105	RAJBHAR 2	195105-005	0	0.92	0	0.5		0
5	Basti Kapuri	195115	YB	195115-009	0	0.78	0	0.42		0
6	Narwey	195117	YADAV BASTI	195117-006	0	0.98	0	0.53		0
7	Nikasipur	195127	YB	195127-004	0	0.73	0	0.39		0
8	Bangaon	195131	RAJBHAR BASTI SOUTH	195131-004	0	3	0	1.62	1 * (10 KVA (1 Ph))	1
			YB	195131-005	0	0.88	0	0.48		0
9	Sonhara	195135	YB	195135-003	0	0.92	0	0.5		0
10	Ajaur	195136	YB	195136-005	0	0.78	0	0.42		0
11	Barauna	195144	YB	195144-007	0	0.7	0	0.38		0
12	Lasara Khurd	195167	YB	195167-006	0	1.31	0	0.71	1 * (10 KVA (1 Ph))	1
13	Khrauli	195171	YB	195171-007	0	1.05	0	0.57		0
14	Kumbha	195175	YB	195175-006	0	1.77	0	0.95	1 * (10 KVA (1 Ph))	1
Total - Martinganj					0	16.17	0	8.74		
Block :: Mehnagar										

Existing Habitation Wise Infrastructure

State : UTTAR PRADESH
District : Azamgarh

Sl.No. (Vill.)	Name of Village (all villages as per census)	Census Code (2011)	Name of Habitation including main villages	Habitation Code	Existing LT Networks (in Kms)				Existing Distribution Transformers (DT)	Total (DT)
					Overhead	AB cable	Overhead	AB cable		
1	2	3	4	5	6	7	8	9	10	11
1	Supnahr Rudrapur	195772	USRAYIYA	195772-011	0	0.68	0	0.36		0
2	Pakaria Ranipur	195785	BHARAUTY	195785-002	0	0.73	0	0.39		0
3	Ganjor	195826	KOHRAN	195826-005	0	0.77	0	0.41		0
4	Ghurehtha	195884	EAST HB	195884-001	0	0.78	0	0.42		0
5	Usama Patti	195911	FATEPUR BHATOULI	195911-005	0	0	0	0		0
			REDDA	195911-009	0	0	0	0		0
6	Amari	195927	CHAUHAN BASTI	195927-002	0	0.87	0	0.47		0
			GOSAI PURA	195927-003	0	0.66	0	0.36		0
7	Gopalpur	195935	SARYA	195935-006	0	1.12	0	0.6	1 * (10 KVA (1 Ph))	1
8	Kishundaspur	195954	BHARAUTY	195954-001	0	0.75	0	0.41		0
9	Pitthu Patti	195955	BHARAUTY	195955-001	0	0.68	0	0.36		0
10	Roshanpur	195956	BHARAUTY	195956-001	0	0.68	0	0.36		0
Total - Mehnagar					0	7.72	0	4.14		
Block :: Mirzapur										
1	Mudiyar	194259	BHARAITI	194259-001	0	1.29	0	0.69	1 * (10 KVA (1 Ph))	1
2	Bakspur	194271	HARIJAN BASTI	194271-002	0	1.11	0	0.6		0
3	Chak Kamarali	194275	PANDIT BASTI	194275-004	0	1.12	0	0.6		0

Existing Habitation Wise Infrastructure

State : UTTAR PRADESH
District : Azamgarh

Sl.No. (Vill.)	Name of Village (all villages as per census)	Census Code (2011)	Name of Habitation including main villages	Habitation Code	Existing LT Networks (in Kms)				Existing Distribution Transformers (DT)	Total (DT)
					Overhead	AB cable	Overhead	AB cable		
1	2	3	4	5	6	7	8	9	10	11
4	Niyauj	194288	YADAV BASTI	194288-006	0	4.9	0	2.64	1 * (10 KVA (1 Ph)) + 1 * (16 KVA (1 Ph)) + 1 * (100 KVA (3 Ph))	3
5	Mirjapur	194294	H.B	194294-001	0	2.13	0	1.15	1 * (10 KVA (1 Ph))	1
			YADAV BASTI	194294-004	0	1.2	0	0.64		0
6	Gauspur	194322	YADAV BASTI	194322-003	0	1.48	0	0.8	1 * (10 KVA (1 Ph))	1
7	Sidha Sultanpur	194335	HARIJAN BASTI	194335-001	0	2.39	0	1.29	1 * (10 KVA (1 Ph))	1
8	Ahiripur	194349	YADAV BASTI	194349-002	0	2.08	0	1.12	1 * (10 KVA (1 Ph))	1
9	Tikariya Maddhu Khan	194351	HARIJAN BASTI	194351-002	0	1.48	0	0.8	1 * (10 KVA (1 Ph))	1
10	Kaudiya	194352	YADAV BASTI	194352-004	0	2.09	0	1.13	1 * (10 KVA (1 Ph))	1
11	Pavailadpur	194382	HARIJAN BASTI	194382-001	0	1.4	0	0.76	1 * (10 KVA (1 Ph))	1
12	Newada	194424	H.B	194424-001	0	1.61	0	0.87	1 * (10 KVA (1 Ph))	1
Total - Mirzapur					0	24.28	0	13.09		
Block :: Mohammadpur										
1	Parsurampur	194560	CHAUHAN BASTI	194560-002	0	1.21	0	0.65	1 * (10 KVA (1 Ph))	1
2	Nagawan	194575	CHAUHAN BASTI	194575-002	0	0.66	0	0.36		0
3	Masud Patti	194616	CHAUHAN BASTI	194616-001	0	1.66	0	0.9	1 * (10 KVA (1 Ph)) + 1 * (16 KVA (1 Ph))	2
4	Avak	194649	RAJBHAR BASTI	194649-006	0	0.98	0	0.53	1 * (10 KVA (1 Ph))	1

Existing Habitation Wise Infrastructure

State : UTTAR PRADESH
District : Azamgarh

Sl.No. (Vill.)	Name of Village (all villages as per census)	Census Code (2011)	Name of Habitation including main villages	Habitation Code	Existing LT Networks (in Kms)				Existing Distribution Transformers (DT)	Total (DT)
					Overhead	AB cable	Overhead	AB cable		
1	2	3	4	5	6	7	8	9	10	11
5	Koilari Bujurg	195760	CHAUHAN BASTI	195760-002	0	0.86	0	0.46		0
Total - Mohammadpur					0	5.37	0	2.9		
Block :: Palhani										
1	Bodhpur Or Godpur	193552	` GODHPUR	193552-001	0	1.81	0	0.97	1 * (10 KVA (1 Ph))	1
2	Aho Patti	193645	YB	193645-004	0	1.47	0	0.79		0
3	Karimuddinpur	193647	GENRAL BASTI	193647-003	0	1.86	0	1	1 * (10 KVA (1 Ph))	1
4	Belnadih	193670	RAJBHAR BASTI	193670-003	0	1.37	0	0.74		0
Total - Palhani					0	6.51	0	3.5		
Block :: Palhna										
1	Narsingh Pur	195413	HB	195413-002	0	1.3	0	0.7	1 * (10 KVA (1 Ph)) + 1 * (16 KVA (1 Ph))	2
2	Bhojpur	195418	BHAROUTI	195418-001	0	1.85	0	0.99	1 * (10 KVA (1 Ph)) + 1 * (16 KVA (1 Ph))	2
3	Sarai Khursu	195419	BHAROUTI	195419-001	0	1.33	0	0.71	1 * (10 KVA (1 Ph)) + 1 * (16 KVA (1 Ph))	2
4	Tarak Dih	195421	HB	195421-001	0	1.66	0	0.9	1 * (10 KVA (1 Ph)) + 1 * (16 KVA (1 Ph))	2
			TADAKDIH	195421-002	0	0.79	0	0.43	1 * (10 KVA (1 Ph)) + 1 * (16 KVA (1 Ph))	2
5	Lahuwa Kalan	195428	HB	195428-003	0	4.67	0	2.51	1 * (10 KVA (1 Ph)) + 3 * (16 KVA (1 Ph)) + 1 * (100 KVA (3 Ph))	5
6	Kota Khurd	195431	HB	195431-003	0	1.29	0	0.69	1 * (10 KVA (1 Ph)) + 1 * (16 KVA (1 Ph))	2
7	Avani	195606	BHAROUTI	195606-002	0	1.3	0	0.7	1 * (10 KVA (1 Ph)) + 1 * (16 KVA (1 Ph))	2

Existing Habitation Wise Infrastructure

State : UTTAR PRADESH
District : Azamgarh

Sl.No. (Vill.)	Name of Village (all villages as per census)	Census Code (2011)	Name of Habitation including main villages	Habitation Code	Existing LT Networks (in Kms)				Existing Distribution Transformers (DT)	Total (DT)
					Overhead	AB cable	Overhead	AB cable		
1	2	3	4	5	6	7	8	9	10	11
8	Karsara	195610	BHAROUTI	195610-001	0	1.34	0	0.72	1 * (10 KVA (1 Ph)) + 1 * (16 KVA (1 Ph))	2
9	Katai	195828	HB	195828-001	0	1.99	0	1.07	1 * (10 KVA (1 Ph)) + 1 * (16 KVA (1 Ph))	2
10	Pauni Kalan	195832	HB	195832-001	0	3.51	0	1.89	1 * (10 KVA (1 Ph)) + 2 * (16 KVA (1 Ph))	3
11	Khajuri	195833	BHAROUTI	195833-001	0	2.48	0	1.34	1 * (10 KVA (1 Ph)) + 2 * (16 KVA (1 Ph))	3
			HB	195833-002	0	1.22	0	0.66	1 * (10 KVA (1 Ph)) + 1 * (16 KVA (1 Ph))	2
12	Singhpur	195944	BHAROUTI	195944-002	0	1.3	0	0.7	1 * (10 KVA (1 Ph)) + 1 * (16 KVA (1 Ph))	2
13	Kahutara	195951	HB SOUTH	195951-003	0	1.91	0	1.03	1 * (10 KVA (1 Ph)) + 1 * (16 KVA (1 Ph))	2
14	Ismailpur Bharathipur	196061	BHAROUTI	196061-001	0	1.94	0	1.04	1 * (10 KVA (1 Ph)) + 1 * (16 KVA (1 Ph))	2
			HB	196061-002	0	1.22	0	0.66	1 * (10 KVA (1 Ph)) + 1 * (16 KVA (1 Ph))	2
Total - Palhna					0	31.1	0	16.74		
Block :: Pawai										
1	Nizampur	194713	BHARAUTI	194713-002	0	2.18	0	1.18	1 * (10 KVA (1 Ph)) + 1 * (16 KVA (1 Ph))	2
			H.B.P	194713-003	0	1.16	0	0.62	1 * (10 KVA (1 Ph))	1
2	Jaldipur	194771	KAWATAN	194771-009	0	2.46	0	1.32	1 * (10 KVA (1 Ph)) + 1 * (16 KVA (1 Ph))	2
3	Jafarpur Kathakan	194799	BHAR BASTI	194799-001	0	1.16	0	0.62	1 * (10 KVA (1 Ph))	1
4	Gondhana	194801	KALAN	194801-006	0	0	0	0		0
5	Ambari	194807	BAZAR	194807-002	0	1.22	0	0.66	1 * (10 KVA (1 Ph))	1
6	Kushaha	194821	BHARAUTI	194821-001	0	1.09	0	0.59	1 * (10 KVA (1 Ph))	1
Total - Pawai					0	9.27	0	4.99		

Existing Habitation Wise Infrastructure

State : UTTAR PRADESH
District : Azamgarh

Sl.No. (Vill.)	Name of Village (all villages as per census)	Census Code (2011)	Name of Habitation including main villages	Habitation Code	Existing LT Networks (in Kms)				Existing Distribution Transformers (DT)	Total (DT)
					Overhead	AB cable	Overhead	AB cable		
1	2	3	4	5	6	7	8	9	10	11
Block :: Phulpur										
1	Gandi	194979	AHIRAN	194979-001	0	0.87	0	0.47		0
2	Dighiya	194983	AHIRAN	194983-001	0	0.9	0	0.48		0
3	Palthi	195016	AHIRAN	195016-001	0	0.69	0	0.37		0
4	Kharsahan Khurd	195050	KOTIYA	195050-003	0	0.77	0	0.41		0
Total - Phulpur					0	3.23	0	1.73		
Block :: Rani Ki Sarai										
1	Hamidpur	193459	HAMEEDPUR	193459-001	0	1.18	0	0.64		0
2	Chuhaipur	193482	CHOOHAN PATTI	193482-001	0	1.37	0	0.74		0
3	Saifpur	193489	SAIFPUR	193489-002	0	3.24	0	1.74	1 * (10 KVA (1 Ph))	1
4	Shambhu Ayeema Or Shambhopu Ay	193496	MUSHER BASTI	193496-002	0	2.68	0	1.44	1 * (10 KVA (1 Ph))	1
5	Daudpur	193510	MUSLIM BASTI	193510-003	0	1.59	0	0.85		0
6	Deoka Patti	193512	DEWKAPATTI H BASTI	193512-001	0	0.82	0	0.44		0
7	Khaira	193517	YB	193517-003	0	1.39	0	0.75		0
8	Dharm Daspur	193518	DHARMDAS PUR	193518-001	0	1.6	0	0.86		0
9	Behta Lachhirampur Or Behta	193522	MUSLIM BASTI	193522-003	0	1.25	0	0.67		0

Existing Habitation Wise Infrastructure

State : UTTAR PRADESH
District : Azamgarh

Sl.No. (Vill.)	Name of Village (all villages as per census)	Census Code (2011)	Name of Habitation including main villages	Habitation Code	Existing LT Networks (in Kms)				Existing Distribution Transformers (DT)	Total (DT)
					Overhead	AB cable	Overhead	AB cable		
1	2	3	4	5	6	7	8	9	10	11
10	Jalaipur	193524	JALAIPUR	193524-002	0	2.7	0	1.46	1 * (10 KVA (1 Ph))	1
11	Shahi Garha	193537	MAURYA BASTI	193537-002	0	2.59	0	1.39	1 * (10 KVA (1 Ph))	1
12	Marantpur Kashi Ali	194444	MARUKHPUR KASHIMALI	194444-001	0	2.03	0	1.09	1 * (10 KVA (1 Ph))	1
13	Kotwalipur	194449	KOHAR BASTI	194449-001	0	1.33	0	0.71		0
14	Dodopur	194456	BHUNKI H BASTI	194456-001	0	1.96	0	1.06	1 * (10 KVA (1 Ph))	1
15	Telipur	194458	TELLI PUR	194458-002	0	1.25	0	0.67		0
16	Isapur	194480	ISHAPUR	194480-001	0	1.86	0	1	1 * (10 KVA (1 Ph))	1
17	Fariya	194495	FARIHA SARHEDPAR H BASTI	194495-004	0	3.06	0	1.65	1 * (10 KVA (1 Ph))	1
18	Gandhuvai	194498	MUSHAR BASTI	194498-003	0	3.29	0	1.77	1 * (10 KVA (1 Ph))	1
19	Khawajapur	194518	KHATIKAN	194518-002	0	1.86	0	1	1 * (10 KVA (1 Ph))	1
20	Katghar Babul	194522	KATGHAR BABOOL	194522-001	0	1.7	0	0.92	1 * (10 KVA (1 Ph))	1
21	Jamin Katghar	194527	HB SOUTH	194527-002	0	1.52	0	0.82		0
22	Sheewli	194536	UTTARI MUSLIM BASTI	194536-005	0	2.07	0	1.11	1 * (10 KVA (1 Ph))	1
Total - Rani Ki Sarai					0	42.34	0	22.78		

Block :: Sathiyaon

Existing Habitation Wise Infrastructure

State : UTTAR PRADESH
District : Azamgarh

Sl.No. (Vill.)	Name of Village (all villages as per census)	Census Code (2011)	Name of Habitation including main villages	Habitation Code	Existing LT Networks (in Kms)				Existing Distribution Transformers (DT)	Total (DT)
					Overhead	AB cable	Overhead	AB cable		
1	2	3	4	5	6	7	8	9	10	11
1	Bhamahaur	193805	HARIJAN BASTI SOUTH	193805-002	0	1.04	0	0.56		0
2	Gagahara	193810	MUSHAR BASTI	193810-007	0	1	0	0.54		0
3	Khemaupur	193843	HARIJAN BASTI EAST	193843-001	0	2.28	0	1.23	1 * (10 KVA (1 Ph))	1
4	Naizarpur	193853	RAJBHAR BASTI	193853-002	0	1.6	0	0.86	1 * (10 KVA (1 Ph))	1
Total - Sathiyaon					0	5.92	0	3.19		
Block :: Tahbarpur										
1	Madya Or Garya	193417	AHIRAN	193417-001	0	0.77	0	0.41	1 * (10 KVA (1 Ph))	1
2	Bhurramaq Bulpur Or Mori Makdu	193418	H BASTI NORTH	193418-004	0	1.04	0	0.56	1 * (10 KVA (1 Ph))	1
3	Ekma	193429	H BASTI	193429-003	0	1.24	0	0.67	1 * (10 KVA (1 Ph))	1
4	Nasiruddinpur	193431	H BASTI	193431-001	0	1.07	0	0.57	1 * (10 KVA (1 Ph))	1
5	Garhwa	194098	LOHRAUTI	194098-005	0	0.69	0	0.37	1 * (10 KVA (1 Ph))	1
6	Ohani	194111	H BASTI	194111-001	0	1.33	0	0.71	1 * (10 KVA (1 Ph))	1
7	Govindpur	194125	H BASTI	194125-003	0	1.14	0	0.62	1 * (10 KVA (1 Ph))	1
8	Kariyabar	194130	Y BASTI NORTH	194130-008	0	0.87	0	0.47	1 * (10 KVA (1 Ph))	1
9	Deoria	194147	FAKIRANA	194147-002	0	0.69	0	0.37	1 * (10 KVA (1 Ph))	1
10	Badsara Khalsa	194150	H BASTI	194150-002	0	1.09	0	0.59	1 * (10 KVA (1 Ph))	1

Existing Habitation Wise Infrastructure

State : UTTAR PRADESH
District : Azamgarh

Sl.No. (Vill.)	Name of Village (all villages as per census)	Census Code (2011)	Name of Habitation including main villages	Habitation Code	Existing LT Networks (in Kms)				Existing Distribution Transformers (DT)	Total (DT)
					Overhead	AB cable	Overhead	AB cable		
1	2	3	4	5	6	7	8	9	10	11
11	Merhi	194191	KAVTANA	194191-003	0	0.77	0	0.41	1 * (10 KVA (1 Ph))	1
12	Madhsiya	194196	CHAUHAN BASTI	194196-002	0	0.87	0	0.47	1 * (10 KVA (1 Ph))	1
13	Chakbari	194197	WEST PURA	194197-004	0	1.3	0	0.7	1 * (10 KVA (1 Ph))	1
14	Bhilauli Khalsa	194226	FAKIRANA	194226-002	0	0.82	0	0.44	1 * (10 KVA (1 Ph))	1
15	Chak Majnu	194229	MOTIDEH	194229-003	0	0.88	0	0.48	1 * (10 KVA (1 Ph))	1
Total - Tahbarpur					0	14.57	0	7.84		
Block :: Tarwa										
1	Barawa	195643	YADAV BASTI	195643-004	0	1.46	0	0.78	1 * (10 KVA (1 Ph))	1
2	Baholpur	195728	BHARAVATI	195728-002	0	0.64	0	0.34		0
3	Zoova	196002	MAROBPUR	196002-003	0	0	0	0		0
4	Bairodih	196026	YADAV BASTI	196026-002	0	0.59	0	0.32		0
5	Titara	196039	PANDETAN	196039-005	0	0.55	0	0.29		0
Total - Tarwa					0	3.24	0	1.73		
Block :: Thekma										
1	Belau	195178	HB.EAST	195178-003	0	1.73	0	0.93	1 * (10 KVA (1 Ph)) + 1 * (16 KVA (1 Ph))	2
2	Gopalpur	195210	GOPALPUR	195210-001	0	1.39	0	0.75	1 * (10 KVA (1 Ph)) + 1 * (16 KVA (1 Ph))	2
3	Para	195304	THAKUR BASTI	195304-008	0	1.13	0	0.61	1 * (10 KVA (1 Ph))	1
4	Bheera	195307	CHAUHAN BASTI	195307-003	0	1.29	0	0.69	1 * (10 KVA (1 Ph))	1

Existing Habitation Wise Infrastructure

State : UTTAR PRADESH
District : Azamgarh

Sl.No. (Vill.)	Name of Village (all villages as per census)	Census Code (2011)	Name of Habitation including main villages	Habitation Code	Existing LT Networks (in Kms)				Existing Distribution Transformers (DT)	Total (DT)
					Overhead	AB cable	Overhead	AB cable		
1	2	3	4	5	6	7	8	9	10	11
5	Chhattar Pur	195309	MUSLIM BASTI	195309-004	0	1.35	0	0.73	1 * (10 KVA (1 Ph)) + 1 * (16 KVA (1 Ph))	2
Total - Thekma					0	6.89	0	3.71		
Summary										
Ahiraula					0	3.9	0	2.1		
Atraulia					0	4.51	0	2.42		
Azmatgarh					0	6.34	0	3.41		
Bilariyaganj					0	4.43	0	2.39		
Haraiya					0	4.81	0	2.59		
Jahanaganj					0	51.12	0	27.56		
Koilsa					0	11.48	0	6.19		
Lalganj					0	16.82	0	9.08		
Mahrajganj					0	5.86	0	3.16		
Martinganj					0	16.17	0	8.74		
Mehnagar					0	7.72	0	4.14		
Mirzapur					0	24.28	0	13.09		
Mohammadpur					0	5.37	0	2.9		
Palhani					0	6.51	0	3.5		
Palhna					0	31.1	0	16.74		
Pawai					0	9.27	0	4.99		
Phulpur					0	3.23	0	1.73		

Existing Habitation Wise Infrastructure

State : UTTAR PRADESH
District : Azamgarh

Sl.No. (Vill.)	Name of Village (all villages as per census)	Census Code (2011)	Name of Habitation including main villages	Habitation Code	Existing LT Networks (in Kms)				Existing Distribution Transformers (DT)	Total (DT)
					Overhead	AB cable	Overhead	AB cable		
1	2	3	4	5	6	7	8	9	10	11
Rani Ki Sarai					0	42.34	0	22.78		
Sathiyaon					0	5.92	0	3.19		
Tahbarpur					0	14.57	0	7.84		
Tarwa					0	3.24	0	1.73		
Thekma					0	6.89	0	3.71		
Grand Total					0	285.88	0	153.98		

Village Wise/Habitation Proposed Works

State : UTTAR PRADESH
District : Azamgarh

Sl.No. (Vill.)	Name of Village (all villages as per census)	Census Code (2011)	Name of Habitation including main villages	Habitation Code	Works Type	Item	Line Length(Kms)	DTR(Nos)	Earthing(Kms)
1	2	3	4	5	6	7	8	9	10
Block :: Ahiraula									
1	Bilari Lakhanpur	192432	THAKURANA	192432-009	New 11 KV Line	11KV Weasel Conductor	0.3	0	0
						25 KVA (3 Ph)	0	1	0
					New ABC Line	2X25+1X16	0.27	0	0
						3X50+1X35+1X16	0.12	0	0
2	Pakhanpur	194845	KUMHAR BASTI	194845-002	New 11 KV Line	11KV Weasel Conductor	0.3	0	0
						25 KVA (3 Ph)	0	1	0
					New ABC Line	2X25+1X16	0.28	0	0
						3X50+1X35+1X16	0.12	0	0
3	Pahijan Rampur	194847	RAMPUR	194847-002	New 11 KV Line	11KV Weasel Conductor	0.34	0	0
						25 KVA (3 Ph)	0	1	0
					New ABC Line	2X25+1X16	0.31	0	0
						3X50+1X35+1X16	0.13	0	0
4	Khuraso	194889	KUMHAR BASTI	194889-004	New 11 KV Line	11KV Weasel Conductor	0.35	0	0
						25 KVA (3 Ph)	0	1	0
					New ABC Line	2X25+1X16	0.31	0	0
						3X50+1X35+1X16	0.13	0	0
Block :: Atraulia									
5	Lohra	191955	DIHWA	191955-027	New 11 KV Line	11KV Weasel Conductor	0.34	0	0
						25 KVA (3 Ph)	0	1	0
					New ABC Line	2X25+1X16	0.3	0	0

Village Wise/Habitation Proposed Works

State : UTTAR PRADESH
District : Azamgarh

Sl.No. (Vill.)	Name of Village (all villages as per census)	Census Code (2011)	Name of Habitation including main villages	Habitation Code	Works Type	Item	Line Length(Kms)	DTR(Nos)	Earthing(Kms)
1	2	3	4	5	6	7	8	9	10
						3X50+1X35+1X16	0.13	0	0
6	Bhikh Pur	191971	NORTH KA PURA	191971-002	New 11 KV Line	11KV Weasel Conductor	0.32	0	0
						25 KVA (3 Ph)	0	1	0
					New ABC Line	2X25+1X16	0.29	0	0
						3X50+1X35+1X16	0.12	0	0
7	Dhaurahra	192015	YB	192015-004	New 11 KV Line	11KV Weasel Conductor	0.3	0	0
						25 KVA (3 Ph)	0	1	0
					New ABC Line	2X25+1X16	0.28	0	0
						3X50+1X35+1X16	0.12	0	0
8	Ataraulia	192039	YB	192039-006	New 11 KV Line	11KV Weasel Conductor	0.32	0	0
						25 KVA (3 Ph)	0	1	0
					New ABC Line	2X25+1X16	0.29	0	0
						3X50+1X35+1X16	0.12	0	0
9	Selhra Patti	192057	YB	192057-005	New 11 KV Line	11KV Weasel Conductor	0.32	0	0
						25 KVA (3 Ph)	0	1	0
					New ABC Line	2X25+1X16	0.29	0	0
						3X50+1X35+1X16	0.12	0	0
Block :: Azmatgarh									
10	Bankatiya	193185	KOIRANA	193185-003	New 11 KV Line	11KV Weasel Conductor	0.3	0	0
						25 KVA (3 Ph)	0	1	0

Village Wise/Habitation Proposed Works

State : UTTAR PRADESH
District : Azamgarh

Sl.No. (Vill.)	Name of Village (all villages as per census)	Census Code (2011)	Name of Habitation including main villages	Habitation Code	Works Type	Item	Line Length(Kms)	DTR(Nos)	Earthing(Kms)
1	2	3	4	5	6	7	8	9	10
					New ABC Line	2X25+1X16	0.27	0	0
						3X50+1X35+1X16	0.12	0	0
11	Meghai Khas	193242	YB	193242-005	New 11 KV Line	11KV Weasel Conductor	0.3	0	0
						25 KVA (3 Ph)	0	1	0
					New ABC Line	2X25+1X16	0.27	0	0
						3X50+1X35+1X16	0.12	0	0
12	Chunugpar	193260	YB	193260-004	New 11 KV Line	11KV Weasel Conductor	0.33	0	0
						25 KVA (3 Ph)	0	1	0
					New ABC Line	2X25+1X16	0.22	0	0
						3X50+1X35+1X16	0.12	0	0
13	Anjan Shaheed	193313	BAZAR	193313-002	New 11 KV Line	11KV Weasel Conductor	0.36	0	0
						25 KVA (3 Ph)	0	1	0
					New ABC Line	2X25+1X16	0.32	0	0
						3X50+1X35+1X16	0.13	0	0
14	Chhattarpur Khushhal	193325	YB	193325-003	New 11 KV Line	11KV Weasel Conductor	0.3	0	0
						25 KVA (3 Ph)	0	1	0
					New ABC Line	2X25+1X16	0.27	0	0
						3X50+1X35+1X16	0.12	0	0
15	Shahpur Newada	193332	YB	193332-003	New 11 KV Line	11KV Weasel Conductor	0.33	0	0
						25 KVA (3 Ph)	0	1	0

Village Wise/Habitation Proposed Works

State : UTTAR PRADESH
District : Azamgarh

Sl.No. (Vill.)	Name of Village (all villages as per census)	Census Code (2011)	Name of Habitation including main villages	Habitation Code	Works Type	Item	Line Length(Kms)	DTR(Nos)	Earthing(Kms)
1	2	3	4	5	6	7	8	9	10
					New ABC Line	2X25+1X16	0.22	0	0
						3X50+1X35+1X16	0.12	0	0
16	Mahawatgarh	193392	YB	193392-006	New 11 KV Line	11KV Weasel Conductor	0.32	0	0
						25 KVA (3 Ph)	0	1	0
					New ABC Line	2X25+1X16	0.29	0	0
						3X50+1X35+1X16	0.12	0	0
Block :: Bilariyaganj									
17	Jagmalpur	192936	HB E	192936-001	New 11 KV Line	11KV Weasel Conductor	0.34	0	0
						25 KVA (3 Ph)	0	1	0
					New ABC Line	2X25+1X16	0.31	0	0
						3X50+1X35+1X16	0.13	0	0
18	Madhnapar	193001	RAMPUR	193001-005	New 11 KV Line	11KV Weasel Conductor	0.35	0	0
						25 KVA (3 Ph)	0	1	0
					New ABC Line	2X25+1X16	0.31	0	0
						3X50+1X35+1X16	0.13	0	0
19	Bindwal	193021	BAZAR	193021-001	New 11 KV Line	11KV Weasel Conductor	0.32	0	0
						25 KVA (3 Ph)	0	1	0
					New ABC Line	2X25+1X16	0.29	0	0
						3X50+1X35+1X16	0.12	0	0
20	Jolhapur	193044	SONKAR BASTI	193044-009	New 11 KV Line	11KV Weasel Conductor	0.33	0	0
						25 KVA (3 Ph)	0	1	0

Village Wise/Habitation Proposed Works

State : UTTAR PRADESH
District : Azamgarh

Sl.No. (Vill.)	Name of Village (all villages as per census)	Census Code (2011)	Name of Habitation including main villages	Habitation Code	Works Type	Item	Line Length(Kms)	DTR(Nos)	Earthing(Kms)
1	2	3	4	5	6	7	8	9	10
					New ABC Line	2X25+1X16	0.22	0	0
						3X50+1X35+1X16	0.12	0	0
Block :: Haraiya									
21	Turkauli	192763	YADAV BASTI	192763-006	New 11 KV Line	11KV Weasel Conductor	0.3	0	0
						25 KVA (3 Ph)	0	1	0
					New ABC Line	2X25+1X16	0.27	0	0
						3X50+1X35+1X16	0.12	0	0
22	Khetapur	192790	YADAV BASTI	192790-005	New 11 KV Line	11KV Weasel Conductor	0.38	0	0
						25 KVA (3 Ph)	0	1	0
					New ABC Line	2X25+1X16	0.33	0	0
						3X50+1X35+1X16	0.14	0	0
23	Parsiya	192797	YADAV BASTI	192797-004	New 11 KV Line	11KV Weasel Conductor	0.32	0	0
						25 KVA (3 Ph)	0	1	0
					New ABC Line	2X25+1X16	0.29	0	0
						3X50+1X35+1X16	0.12	0	0
24	Bardiha	192805	H B EAST	192805-002	New 11 KV Line	11KV Weasel Conductor	0.58	0	0
						25 KVA (3 Ph)	0	2	0
					New ABC Line	2X25+1X16	0.53	0	0
						3X50+1X35+1X16	0.25	0	0
25	Bankata Urf Bazargosain	192839	YADAV BASTI	192839-006	New 11 KV Line	11KV Weasel Conductor	0.38	0	0

Village Wise/Habitation Proposed Works

State : UTTAR PRADESH
District : Azamgarh

Sl.No. (Vill.)	Name of Village (all villages as per census)	Census Code (2011)	Name of Habitation including main villages	Habitation Code	Works Type	Item	Line Length(Kms)	DTR(Nos)	Earthing(Kms)
1	2	3	4	5	6	7	8	9	10
					New ABC Line	25 KVA (3 Ph)	0	1	0
						2X25+1X16	0.34	0	0
						3X50+1X35+1X16	0.14	0	0
26	Harraiya	192840	H B EAST	192840-006	New 11 KV Line	11KV Weasel Conductor	0.32	0	0
						25 KVA (3 Ph)	0	1	0
					New ABC Line	2X25+1X16	0.29	0	0
						3X50+1X35+1X16	0.14	0	0
Block :: Jahanaganj									
27	Koilarai Khurd	193877	KHODADPUR	193877-001	New 11 KV Line	11KV Weasel Conductor	0.63	0	0
						25 KVA (3 Ph)	0	2	0
					New ABC Line	2X25+1X16	0.57	0	0
						3X50+1X35+1X16	0.24	0	0
28	Karaut	193901	HB NORTH	193901-005	New 11 KV Line	11KV Weasel Conductor	0.35	0	0
						25 KVA (3 Ph)	0	1	0
					New ABC Line	2X25+1X16	0.31	0	0
						3X50+1X35+1X16	0.13	0	0
29	Mittupur	193919	CHAUHAN BASTI	193919-001	New 11 KV Line	11KV Weasel Conductor	0.99	0	0
						25 KVA (3 Ph)	0	3	0
					New ABC Line	2X25+1X16	0.89	0	0
						3X50+1X35+1X16	0.37	0	0

Village Wise/Habitation Proposed Works

State : UTTAR PRADESH
District : Azamgarh

Sl.No. (Vill.)	Name of Village (all villages as per census)	Census Code (2011)	Name of Habitation including main villages	Habitation Code	Works Type	Item	Line Length(Kms)	DTR(Nos)	Earthing(Kms)
1	2	3	4	5	6	7	8	9	10
30	Sevata	193923	SAREEKAT CHAK KHASH	193923-001	New 11 KV Line	11KV Weasel Conductor	0.7	0	0
						25 KVA (3 Ph)	0	2	0
					New ABC Line	2X25+1X16	0.62	0	0
						3X50+1X35+1X16	0.26	0	0
31	Zahid Chak	193930	MATIYANA	193930-003	New 11 KV Line	11KV Weasel Conductor	0.85	0	0
						25 KVA (3 Ph)	0	3	0
					New ABC Line	2X25+1X16	0.79	0	0
						3X50+1X35+1X16	0.37	0	0
			GAURSAR	193930-004	New 11 KV Line	11KV Weasel Conductor	0.6	0	0
						25 KVA (3 Ph)	0	2	0
					New ABC Line	2X25+1X16	0.55	0	0
						3X50+1X35+1X16	0.26	0	0
32	Kannayala Karanhat	193954	YB	193954-004	New 11 KV Line	11KV Weasel Conductor	0.62	0	0
						25 KVA (3 Ph)	0	2	0
					New ABC Line	2X25+1X16	0.57	0	0
						3X50+1X35+1X16	0.24	0	0
33	Dharawara	193959	HB NORTH	193959-003	New 11 KV Line	11KV Weasel Conductor	0.64	0	0
						25 KVA (3 Ph)	0	2	0
					New ABC Line	2X25+1X16	0.58	0	0
						3X50+1X35+1X16	0.24	0	0

Village Wise/Habitation Proposed Works

State : UTTAR PRADESH
District : Azamgarh

Sl.No. (Vill.)	Name of Village (all villages as per census)	Census Code (2011)	Name of Habitation including main villages	Habitation Code	Works Type	Item	Line Length(Kms)	DTR(Nos)	Earthing(Kms)
1	2	3	4	5	6	7	8	9	10
34	Jogapur	193986	Jogapur	193986-001	New 11 KV Line	11KV Weasel Conductor	0.65	0	0
						25 KVA (3 Ph)	0	2	0
					New ABC Line	2X25+1X16	0.59	0	0
						3X50+1X35+1X16	0.24	0	0
35	Laxmipur	193999	LAKHANTAND	193999-001	New 11 KV Line	11KV Weasel Conductor	0.64	0	0
						25 KVA (3 Ph)	0	2	0
					New ABC Line	2X25+1X16	0.58	0	0
						3X50+1X35+1X16	0.24	0	0
36	Badasar Or Kadasar	194022	BAHAUDDINPU R	194022-001	New 11 KV Line	11KV Weasel Conductor	0.38	0	0
						25 KVA (3 Ph)	0	1	0
					New ABC Line	2X25+1X16	0.34	0	0
						3X50+1X35+1X16	0.14	0	0
37	Masuba	194027	MAMARKHAPU R KHASH	194027-001	New 11 KV Line	11KV Weasel Conductor	0.97	0	0
						25 KVA (3 Ph)	0	3	0
					New ABC Line	2X25+1X16	0.88	0	0
						3X50+1X35+1X16	0.37	0	0
38	Khanpur	194028	KATGHAR ISMAILE	194028-001	New 11 KV Line	11KV Weasel Conductor	0.66	0	0
						25 KVA (3 Ph)	0	2	0
					New ABC Line	2X25+1X16	0.6	0	0

Village Wise/Habitation Proposed Works

State : UTTAR PRADESH
District : Azamgarh

Sl.No. (Vill.)	Name of Village (all villages as per census)	Census Code (2011)	Name of Habitation including main villages	Habitation Code	Works Type	Item	Line Length(Kms)	DTR(Nos)	Earthing(Kms)
1	2	3	4	5	6	7	8	9	10
						3X50+1X35+1X16	0.25	0	0
39	Haripur Khurd Or Serpur Khurd	194068	CHAUHAN BASTI	194068-001	New 11 KV Line	11KV Weasel Conductor	0.34	0	0
						25 KVA (3 Ph)	0	1	0
					New ABC Line	2X25+1X16	0.31	0	0
						3X50+1X35+1X16	0.13	0	0
40	Telahua Chakvali	194081	SURAJPUR	194081-001	New 11 KV Line	11KV Weasel Conductor	1	0	0
						25 KVA (3 Ph)	0	3	0
					New ABC Line	2X25+1X16	0.9	0	0
						3X50+1X35+1X16	0.37	0	0
41	Barahatir Jagdishpur (CT)	194085	BAJAR	194085-001	New 11 KV Line	11KV Weasel Conductor	3.36	0	0
						25 KVA (3 Ph)	0	2	0
						63 KVA (3 Ph)	0	4	0
					New ABC Line	2X25+1X16	2.82	0	0
						3X50+1X35+1X16	1.08	0	0
			CHAUHAN BASTI	194085-003	New 11 KV Line	11KV Weasel Conductor	0.67	0	0
						25 KVA (3 Ph)	0	2	0
					New ABC Line	2X25+1X16	0.6	0	0
						3X50+1X35+1X16	0.25	0	0

Block :: Koilsa

Village Wise/Habitation Proposed Works

State : UTTAR PRADESH
District : Azamgarh

Sl.No. (Vill.)	Name of Village (all villages as per census)	Census Code (2011)	Name of Habitation including main villages	Habitation Code	Works Type	Item	Line Length(Kms)	DTR(Nos)	Earthing(Kms)
1	2	3	4	5	6	7	8	9	10
42	Baragaon	192153	PANDAY KA PURA	192153-003	New 11 KV Line	11KV Weasel Conductor	0.3	0	0
						25 KVA (3 Ph)	0	1	0
					New ABC Line	2X25+1X16	0.27	0	0
						3X50+1X35+1X16	0.12	0	0
43	Bhilampur Chhapara	192158	MUSLIM BASTI	192158-006	New 11 KV Line	11KV Weasel Conductor	0.63	0	0
						25 KVA (3 Ph)	0	2	0
					New ABC Line	2X25+1X16	0.57	0	0
						3X50+1X35+1X16	0.24	0	0
44	Burhanpur	192194	BAZAR	192194-001	New 11 KV Line	11KV Weasel Conductor	0.63	0	0
						25 KVA (3 Ph)	0	2	0
					New ABC Line	2X25+1X16	0.57	0	0
						3X50+1X35+1X16	0.24	0	0
45	Koilsa	192199	MUSLIM BASTI	192199-003	New 11 KV Line	11KV Weasel Conductor	0.31	0	0
						25 KVA (3 Ph)	0	1	0
					New ABC Line	2X25+1X16	0.28	0	0
						3X50+1X35+1X16	0.12	0	0
46	Ishwarpur Pawni	192200	BAZAR	192200-001	New 11 KV Line	11KV Weasel Conductor	0.86	0	0
						25 KVA (3 Ph)	0	2	0
					New ABC Line	2X25+1X16	0.74	0	0
						3X50+1X35+1X16	0.3	0	0

Village Wise/Habitation Proposed Works

State : UTTAR PRADESH
District : Azamgarh

Sl.No. (Vill.)	Name of Village (all villages as per census)	Census Code (2011)	Name of Habitation including main villages	Habitation Code	Works Type	Item	Line Length(Kms)	DTR(Nos)	Earthing(Kms)
1	2	3	4	5	6	7	8	9	10
47	Ekdangi	192216	MUSLIM BASTI	192216-003	New 11 KV Line	11KV Weasel Conductor	0.3	0	0
						25 KVA (3 Ph)	0	1	0
					New ABC Line	2X25+1X16	0.27	0	0
						3X50+1X35+1X16	0.12	0	0
48	Bhedaura	192242	TAKIYA	192242-006	New 11 KV Line	11KV Weasel Conductor	0.3	0	0
						25 KVA (3 Ph)	0	1	0
					New ABC Line	2X25+1X16	0.27	0	0
						3X50+1X35+1X16	0.12	0	0
49	Bhimakol	192277	PANDAY KA PURA	192277-007	New 11 KV Line	11KV Weasel Conductor	0.31	0	0
						25 KVA (3 Ph)	0	1	0
					New ABC Line	2X25+1X16	0.28	0	0
						3X50+1X35+1X16	0.12	0	0
Block :: Lalganj									
50	Tikar Garh	195359	MUSLIM BASTI	195359-002	New 11 KV Line	11KV Weasel Conductor	0.36	0	0
						25 KVA (3 Ph)	0	1	0
					New ABC Line	3X50+1X35+1X16	0.13	0	0
						2X25+1X16	0.32	0	0
51	Mehnazpur	195385	MEHNAJPUR	195385-001	New 11 KV Line	11KV Weasel Conductor	2.46	0	0
						25 KVA (3 Ph)	0	2	0
						63 KVA (3 Ph)	0	4	0

Village Wise/Habitation Proposed Works

State : UTTAR PRADESH
District : Azamgarh

Sl.No. (Vill.)	Name of Village (all villages as per census)	Census Code (2011)	Name of Habitation including main villages	Habitation Code	Works Type	Item	Line Length(Kms)	DTR(Nos)	Earthing(Kms)
1	2	3	4	5	6	7	8	9	10
					New ABC Line	3X50+1X35+1X16	0.86	0	0
						2X25+1X16	2.15	0	0
52	Narayanpur Nevada	195494	MUSLIM BASTI	195494-003	New 11 KV Line	11KV Weasel Conductor	0.34	0	0
						25 KVA (3 Ph)	0	1	0
					New ABC Line	3X50+1X35+1X16	0.13	0	0
						2X25+1X16	0.31	0	0
53	Zirikpur	195513	CHAUHAN	195513-006	New 11 KV Line	11KV Weasel Conductor	0.86	0	0
						25 KVA (3 Ph)	0	3	0
					New ABC Line	3X50+1X35+1X16	0.37	0	0
						2X25+1X16	0.8	0	0
			H B	195513-007	New 11 KV Line	11KV Weasel Conductor	1.16	0	0
						25 KVA (3 Ph)	0	4	0
					New ABC Line	3X50+1X35+1X16	0.5	0	0
						2X25+1X16	1.07	0	0
			NONIPUR	195513-008	New 11 KV Line	11KV Weasel Conductor	0.77	0	0
						25 KVA (3 Ph)	0	2	0
					New ABC Line	3X50+1X35+1X16	0.34	0	0
						2X25+1X16	0.68	0	0
			YADAV BASTI	195513-009	New 11 KV Line	11KV Weasel Conductor	0.86	0	0
						25 KVA (3 Ph)	0	3	0

Village Wise/Habitation Proposed Works

State : UTTAR PRADESH
District : Azamgarh

Sl.No. (Vill.)	Name of Village (all villages as per census)	Census Code (2011)	Name of Habitation including main villages	Habitation Code	Works Type	Item	Line Length(Kms)	DTR(Nos)	Earthing(Kms)
1	2	3	4	5	6	7	8	9	10
					New ABC Line	3X50+1X35+1X16	0.37	0	0
						2X25+1X16	0.8	0	0
54	Srikantpur	195515	YB	195515-004	New 11 KV Line	11KV Weasel Conductor	0.35	0	0
						25 KVA (3 Ph)	0	1	0
					New ABC Line	3X50+1X35+1X16	0.13	0	0
						2X25+1X16	0.31	0	0
55	Agahata	195523	YB	195523-005	New 11 KV Line	11KV Weasel Conductor	0.34	0	0
						25 KVA (3 Ph)	0	1	0
					New ABC Line	3X50+1X35+1X16	0.13	0	0
						2X25+1X16	0.31	0	0
Block :: Mahrajganj									
56	Dewara Kadim	192453	KHANGERPUR	192453-003	New 11 KV Line	11KV Weasel Conductor	0.64	0	0
						25 KVA (3 Ph)	0	2	0
					New ABC Line	2X25+1X16	0.58	0	0
						3X50+1X35+1X16	0.24	0	0
57	Barauli	192564	RAJBHAR BASTI	192564-002	New 11 KV Line	11KV Weasel Conductor	0.3	0	0
						25 KVA (3 Ph)	0	1	0
					New ABC Line	2X25+1X16	0.27	0	0
						3X50+1X35+1X16	0.12	0	0
58	Narottampur Suryman	192633	RAJBHAR BASTI	192633-002	New 11 KV Line	11KV Weasel Conductor	0.3	0	0

Village Wise/Habitation Proposed Works

State : UTTAR PRADESH
District : Azamgarh

Sl.No. (Vill.)	Name of Village (all villages as per census)	Census Code (2011)	Name of Habitation including main villages	Habitation Code	Works Type	Item	Line Length(Kms)	DTR(Nos)	Earthing(Kms)
1	2	3	4	5	6	7	8	9	10
						25 KVA (3 Ph)	0	1	0
					New ABC Line	2X25+1X16	0.28	0	0
						3X50+1X35+1X16	0.12	0	0
59	Mirpur Navey	192646	MEERPUR NAVE	192646-001	New 11 KV Line	11KV Weasel Conductor	0.3	0	0
						25 KVA (3 Ph)	0	1	0
					New ABC Line	2X25+1X16	0.27	0	0
						3X50+1X35+1X16	0.11	0	0
60	Bhitehara	192653	RAJBHAR BASTI	192653-004	New 11 KV Line	11KV Weasel Conductor	0.29	0	0
						25 KVA (3 Ph)	0	1	0
					New ABC Line	2X25+1X16	0.27	0	0
						3X50+1X35+1X16	0.11	0	0
61	Baidra	192655	RAJBHAR BASTI	192655-001	New 11 KV Line	11KV Weasel Conductor	0.31	0	0
						25 KVA (3 Ph)	0	1	0
					New ABC Line	2X25+1X16	0.28	0	0
						3X50+1X35+1X16	0.12	0	0
62	Chandpur Bhataura	192689	RAJBHAR BASTI	192689-004	New 11 KV Line	11KV Weasel Conductor	0.29	0	0
						25 KVA (3 Ph)	0	1	0
					New ABC Line	2X25+1X16	0.27	0	0
						3X50+1X35+1X16	0.11	0	0

Block :: Martinganj

Village Wise/Habitation Proposed Works

State : UTTAR PRADESH
District : Azamgarh

Sl.No. (Vill.)	Name of Village (all villages as per census)	Census Code (2011)	Name of Habitation including main villages	Habitation Code	Works Type	Item	Line Length(Kms)	DTR(Nos)	Earthing(Kms)
1	2	3	4	5	6	7	8	9	10
63	Pipraula	195077	YB	195077-005	New 11 KV Line	11KV Weasel Conductor	0.3	0	0
						25 KVA (3 Ph)	0	1	0
					New ABC Line	2X25+1X16	0.28	0	0
						3X50+1X35+1X16	0.12	0	0
64	Karuie	195078	BANPURWA	195078-001	New 11 KV Line	11KV Weasel Conductor	0.32	0	0
						25 KVA (3 Ph)	0	1	0
					New ABC Line	2X25+1X16	0.29	0	0
						3X50+1X35+1X16	0.12	0	0
65	Purandarpur	195088	YB	195088-008	New 11 KV Line	11KV Weasel Conductor	0.3	0	0
						25 KVA (3 Ph)	0	1	0
					New ABC Line	2X25+1X16	0.28	0	0
						3X50+1X35+1X16	0.12	0	0
66	Para	195105	RAJBHAR 2	195105-005	New 11 KV Line	11KV Weasel Conductor	0.32	0	0
						25 KVA (3 Ph)	0	1	0
					New ABC Line	2X25+1X16	0.29	0	0
						3X50+1X35+1X16	0.12	0	0
67	Basti Kapuri	195115	YB	195115-009	New 11 KV Line	11KV Weasel Conductor	0.31	0	0
						25 KVA (3 Ph)	0	1	0
					New ABC Line	2X25+1X16	0.28	0	0
						3X50+1X35+1X16	0.12	0	0
68	Narwey	195117	YADAV BASTI	195117-006	New 11 KV Line	11KV Weasel Conductor	0.32	0	0

Village Wise/Habitation Proposed Works

State : UTTAR PRADESH
District : Azamgarh

Sl.No. (Vill.)	Name of Village (all villages as per census)	Census Code (2011)	Name of Habitation including main villages	Habitation Code	Works Type	Item	Line Length(Kms)	DTR(Nos)	Earthing(Kms)
1	2	3	4	5	6	7	8	9	10
						25 KVA (3 Ph)	0	1	0
					New ABC Line	2X25+1X16	0.29	0	0
						3X50+1X35+1X16	0.12	0	0
69	Nikasipur	195127	YB	195127-004	New 11 KV Line	11KV Weasel Conductor	0.3	0	0
						25 KVA (3 Ph)	0	1	0
					New ABC Line	2X25+1X16	0.28	0	0
						3X50+1X35+1X16	0.12	0	0
70	Bangaon	195131	RAJBHAR BASTI SOUTH	195131-004	New 11 KV Line	11KV Weasel Conductor	0.98	0	0
						25 KVA (3 Ph)	0	3	0
					New ABC Line	2X25+1X16	0.89	0	0
						3X50+1X35+1X16	0.37	0	0
			YB	195131-005	New 11 KV Line	11KV Weasel Conductor	0.32	0	0
						25 KVA (3 Ph)	0	1	0
					New ABC Line	2X25+1X16	0.29	0	0
						3X50+1X35+1X16	0.12	0	0
71	Sonhara	195135	YB	195135-003	New 11 KV Line	11KV Weasel Conductor	0.32	0	0
						25 KVA (3 Ph)	0	1	0
					New ABC Line	2X25+1X16	0.29	0	0
						3X50+1X35+1X16	0.12	0	0
72	Ajaur	195136	YB	195136-005	New 11 KV Line	11KV Weasel Conductor	0.31	0	0

Village Wise/Habitation Proposed Works

State : UTTAR PRADESH
District : Azamgarh

Sl.No. (Vill.)	Name of Village (all villages as per census)	Census Code (2011)	Name of Habitation including main villages	Habitation Code	Works Type	Item	Line Length(Kms)	DTR(Nos)	Earthing(Kms)
1	2	3	4	5	6	7	8	9	10
						25 KVA (3 Ph)	0	1	0
					New ABC Line	2X25+1X16	0.28	0	0
						3X50+1X35+1X16	0.12	0	0
73	Barauna	195144	YB	195144-007	New 11 KV Line	11KV Weasel Conductor	0.3	0	0
						25 KVA (3 Ph)	0	1	0
					New ABC Line	2X25+1X16	0.28	0	0
						3X50+1X35+1X16	0.12	0	0
74	Lasara Khurd	195167	YB	195167-006	New 11 KV Line	11KV Weasel Conductor	0.35	0	0
						25 KVA (3 Ph)	0	1	0
					New ABC Line	2X25+1X16	0.31	0	0
						3X50+1X35+1X16	0.13	0	0
75	Khrauli	195171	YB	195171-007	New 11 KV Line	11KV Weasel Conductor	0.33	0	0
						25 KVA (3 Ph)	0	1	0
					New ABC Line	2X25+1X16	0.22	0	0
						3X50+1X35+1X16	0.13	0	0
76	Kumbha	195175	YB	195175-006	New 11 KV Line	11KV Weasel Conductor	0.63	0	0
						25 KVA (3 Ph)	0	2	0
					New ABC Line	2X25+1X16	0.57	0	0
						3X50+1X35+1X16	0.24	0	0

Block :: Mehnagar

Village Wise/Habitation Proposed Works

State : UTTAR PRADESH
District : Azamgarh

Sl.No. (Vill.)	Name of Village (all villages as per census)	Census Code (2011)	Name of Habitation including main villages	Habitation Code	Works Type	Item	Line Length(Kms)	DTR(Nos)	Earthing(Kms)
1	2	3	4	5	6	7	8	9	10
77	Supnaha Rudrapur	195772	USRAYIYA	195772-011	New 11 KV Line	11KV Weasel Conductor	0.3	0	0
						25 KVA (3 Ph)	0	1	0
					New ABC Line	3X50+1X35+1X16	0.12	0	0
						2X25+1X16	0.27	0	0
78	Pakaria Ranipur	195785	BHARAUTY	195785-002	New 11 KV Line	11KV Weasel Conductor	0.3	0	0
						25 KVA (3 Ph)	0	1	0
					New ABC Line	3X50+1X35+1X16	0.12	0	0
						2X25+1X16	0.28	0	0
79	Ganjor	195826	KOHRAN	195826-005	New 11 KV Line	11KV Weasel Conductor	0.3	0	0
						25 KVA (3 Ph)	0	1	0
					New ABC Line	3X50+1X35+1X16	0.12	0	0
						2X25+1X16	0.28	0	0
80	Ghurehtha	195884	EAST HB	195884-001	New 11 KV Line	11KV Weasel Conductor	0.31	0	0
						25 KVA (3 Ph)	0	1	0
					New ABC Line	3X50+1X35+1X16	0.12	0	0
						2X25+1X16	0.28	0	0
81	Usama Patti	195911	FATEPUR BHATOULI	195911-005	New 11 KV Line	11KV Weasel Conductor	0.32	0	0
						25 KVA (3 Ph)	0	1	0
					New ABC Line	3X50+1X35+1X16	0.14	0	0
						2X25+1X16	0.29	0	0

Village Wise/Habitation Proposed Works

State : UTTAR PRADESH
District : Azamgarh

Sl.No. (Vill.)	Name of Village (all villages as per census)	Census Code (2011)	Name of Habitation including main villages	Habitation Code	Works Type	Item	Line Length(Kms)	DTR(Nos)	Earthing(Kms)
1	2	3	4	5	6	7	8	9	10
			REDDA	195911-009	New 11 KV Line	11KV Weasel Conductor	0.6	0	0
						25 KVA (3 Ph)	0	2	0
					New ABC Line	3X50+1X35+1X16	0.26	0	0
						2X25+1X16	0.55	0	0
82	Amari	195927	CHAUHAN BASTI	195927-002	New 11 KV Line	11KV Weasel Conductor	0.32	0	0
						25 KVA (3 Ph)	0	1	0
					New ABC Line	3X50+1X35+1X16	0.12	0	0
						2X25+1X16	0.29	0	0
			GOSAI PURA	195927-003	New 11 KV Line	11KV Weasel Conductor	0.3	0	0
						25 KVA (3 Ph)	0	1	0
					New ABC Line	3X50+1X35+1X16	0.12	0	0
						2X25+1X16	0.27	0	0
83	Gopalpur	195935	SARYA	195935-006	New 11 KV Line	11KV Weasel Conductor	0.34	0	0
						25 KVA (3 Ph)	0	1	0
					New ABC Line	3X50+1X35+1X16	0.13	0	0
						2X25+1X16	0.3	0	0
84	Kishundaspur	195954	BHARAUTY	195954-001	New 11 KV Line	11KV Weasel Conductor	0.3	0	0
						25 KVA (3 Ph)	0	1	0
					New ABC Line	3X50+1X35+1X16	0.12	0	0
						2X25+1X16	0.28	0	0

Village Wise/Habitation Proposed Works

State : UTTAR PRADESH
District : Azamgarh

Sl.No. (Vill.)	Name of Village (all villages as per census)	Census Code (2011)	Name of Habitation including main villages	Habitation Code	Works Type	Item	Line Length(Kms)	DTR(Nos)	Earthing(Kms)
1	2	3	4	5	6	7	8	9	10
85	Pitthu Patti	195955	BHARAUTY	195955-001	New 11 KV Line	11KV Weasel Conductor	0.3	0	0
						25 KVA (3 Ph)	0	1	0
					New ABC Line	3X50+1X35+1X16	0.12	0	0
						2X25+1X16	0.27	0	0
86	Roshanpur	195956	BHARAUTY	195956-001	New 11 KV Line	11KV Weasel Conductor	0.3	0	0
						25 KVA (3 Ph)	0	1	0
					New ABC Line	3X50+1X35+1X16	0.12	0	0
						2X25+1X16	0.27	0	0
Block :: Mirzapur									
87	Mudiyar	194259	BHARAITI	194259-001	New 11 KV Line	11KV Weasel Conductor	0.35	0	0
						25 KVA (3 Ph)	0	1	0
					New ABC Line	2X25+1X16	0.31	0	0
						3X50+1X35+1X16	0.13	0	0
88	Bakspur	194271	HARIJAN BASTI	194271-002	New 11 KV Line	11KV Weasel Conductor	0.34	0	0
						25 KVA (3 Ph)	0	1	0
					New ABC Line	2X25+1X16	0.3	0	0
						3X50+1X35+1X16	0.13	0	0
89	Chak Kamarali	194275	PANDIT BASTI	194275-004	New 11 KV Line	11KV Weasel Conductor	0.34	0	0
						25 KVA (3 Ph)	0	1	0
					New ABC Line	2X25+1X16	0.3	0	0
						3X50+1X35+1X16	0.13	0	0

Village Wise/Habitation Proposed Works

State : UTTAR PRADESH
District : Azamgarh

Sl.No. (Vill.)	Name of Village (all villages as per census)	Census Code (2011)	Name of Habitation including main villages	Habitation Code	Works Type	Item	Line Length(Kms)	DTR(Nos)	Earthing(Kms)
1	2	3	4	5	6	7	8	9	10
90	Niyauj	194288	YADAV BASTI	194288-006	New 11 KV Line	11KV Weasel Conductor	1.14	0	0
						25 KVA (3 Ph)	0	3	0
					New ABC Line	2X25+1X16	1.01	0	0
						3X50+1X35+1X16	0.41	0	0
91	Mirjapur	194294	H.B	194294-001	New 11 KV Line	11KV Weasel Conductor	0.66	0	0
						25 KVA (3 Ph)	0	2	0
					New ABC Line	2X25+1X16	0.6	0	0
						3X50+1X35+1X16	0.25	0	0
			YADAV BASTI	194294-004	New 11 KV Line	11KV Weasel Conductor	0.34	0	0
						25 KVA (3 Ph)	0	1	0
					New ABC Line	2X25+1X16	0.31	0	0
						3X50+1X35+1X16	0.13	0	0
92	Gauspur	194322	YADAV BASTI	194322-003	New 11 KV Line	11KV Weasel Conductor	0.37	0	0
						25 KVA (3 Ph)	0	1	0
					New ABC Line	2X25+1X16	0.33	0	0
						3X50+1X35+1X16	0.13	0	0
93	Sidha Sultanpur	194335	HARIJAN BASTI	194335-001	New 11 KV Line	11KV Weasel Conductor	0.69	0	0
						25 KVA (3 Ph)	0	2	0
					New ABC Line	2X25+1X16	0.62	0	0
						3X50+1X35+1X16	0.25	0	0
94	Ahiripur	194349	YADAV BASTI	194349-002	New 11 KV Line	11KV Weasel Conductor	0.66	0	0

Village Wise/Habitation Proposed Works

State : UTTAR PRADESH
District : Azamgarh

Sl.No. (Vill.)	Name of Village (all villages as per census)	Census Code (2011)	Name of Habitation including main villages	Habitation Code	Works Type	Item	Line Length(Kms)	DTR(Nos)	Earthing(Kms)
1	2	3	4	5	6	7	8	9	10
						25 KVA (3 Ph)	0	2	0
					New ABC Line	2X25+1X16	0.6	0	0
						3X50+1X35+1X16	0.25	0	0
95	Tikariya Maddhu Khan	194351	HARIJAN BASTI	194351-002	New 11 KV Line	11KV Weasel Conductor	0.37	0	0
						25 KVA (3 Ph)	0	1	0
					New ABC Line	2X25+1X16	0.33	0	0
						3X50+1X35+1X16	0.13	0	0
96	Kaudiya	194352	YADAV BASTI	194352-004	New 11 KV Line	11KV Weasel Conductor	0.66	0	0
						25 KVA (3 Ph)	0	2	0
					New ABC Line	2X25+1X16	0.6	0	0
						3X50+1X35+1X16	0.25	0	0
97	Pavailadpur	194382	HARIJAN BASTI	194382-001	New 11 KV Line	11KV Weasel Conductor	0.36	0	0
						25 KVA (3 Ph)	0	1	0
					New ABC Line	2X25+1X16	0.32	0	0
						3X50+1X35+1X16	0.13	0	0
98	Newada	194424	H.B	194424-001	New 11 KV Line	11KV Weasel Conductor	0.38	0	0
						25 KVA (3 Ph)	0	1	0
					New ABC Line	2X25+1X16	0.34	0	0
						3X50+1X35+1X16	0.14	0	0

Block :: Mohammadpur

Village Wise/Habitation Proposed Works

State : UTTAR PRADESH
District : Azamgarh

Sl.No. (Vill.)	Name of Village (all villages as per census)	Census Code (2011)	Name of Habitation including main villages	Habitation Code	Works Type	Item	Line Length(Kms)	DTR(Nos)	Earthing(Kms)
1	2	3	4	5	6	7	8	9	10
99	Parsurampur	194560	CHAUHAN BASTI	194560-002	New 11 KV Line	11KV Weasel Conductor	0.34	0	0
						25 KVA (3 Ph)	0	1	0
					New ABC Line	2X25+1X16	0.31	0	0
						3X50+1X35+1X16	0.13	0	0
100	Nagawan	194575	CHAUHAN BASTI	194575-002	New 11 KV Line	11KV Weasel Conductor	0.3	0	0
						25 KVA (3 Ph)	0	1	0
					New ABC Line	2X25+1X16	0.27	0	0
						3X50+1X35+1X16	0.12	0	0
101	Masud Patti	194616	CHAUHAN BASTI	194616-001	New 11 KV Line	11KV Weasel Conductor	0.62	0	0
						25 KVA (3 Ph)	0	2	0
					New ABC Line	2X25+1X16	0.57	0	0
						3X50+1X35+1X16	0.24	0	0
102	Avak	194649	RAJBHAR BASTI	194649-006	New 11 KV Line	11KV Weasel Conductor	0.32	0	0
						25 KVA (3 Ph)	0	1	0
					New ABC Line	2X25+1X16	0.29	0	0
						3X50+1X35+1X16	0.12	0	0
103	Koilari Bujurg	195760	CHAUHAN BASTI	195760-002	New 11 KV Line	11KV Weasel Conductor	0.32	0	0
						25 KVA (3 Ph)	0	1	0
					New ABC Line	2X25+1X16	0.29	0	0

Village Wise/Habitation Proposed Works

State : UTTAR PRADESH
District : Azamgarh

Sl.No. (Vill.)	Name of Village (all villages as per census)	Census Code (2011)	Name of Habitation including main villages	Habitation Code	Works Type	Item	Line Length(Kms)	DTR(Nos)	Earthing(Kms)
1	2	3	4	5	6	7	8	9	10
						3X50+1X35+1X16	0.12	0	0
Block :: Palhani									
104	Bodhpur Or Godpur	193552	` GODHPUR	193552-001	New 11 KV Line	11KV Weasel Conductor	0.64	0	0
						25 KVA (3 Ph)	0	2	0
					New ABC Line	2X25+1X16	0.58	0	0
						3X50+1X35+1X16	0.24	0	0
105	Aho Patti	193645	YB	193645-004	New 11 KV Line	11KV Weasel Conductor	0.36	0	0
						25 KVA (3 Ph)	0	1	0
					New ABC Line	2X25+1X16	0.32	0	0
						3X50+1X35+1X16	0.14	0	0
106	Karimuddinpur	193647	GENRAL BASTI	193647-003	New 11 KV Line	11KV Weasel Conductor	0.64	0	0
						25 KVA (3 Ph)	0	2	0
					New ABC Line	2X25+1X16	0.58	0	0
						3X50+1X35+1X16	0.24	0	0
107	Belnadih	193670	RAJBHAR BASTI	193670-003	New 11 KV Line	11KV Weasel Conductor	0.36	0	0
						25 KVA (3 Ph)	0	1	0
					New ABC Line	2X25+1X16	0.32	0	0
						3X50+1X35+1X16	0.13	0	0
Block :: Palhna									
108	Narsingh Pur	195413	HB	195413-002	New 11 KV Line	11KV Weasel Conductor	0.35	0	0

Village Wise/Habitation Proposed Works

State : UTTAR PRADESH
District : Azamgarh

Sl.No. (Vill.)	Name of Village (all villages as per census)	Census Code (2011)	Name of Habitation including main villages	Habitation Code	Works Type	Item	Line Length(Kms)	DTR(Nos)	Earthing(Kms)
1	2	3	4	5	6	7	8	9	10
						25 KVA (3 Ph)	0	1	0
					New ABC Line	3X50+1X35+1X16	0.13	0	0
						2X25+1X16	0.31	0	0
109	Bhojpur	195418	BHAROUTI	195418-001	New 11 KV Line	11KV Weasel Conductor	0.64	0	0
						25 KVA (3 Ph)	0	2	0
					New ABC Line	3X50+1X35+1X16	0.24	0	0
						2X25+1X16	0.58	0	0
110	Sarai Khursu	195419	BHAROUTI	195419-001	New 11 KV Line	11KV Weasel Conductor	0.36	0	0
						25 KVA (3 Ph)	0	1	0
					New ABC Line	3X50+1X35+1X16	0.13	0	0
						2X25+1X16	0.32	0	0
111	Tarak Dih	195421	HB	195421-001	New 11 KV Line	11KV Weasel Conductor	0.62	0	0
						25 KVA (3 Ph)	0	2	0
					New ABC Line	3X50+1X35+1X16	0.24	0	0
						2X25+1X16	0.57	0	0
			TADAKDIH	195421-002	New 11 KV Line	11KV Weasel Conductor	0.47	0	0
						25 KVA (3 Ph)	0	1	0
					New ABC Line	3X50+1X35+1X16	0.23	0	0
						2X25+1X16	0.4	0	0
112	Lahuwa Kalan	195428	HB	195428-003	New 11 KV Line	11KV Weasel Conductor	1.12	0	0
						25 KVA (3 Ph)	0	3	0

Village Wise/Habitation Proposed Works

State : UTTAR PRADESH
District : Azamgarh

Sl.No. (Vill.)	Name of Village (all villages as per census)	Census Code (2011)	Name of Habitation including main villages	Habitation Code	Works Type	Item	Line Length(Kms)	DTR(Nos)	Earthing(Kms)
1	2	3	4	5	6	7	8	9	10
					New ABC Line	3X50+1X35+1X16	0.4	0	0
						2X25+1X16	0.99	0	0
113	Kota Khurd	195431	HB	195431-003	New 11 KV Line	11KV Weasel Conductor	0.35	0	0
						25 KVA (3 Ph)	0	1	0
					New ABC Line	3X50+1X35+1X16	0.13	0	0
						2X25+1X16	0.31	0	0
114	Avani	195606	BHAROUTI	195606-002	New 11 KV Line	11KV Weasel Conductor	0.35	0	0
						25 KVA (3 Ph)	0	1	0
					New ABC Line	3X50+1X35+1X16	0.13	0	0
						2X25+1X16	0.31	0	0
115	Karsara	195610	BHAROUTI	195610-001	New 11 KV Line	11KV Weasel Conductor	0.36	0	0
						25 KVA (3 Ph)	0	1	0
					New ABC Line	3X50+1X35+1X16	0.13	0	0
						2X25+1X16	0.32	0	0
116	Katai	195828	HB	195828-001	New 11 KV Line	11KV Weasel Conductor	0.65	0	0
						25 KVA (3 Ph)	0	2	0
					New ABC Line	3X50+1X35+1X16	0.25	0	0
						2X25+1X16	0.59	0	0
117	Pauni Kalan	195832	HB	195832-001	New 11 KV Line	11KV Weasel Conductor	1.02	0	0
						25 KVA (3 Ph)	0	3	0
					New ABC Line	3X50+1X35+1X16	0.38	0	0

Village Wise/Habitation Proposed Works

State : UTTAR PRADESH
District : Azamgarh

Sl.No. (Vill.)	Name of Village (all villages as per census)	Census Code (2011)	Name of Habitation including main villages	Habitation Code	Works Type	Item	Line Length(Kms)	DTR(Nos)	Earthing(Kms)
1	2	3	4	5	6	7	8	9	10
						2X25+1X16	0.92	0	0
118	Khajuri	195833	BHAROUTI	195833-001	New 11 KV Line	11KV Weasel Conductor	0.7	0	0
						25 KVA (3 Ph)	0	2	0
					New ABC Line	3X50+1X35+1X16	0.26	0	0
						2X25+1X16	0.62	0	0
			HB	195833-002	New 11 KV Line	11KV Weasel Conductor	0.47	0	0
						25 KVA (3 Ph)	0	1	0
					New ABC Line	3X50+1X35+1X16	0.32	0	0
						2X25+1X16	0.59	0	0
119	Singhpur	195944	BHAROUTI	195944-002	New 11 KV Line	11KV Weasel Conductor	0.35	0	0
						25 KVA (3 Ph)	0	1	0
					New ABC Line	3X50+1X35+1X16	0.13	0	0
						2X25+1X16	0.31	0	0
120	Kahutara	195951	HB SOUTH	195951-003	New 11 KV Line	11KV Weasel Conductor	0.65	0	0
						25 KVA (3 Ph)	0	2	0
					New ABC Line	3X50+1X35+1X16	0.24	0	0
						2X25+1X16	0.59	0	0
121	Ismailpur Bharathipur	196061	BHAROUTI	196061-001	New 11 KV Line	11KV Weasel Conductor	0.65	0	0
						25 KVA (3 Ph)	0	2	0
					New ABC Line	3X50+1X35+1X16	0.24	0	0

Village Wise/Habitation Proposed Works

State : UTTAR PRADESH
District : Azamgarh

Sl.No. (Vill.)	Name of Village (all villages as per census)	Census Code (2011)	Name of Habitation including main villages	Habitation Code	Works Type	Item	Line Length(Kms)	DTR(Nos)	Earthing(Kms)
1	2	3	4	5	6	7	8	9	10
						2X25+1X16	0.59	0	0
			HB	196061-002	New 11 KV Line	11KV Weasel Conductor	0.47	0	0
						25 KVA (3 Ph)	0	1	0
					New ABC Line	3X50+1X35+1X16	0.32	0	0
						2X25+1X16	0.59	0	0
Block :: Pawai									
122	Nizampur	194713	BHARAUTI	194713-002	New 11 KV Line	11KV Weasel Conductor	0.67	0	0
						25 KVA (3 Ph)	0	2	0
					New ABC Line	3X50+1X35+1X16	0.25	0	0
						2X25+1X16	0.6	0	0
			H.B.P	194713-003	New 11 KV Line	11KV Weasel Conductor	0.34	0	0
						25 KVA (3 Ph)	0	1	0
					New ABC Line	3X50+1X35+1X16	0.13	0	0
						2X25+1X16	0.31	0	0
123	Jaldipur	194771	KAWATAN	194771-009	New 11 KV Line	11KV Weasel Conductor	0.69	0	0
						25 KVA (3 Ph)	0	2	0
					New ABC Line	3X50+1X35+1X16	0.26	0	0
						2X25+1X16	0.62	0	0
124	Jafarpur Kathakan	194799	BHAR BASTI	194799-001	New 11 KV Line	11KV Weasel Conductor	0.34	0	0
						25 KVA (3 Ph)	0	1	0
					New ABC Line	3X50+1X35+1X16	0.13	0	0

Village Wise/Habitation Proposed Works

State : UTTAR PRADESH
District : Azamgarh

Sl.No. (Vill.)	Name of Village (all villages as per census)	Census Code (2011)	Name of Habitation including main villages	Habitation Code	Works Type	Item	Line Length(Kms)	DTR(Nos)	Earthing(Kms)
1	2	3	4	5	6	7	8	9	10
						2X25+1X16	0.31	0	0
125	Gondhana	194801	KALAN	194801-006	New 11 KV Line	11KV Weasel Conductor	0.85	0	0
						25 KVA (3 Ph)	0	3	0
					New ABC Line	3X50+1X35+1X16	0.37	0	0
						2X25+1X16	0.79	0	0
126	Ambari	194807	BAZAR	194807-002	New 11 KV Line	11KV Weasel Conductor	0.34	0	0
						25 KVA (3 Ph)	0	1	0
					New ABC Line	3X50+1X35+1X16	0.13	0	0
						2X25+1X16	0.31	0	0
127	Kushaha	194821	BHARAUTI	194821-001	New 11 KV Line	11KV Weasel Conductor	0.34	0	0
						25 KVA (3 Ph)	0	1	0
					New ABC Line	3X50+1X35+1X16	0.13	0	0
						2X25+1X16	0.3	0	0
Block :: Phulpur									
128	Gandi	194979	AHIRAN	194979-001	New 11 KV Line	11KV Weasel Conductor	0.32	0	0
						25 KVA (3 Ph)	0	1	0
					New ABC Line	2X25+1X16	0.29	0	0
						3X50+1X35+1X16	0.12	0	0
129	Dighiya	194983	AHIRAN	194983-001	New 11 KV Line	11KV Weasel Conductor	0.32	0	0
						25 KVA (3 Ph)	0	1	0
					New ABC Line	2X25+1X16	0.29	0	0

Village Wise/Habitation Proposed Works

State : UTTAR PRADESH
District : Azamgarh

Sl.No. (Vill.)	Name of Village (all villages as per census)	Census Code (2011)	Name of Habitation including main villages	Habitation Code	Works Type	Item	Line Length(Kms)	DTR(Nos)	Earthing(Kms)
1	2	3	4	5	6	7	8	9	10
						3X50+1X35+1X16	0.12	0	0
130	Palthi	195016	AHIRAN	195016-001	New 11 KV Line	11KV Weasel Conductor	0.3	0	0
						25 KVA (3 Ph)	0	1	0
					New ABC Line	2X25+1X16	0.27	0	0
						3X50+1X35+1X16	0.12	0	0
131	Kharsahan Khurd	195050	KOTIYA	195050-003	New 11 KV Line	11KV Weasel Conductor	0.3	0	0
						25 KVA (3 Ph)	0	1	0
					New ABC Line	2X25+1X16	0.28	0	0
						3X50+1X35+1X16	0.12	0	0
Block :: Rani Ki Sarai									
132	Hamidpur	193459	HAMEEDPUR	193459-001	New 11 KV Line	11KV Weasel Conductor	0.34	0	0
						25 KVA (3 Ph)	0	1	0
					New ABC Line	2X25+1X16	0.31	0	0
						3X50+1X35+1X16	0.13	0	0
133	Chuhaipur	193482	CHOOHAN PATTI	193482-001	New 11 KV Line	11KV Weasel Conductor	0.36	0	0
						25 KVA (3 Ph)	0	1	0
					New ABC Line	2X25+1X16	0.32	0	0
						3X50+1X35+1X16	0.13	0	0
134	Saifpur	193489	SAIFPUR	193489-002	New 11 KV Line	11KV Weasel Conductor	1	0	0
						25 KVA (3 Ph)	0	3	0

Village Wise/Habitation Proposed Works

State : UTTAR PRADESH
District : Azamgarh

Sl.No. (Vill.)	Name of Village (all villages as per census)	Census Code (2011)	Name of Habitation including main villages	Habitation Code	Works Type	Item	Line Length(Kms)	DTR(Nos)	Earthing(Kms)
1	2	3	4	5	6	7	8	9	10
					New ABC Line	2X25+1X16	0.9	0	0
						3X50+1X35+1X16	0.37	0	0
135	Shambhu Ayeema Or Shambhopu Ay	193496	MUSHER BASTI	193496-002	New 11 KV Line	11KV Weasel Conductor	0.71	0	0
						25 KVA (3 Ph)	0	2	0
					New ABC Line	2X25+1X16	0.63	0	0
						3X50+1X35+1X16	0.26	0	0
136	Daudpur	193510	MUSLIM BASTI	193510-003	New 11 KV Line	11KV Weasel Conductor	0.38	0	0
						25 KVA (3 Ph)	0	1	0
					New ABC Line	2X25+1X16	0.33	0	0
						3X50+1X35+1X16	0.14	0	0
137	Deoka Patti	193512	DEWKAPATTI H BASTI	193512-001	New 11 KV Line	11KV Weasel Conductor	0.48	0	0
						25 KVA (3 Ph)	0	1	0
					New ABC Line	2X25+1X16	0.41	0	0
						3X50+1X35+1X16	0.23	0	0
138	Khaira	193517	YB	193517-003	New 11 KV Line	11KV Weasel Conductor	0.36	0	0
						25 KVA (3 Ph)	0	1	0
					New ABC Line	2X25+1X16	0.32	0	0
						3X50+1X35+1X16	0.13	0	0
139	Dharm Daspur	193518	DHARMDAS PUR	193518-001	New 11 KV Line	11KV Weasel Conductor	0.38	0	0

Village Wise/Habitation Proposed Works

State : UTTAR PRADESH
District : Azamgarh

Sl.No. (Vill.)	Name of Village (all villages as per census)	Census Code (2011)	Name of Habitation including main villages	Habitation Code	Works Type	Item	Line Length(Kms)	DTR(Nos)	Earthing(Kms)
1	2	3	4	5	6	7	8	9	10
						25 KVA (3 Ph)	0	1	0
					New ABC Line	2X25+1X16	0.34	0	0
						3X50+1X35+1X16	0.14	0	0
140	Behta Lachhirampur Or Behta	193522	MUSLIM BASTI	193522-003	New 11 KV Line	11KV Weasel Conductor	0.35	0	0
						25 KVA (3 Ph)	0	1	0
					New ABC Line	2X25+1X16	0.31	0	0
						3X50+1X35+1X16	0.13	0	0
141	Jalaipur	193524	JALAIPUR	193524-002	New 11 KV Line	11KV Weasel Conductor	0.72	0	0
						25 KVA (3 Ph)	0	2	0
					New ABC Line	2X25+1X16	0.64	0	0
						3X50+1X35+1X16	0.26	0	0
142	Shahi Garha	193537	MAURYA BASTI	193537-002	New 11 KV Line	11KV Weasel Conductor	0.7	0	0
						25 KVA (3 Ph)	0	2	0
					New ABC Line	2X25+1X16	0.63	0	0
						3X50+1X35+1X16	0.26	0	0
143	Marantpur Kashi Ali	194444	MARUKHPUR KASHIMALI	194444-001	New 11 KV Line	11KV Weasel Conductor	0.65	0	0
						25 KVA (3 Ph)	0	2	0
					New ABC Line	2X25+1X16	0.59	0	0
						3X50+1X35+1X16	0.25	0	0

Village Wise/Habitation Proposed Works

State : UTTAR PRADESH
District : Azamgarh

Sl.No. (Vill.)	Name of Village (all villages as per census)	Census Code (2011)	Name of Habitation including main villages	Habitation Code	Works Type	Item	Line Length(Kms)	DTR(Nos)	Earthing(Kms)
1	2	3	4	5	6	7	8	9	10
144	Kotwalipur	194449	KOHAR BASTI	194449-001	New 11 KV Line	11KV Weasel Conductor	0.36	0	0
						25 KVA (3 Ph)	0	1	0
					New ABC Line	2X25+1X16	0.32	0	0
						3X50+1X35+1X16	0.13	0	0
145	Dodopur	194456	BHUNKI H BASTI	194456-001	New 11 KV Line	11KV Weasel Conductor	0.65	0	0
						25 KVA (3 Ph)	0	2	0
					New ABC Line	2X25+1X16	0.59	0	0
						3X50+1X35+1X16	0.24	0	0
146	Telipur	194458	TELLI PUR	194458-002	New 11 KV Line	11KV Weasel Conductor	0.35	0	0
						25 KVA (3 Ph)	0	1	0
					New ABC Line	2X25+1X16	0.31	0	0
						3X50+1X35+1X16	0.13	0	0
147	Isapur	194480	ISHAPUR	194480-001	New 11 KV Line	11KV Weasel Conductor	0.64	0	0
						25 KVA (3 Ph)	0	2	0
					New ABC Line	2X25+1X16	0.58	0	0
						3X50+1X35+1X16	0.24	0	0
148	Fariya	194495	FARIHA SARHEDPAR H BASTI	194495-004	New 11 KV Line	11KV Weasel Conductor	0.98	0	0
						25 KVA (3 Ph)	0	3	0
					New ABC Line	2X25+1X16	0.89	0	0

Village Wise/Habitation Proposed Works

State : UTTAR PRADESH
District : Azamgarh

Sl.No. (Vill.)	Name of Village (all villages as per census)	Census Code (2011)	Name of Habitation including main villages	Habitation Code	Works Type	Item	Line Length(Kms)	DTR(Nos)	Earthing(Kms)
1	2	3	4	5	6	7	8	9	10
						3X50+1X35+1X16	0.37	0	0
149	Gandhuvai	194498	MUSHAR BASTI	194498-003	New 11 KV Line	11KV Weasel Conductor	1	0	0
						25 KVA (3 Ph)	0	3	0
					New ABC Line	2X25+1X16	0.9	0	0
						3X50+1X35+1X16	0.37	0	0
150	Khawajapur	194518	KHATIKAN	194518-002	New 11 KV Line	11KV Weasel Conductor	0.64	0	0
						25 KVA (3 Ph)	0	2	0
					New ABC Line	2X25+1X16	0.58	0	0
						3X50+1X35+1X16	0.24	0	0
151	Katghar Babul	194522	KATGHAR BABOOL	194522-001	New 11 KV Line	11KV Weasel Conductor	0.63	0	0
						25 KVA (3 Ph)	0	2	0
					New ABC Line	2X25+1X16	0.57	0	0
						3X50+1X35+1X16	0.24	0	0
152	Jamin Katghar	194527	HB SOUTH	194527-002	New 11 KV Line	11KV Weasel Conductor	0.37	0	0
						25 KVA (3 Ph)	0	1	0
					New ABC Line	2X25+1X16	0.33	0	0
						3X50+1X35+1X16	0.14	0	0
153	Sheewli	194536	UTTARI MUSLIM BASTI	194536-005	New 11 KV Line	11KV Weasel Conductor	0.66	0	0
						25 KVA (3 Ph)	0	2	0
					New ABC Line	2X25+1X16	0.59	0	0

Village Wise/Habitation Proposed Works

State : UTTAR PRADESH
District : Azamgarh

Sl.No. (Vill.)	Name of Village (all villages as per census)	Census Code (2011)	Name of Habitation including main villages	Habitation Code	Works Type	Item	Line Length(Kms)	DTR(Nos)	Earthing(Kms)
1	2	3	4	5	6	7	8	9	10
						3X50+1X35+1X16	0.25	0	0
Block :: Sathiyaon									
154	Bhamahaur	193805	HARIJAN BASTI SOUTH	193805-002	New 11 KV Line	11KV Weasel Conductor	0.33	0	0
						25 KVA (3 Ph)	0	1	0
					New ABC Line	2X25+1X16	0.3	0	0
						3X50+1X35+1X16	0.13	0	0
155	Gagahara	193810	MUSHAR BASTI	193810-007	New 11 KV Line	11KV Weasel Conductor	0.32	0	0
						25 KVA (3 Ph)	0	1	0
					New ABC Line	2X25+1X16	0.29	0	0
						3X50+1X35+1X16	0.12	0	0
156	Khemapur	193843	HARIJAN BASTI EAST	193843-001	New 11 KV Line	11KV Weasel Conductor	0.68	0	0
						25 KVA (3 Ph)	0	2	0
					New ABC Line	2X25+1X16	0.61	0	0
						3X50+1X35+1X16	0.25	0	0
157	Naizarpur	193853	RAJBHAR BASTI	193853-002	New 11 KV Line	11KV Weasel Conductor	0.38	0	0
						25 KVA (3 Ph)	0	1	0
					New ABC Line	2X25+1X16	0.34	0	0
						3X50+1X35+1X16	0.14	0	0
Block :: Tahbarpur									
158	Madya Or Garya	193417	AHIRAN	193417-001	New 11 KV Line	11KV Weasel Conductor	0.3	0	0

Village Wise/Habitation Proposed Works

State : UTTAR PRADESH
District : Azamgarh

Sl.No. (Vill.)	Name of Village (all villages as per census)	Census Code (2011)	Name of Habitation including main villages	Habitation Code	Works Type	Item	Line Length(Kms)	DTR(Nos)	Earthing(Kms)
1	2	3	4	5	6	7	8	9	10
						25 KVA (3 Ph)	0	1	0
					New ABC Line	3X50+1X35+1X16	0.12	0	0
						2X25+1X16	0.28	0	0
159	Bhurramaq Bulpur Or Mori Makdu	193418	H BASTI NORTH	193418-004	New 11 KV Line	11KV Weasel Conductor	0.33	0	0
						25 KVA (3 Ph)	0	1	0
					New ABC Line	3X50+1X35+1X16	0.13	0	0
						2X25+1X16	0.3	0	0
160	Ekma	193429	H BASTI	193429-003	New 11 KV Line	11KV Weasel Conductor	0.34	0	0
						25 KVA (3 Ph)	0	1	0
					New ABC Line	3X50+1X35+1X16	0.13	0	0
						2X25+1X16	0.31	0	0
161	Nasiruddinpur	193431	H BASTI	193431-001	New 11 KV Line	11KV Weasel Conductor	0.33	0	0
						25 KVA (3 Ph)	0	1	0
					New ABC Line	3X50+1X35+1X16	0.13	0	0
						2X25+1X16	0.3	0	0
162	Garhwa	194098	LOHRAUTI	194098-005	New 11 KV Line	11KV Weasel Conductor	0.3	0	0
						25 KVA (3 Ph)	0	1	0
					New ABC Line	3X50+1X35+1X16	0.12	0	0
						2X25+1X16	0.27	0	0
163	Ohani	194111	H BASTI	194111-001	New 11 KV Line	11KV Weasel Conductor	0.36	0	0

Village Wise/Habitation Proposed Works

State : UTTAR PRADESH
District : Azamgarh

Sl.No. (Vill.)	Name of Village (all villages as per census)	Census Code (2011)	Name of Habitation including main villages	Habitation Code	Works Type	Item	Line Length(Kms)	DTR(Nos)	Earthing(Kms)
1	2	3	4	5	6	7	8	9	10
						25 KVA (3 Ph)	0	1	0
					New ABC Line	3X50+1X35+1X16	0.13	0	0
						2X25+1X16	0.32	0	0
164	Govindpur	194125	H BASTI	194125-003	New 11 KV Line	11KV Weasel Conductor	0.34	0	0
						25 KVA (3 Ph)	0	1	0
					New ABC Line	3X50+1X35+1X16	0.13	0	0
						2X25+1X16	0.31	0	0
165	Kariyabar	194130	Y BASTI NORTH	194130-008	New 11 KV Line	11KV Weasel Conductor	0.32	0	0
						25 KVA (3 Ph)	0	1	0
					New ABC Line	3X50+1X35+1X16	0.12	0	0
						2X25+1X16	0.29	0	0
166	Deoria	194147	FAKIRANA	194147-002	New 11 KV Line	11KV Weasel Conductor	0.3	0	0
						25 KVA (3 Ph)	0	1	0
					New ABC Line	3X50+1X35+1X16	0.12	0	0
						2X25+1X16	0.27	0	0
167	Badsara Khalsa	194150	H BASTI	194150-002	New 11 KV Line	11KV Weasel Conductor	0.34	0	0
						25 KVA (3 Ph)	0	1	0
					New ABC Line	3X50+1X35+1X16	0.13	0	0
						2X25+1X16	0.3	0	0
168	Merhi	194191	KAVTANA	194191-003	New 11 KV Line	11KV Weasel Conductor	0.3	0	0
						25 KVA (3 Ph)	0	1	0

Village Wise/Habitation Proposed Works

State : UTTAR PRADESH
District : Azamgarh

Sl.No. (Vill.)	Name of Village (all villages as per census)	Census Code (2011)	Name of Habitation including main villages	Habitation Code	Works Type	Item	Line Length(Kms)	DTR(Nos)	Earthing(Kms)
1	2	3	4	5	6	7	8	9	10
					New ABC Line	3X50+1X35+1X16	0.12	0	0
						2X25+1X16	0.28	0	0
169	Madhsiya	194196	CHAUHAN BASTI	194196-002	New 11 KV Line	11KV Weasel Conductor	0.32	0	0
						25 KVA (3 Ph)	0	1	0
					New ABC Line	3X50+1X35+1X16	0.12	0	0
						2X25+1X16	0.29	0	0
170	Chakbari	194197	WEST PURA	194197-004	New 11 KV Line	11KV Weasel Conductor	0.35	0	0
						25 KVA (3 Ph)	0	1	0
					New ABC Line	3X50+1X35+1X16	0.13	0	0
						2X25+1X16	0.31	0	0
171	Bhilauli Khalsa	194226	FAKIRANA	194226-002	New 11 KV Line	11KV Weasel Conductor	0.31	0	0
						25 KVA (3 Ph)	0	1	0
					New ABC Line	3X50+1X35+1X16	0.12	0	0
						2X25+1X16	0.28	0	0
172	Chak Majnu	194229	MOTIDEH	194229-003	New 11 KV Line	11KV Weasel Conductor	0.32	0	0
						25 KVA (3 Ph)	0	1	0
					New ABC Line	3X50+1X35+1X16	0.12	0	0
						2X25+1X16	0.29	0	0
Block :: Tarwa									
173	Barawa	195643	YADAV BASTI	195643-004	New 11 KV Line	11KV Weasel Conductor	0.36	0	0

Village Wise/Habitation Proposed Works

State : UTTAR PRADESH
District : Azamgarh

Sl.No. (Vill.)	Name of Village (all villages as per census)	Census Code (2011)	Name of Habitation including main villages	Habitation Code	Works Type	Item	Line Length(Kms)	DTR(Nos)	Earthing(Kms)
1	2	3	4	5	6	7	8	9	10
						25 KVA (3 Ph)	0	1	0
					New ABC Line	3X50+1X35+1X16	0.13	0	0
						2X25+1X16	0.32	0	0
174	Bahlolpur	195728	BHARAVATI	195728-002	New 11 KV Line	11KV Weasel Conductor	0.3	0	0
						25 KVA (3 Ph)	0	1	0
					New ABC Line	3X50+1X35+1X16	0.11	0	0
						2X25+1X16	0.27	0	0
175	Zoova	196002	MAROBPUR	196002-003	New 11 KV Line	11KV Weasel Conductor	0.31	0	0
						25 KVA (3 Ph)	0	1	0
					New ABC Line	3X50+1X35+1X16	0.13	0	0
						2X25+1X16	0.28	0	0
176	Bairodih	196026	YADAV BASTI	196026-002	New 11 KV Line	11KV Weasel Conductor	0.29	0	0
						25 KVA (3 Ph)	0	1	0
					New ABC Line	3X50+1X35+1X16	0.11	0	0
						2X25+1X16	0.27	0	0
177	Titara	196039	PANDETAN	196039-005	New 11 KV Line	11KV Weasel Conductor	0.29	0	0
						25 KVA (3 Ph)	0	1	0
					New ABC Line	3X50+1X35+1X16	0.11	0	0
						2X25+1X16	0.27	0	0
Block :: Thekma									
178	Belau	195178	HB.EAST	195178-003	New 11 KV Line	11KV Weasel Conductor	0.63	0	0

Village Wise/Habitation Proposed Works

State : UTTAR PRADESH
District : Azamgarh

Sl.No. (Vill.)	Name of Village (all villages as per census)	Census Code (2011)	Name of Habitation including main villages	Habitation Code	Works Type	Item	Line Length(Kms)	DTR(Nos)	Earthing(Kms)
1	2	3	4	5	6	7	8	9	10
						25 KVA (3 Ph)	0	2	0
					New ABC Line	3X50+1X35+1X16	0.24	0	0
						2X25+1X16	0.57	0	0
179	Gopalpur	195210	GOPALPUR	195210-001	New 11 KV Line	11KV Weasel Conductor	0.36	0	0
						25 KVA (3 Ph)	0	1	0
					New ABC Line	3X50+1X35+1X16	0.13	0	0
						2X25+1X16	0.32	0	0
180	Para	195304	THAKUR BASTI	195304-008	New 11 KV Line	11KV Weasel Conductor	0.34	0	0
						25 KVA (3 Ph)	0	1	0
					New ABC Line	3X50+1X35+1X16	0.13	0	0
						2X25+1X16	0.31	0	0
181	Bheera	195307	CHAUHAN BASTI	195307-003	New 11 KV Line	11KV Weasel Conductor	0.35	0	0
						25 KVA (3 Ph)	0	1	0
					New ABC Line	3X50+1X35+1X16	0.13	0	0
						2X25+1X16	0.31	0	0
182	Chhattar Pur	195309	MUSLIM BASTI	195309-004	New 11 KV Line	11KV Weasel Conductor	0.36	0	0
						25 KVA (3 Ph)	0	1	0
					New ABC Line	3X50+1X35+1X16	0.13	0	0
						2X25+1X16	0.32	0	0

Block Wise Summary

Village Wise/Habitation Proposed Works

State : UTTAR PRADESH
District : Azamgarh

Sl.No. (Vill.)	Name of Village (all villages as per census)	Census Code (2011)	Name of Habitation including main villages	Habitation Code	Works Type	Item	Line Length(Kms)	DTR(Nos)	Earthing(Kms)
1	2	3	4	5	6	7	8	9	10
1	Ahiraula				New 11 KV Line	11KV Weasel Conductor	1.29	0	0
						25 KVA (3 Ph)	0	4	0
					New ABC Line	2X25+1X16	1.17	0	0
						3X50+1X35+1X16	0.5	0	0
2	Atraulia				New 11 KV Line	11KV Weasel Conductor	1.6	0	0
						25 KVA (3 Ph)	0	5	0
					New ABC Line	2X25+1X16	1.45	0	0
						3X50+1X35+1X16	0.61	0	0
3	Azmatgarh				New 11 KV Line	11KV Weasel Conductor	2.24	0	0
						25 KVA (3 Ph)	0	7	0
					New ABC Line	2X25+1X16	1.86	0	0
						3X50+1X35+1X16	0.85	0	0
4	Bilariyaganj				New 11 KV Line	11KV Weasel Conductor	1.34	0	0
						25 KVA (3 Ph)	0	4	0
					New ABC Line	2X25+1X16	1.13	0	0
						3X50+1X35+1X16	0.5	0	0
5	Haraiya				New 11 KV Line	11KV Weasel Conductor	2.28	0	0
						25 KVA (3 Ph)	0	7	0
					New ABC Line	2X25+1X16	2.05	0	0
						3X50+1X35+1X16	0.91	0	0
6	Jahanaganj				New 11 KV Line	11KV Weasel Conductor	14.05	0	0

Village Wise/Habitation Proposed Works

State : UTTAR PRADESH
District : Azamgarh

Sl.No. (Vill.)	Name of Village (all villages as per census)	Census Code (2011)	Name of Habitation including main villages	Habitation Code	Works Type	Item	Line Length(Kms)	DTR(Nos)	Earthing(Kms)
1	2	3	4	5	6	7	8	9	10
						25 KVA (3 Ph)	0	35	0
					New ABC Line	2X25+1X16	12.5	0	0
						3X50+1X35+1X16	5.18	0	0
					New 11 KV Line	63 KVA (3 Ph)	0	4	0
7	Koilsa					11KV Weasel Conductor	3.64	0	0
						25 KVA (3 Ph)	0	11	0
					New ABC Line	2X25+1X16	3.25	0	0
						3X50+1X35+1X16	1.38	0	0
8	Lalganj				New 11 KV Line	11KV Weasel Conductor	7.5	0	0
						25 KVA (3 Ph)	0	18	0
					New ABC Line	3X50+1X35+1X16	2.96	0	0
						2X25+1X16	6.75	0	0
					New 11 KV Line	63 KVA (3 Ph)	0	4	0
9	Mahrajganj					11KV Weasel Conductor	2.43	0	0
						25 KVA (3 Ph)	0	8	0
					New ABC Line	2X25+1X16	2.22	0	0
						3X50+1X35+1X16	0.93	0	0
10	Martinganj				New 11 KV Line	11KV Weasel Conductor	5.71	0	0
						25 KVA (3 Ph)	0	18	0
					New ABC Line	2X25+1X16	5.12	0	0
						3X50+1X35+1X16	2.19	0	0

Village Wise/Habitation Proposed Works

State : UTTAR PRADESH
District : Azamgarh

Sl.No. (Vill.)	Name of Village (all villages as per census)	Census Code (2011)	Name of Habitation including main villages	Habitation Code	Works Type	Item	Line Length(Kms)	DTR(Nos)	Earthing(Kms)
1	2	3	4	5	6	7	8	9	10
11	Mehnagar				New 11 KV Line	11KV Weasel Conductor	3.99	0	0
						25 KVA (3 Ph)	0	13	0
					New ABC Line	3X50+1X35+1X16	1.61	0	0
						2X25+1X16	3.63	0	0
12	Mirzapur				New 11 KV Line	11KV Weasel Conductor	6.66	0	0
						25 KVA (3 Ph)	0	19	0
					New ABC Line	2X25+1X16	5.97	0	0
						3X50+1X35+1X16	2.46	0	0
13	Mohammadpur				New 11 KV Line	11KV Weasel Conductor	1.9	0	0
						25 KVA (3 Ph)	0	6	0
					New ABC Line	2X25+1X16	1.73	0	0
						3X50+1X35+1X16	0.73	0	0
14	Palhani				New 11 KV Line	11KV Weasel Conductor	2	0	0
						25 KVA (3 Ph)	0	6	0
					New ABC Line	2X25+1X16	1.8	0	0
						3X50+1X35+1X16	0.75	0	0
15	Palhna				New 11 KV Line	11KV Weasel Conductor	9.58	0	0
						25 KVA (3 Ph)	0	27	0
					New ABC Line	3X50+1X35+1X16	3.9	0	0
						2X25+1X16	8.91	0	0
16	Pawai				New 11 KV Line	11KV Weasel Conductor	3.57	0	0

Village Wise/Habitation Proposed Works

State : UTTAR PRADESH
District : Azamgarh

Sl.No. (Vill.)	Name of Village (all villages as per census)	Census Code (2011)	Name of Habitation including main villages	Habitation Code	Works Type	Item	Line Length(Kms)	DTR(Nos)	Earthing(Kms)
1	2	3	4	5	6	7	8	9	10
						25 KVA (3 Ph)	0	11	0
					New ABC Line	3X50+1X35+1X16	1.4	0	0
						2X25+1X16	3.24	0	0
17	Phulpur				New 11 KV Line	11KV Weasel Conductor	1.24	0	0
						25 KVA (3 Ph)	0	4	0
					New ABC Line	2X25+1X16	1.13	0	0
						3X50+1X35+1X16	0.48	0	0
18	Rani Ki Sarai				New 11 KV Line	11KV Weasel Conductor	12.71	0	0
						25 KVA (3 Ph)	0	37	0
					New ABC Line	2X25+1X16	11.39	0	0
						3X50+1X35+1X16	4.78	0	0
19	Sathiyaon				New 11 KV Line	11KV Weasel Conductor	1.71	0	0
						25 KVA (3 Ph)	0	5	0
					New ABC Line	2X25+1X16	1.54	0	0
						3X50+1X35+1X16	0.64	0	0
20	Tahbarpur				New 11 KV Line	11KV Weasel Conductor	4.86	0	0
						25 KVA (3 Ph)	0	15	0
					New ABC Line	3X50+1X35+1X16	1.87	0	0
						2X25+1X16	4.4	0	0
21	Tarwa				New 11 KV Line	11KV Weasel Conductor	1.55	0	0
						25 KVA (3 Ph)	0	5	0

Village Wise/Habitation Proposed Works

State : UTTAR PRADESH
District : Azamgarh

Sl.No. (Vill.)	Name of Village (all villages as per census)	Census Code (2011)	Name of Habitation including main villages	Habitation Code	Works Type	Item	Line Length(Kms)	DTR(Nos)	Earthing(Kms)
1	2	3	4	5	6	7	8	9	10
					New ABC Line	3X50+1X35+1X16	0.59	0	0
						2X25+1X16	1.41	0	0
22	Thekma				New 11 KV Line	11KV Weasel Conductor	2.04	0	0
						25 KVA (3 Ph)	0	6	0
					New ABC Line	3X50+1X35+1X16	0.76	0	0
						2X25+1X16	1.83	0	0
District Wise Summary									
1	New 11 KV Line				11KV Weasel Conductor		93.89	0	0
					25 KVA (3 Ph)		0	271	0
					63 KVA (3 Ph)		0	8	0
2	New ABC Line				2X25+1X16		84.48	0	0
					3X50+1X35+1X16		35.98	0	0

Existing REDB Infrastructure

State : UTTAR PRADESH
District : Azamgarh

S.No.	Name of Block	Name of SubStation	Type of Sub-Station (33/11 or 66/11 KV)	Power Transformer Detail (MVA)	Total Power Transformer Capacity (MVA)	Constructed Under(Scheme)	GPS Co-ordinate	Name of Feeding EHV SubStation	Distance from Feeding EHV SubStation (in KM)	Type	Existing 11 KV Bay
1	Ahiraula	AHIRAULA	33/11 KV	1x5+0+0+0+0	5	1	N26 12.487 E82 54.959	Phoolpur	22	Radial	3
		MDIYAPAR	33/11 KV	1x5+0+0+0+0	5	1	N26 16.104 E82 55.609	Koilsa	18	Radial	3
		MAHUL	33/11 KV	1x5+0+0+0+0	5	1	N26 08.473 E82 48.518	Phoolpur	8	Radial	1
2	Atraulia	ATRAULIA	33/11 KV	1x5+1x5+0+0+0	10	1	N26 20.672 E82 55.608	Atrauliya	0.2	Radial	5
3	Azmatgarh	AMUWARI NARAINPUR	33/11 KV	1x3+0+0+0+0	3	1	N26 06.496 E83 21.656	Hafizpur	35	LILO	3
		JIYANPUR	33/11 KV	1x5+1x5+0+0+0	10	1	N26 09.522 E83 20.013	Hafizpur	19	Radial	5
		LATGHAT	33/11 KV	1x3+1x5+0+0+0	8	1	N26 13.405 E83 23.210	Dohri ghat (Mau District)	12	Radial	3
		MALTADI	33/11 KV	1x5+0+0+0+0	5	1	N26 10.689 E83 17.335	Dohri ghat (Mau District)	25	LILO	3
4	Bilariyaganj	BILARIYAGANJ	33/11 KV	1x5+1x5+0+0+0	10	1	N26 11.815 E83 14.193	Hafizpur	17	Radial	4
		PATWADH KAUTAK	33/11 KV	1x5+0+0+0+0	5	1	N26 09.246 E83 12.296	Hafizpur	10	LILO	3
5	Haraiya	RAUNAPUR	33/11 KV	1x5+0+0+0+0	5	1	N26 16.787 E83 16.983	Hafizpur	30	LILO	4
		MAU KUTUBPUR	33/11 KV	1x3+0+0+0+0	3	1	N26 14.693 E83 17.184	Dohri ghat (Mau District)	7	LILO	3
6	Jahanaganj	CHANDESHWAR	33/11 KV	1x5+1x5+0+0+0	10	1	N26 00.041 E83 12.475	Sidhari	7	Radial	4
		JAHANGANJ	33/11 KV	1x5+1x5+0+0+0	10	1	N25 56.529 E83 16.391	Sidhari	20	Radial	4
		KANILA	33/11 KV	1x5+0+0+0+0	5	1	N25 53.762 E83 13.272	Sidhari	20	LILO	3

Existing REDB Infrastructure

State : UTTAR PRADESH
District : Azamgarh

S.No.	Name of Block	Name of SubStation	Type of Sub-Station (33/11 or 66/11 KV)	Power Transformer Detail (MVA)	Total Power Transformer Capacity (MVA)	Constructed Under(Scheme)	GPS Co-ordinate	Name of Feeding EHV SubStation	Distance from Feeding EHV SubStation (in KM)	Type	Existing 11 KV Bay
		SHERPUR	33/11 KV	1x5+0+0+0+0	5	1	N25 52.687 E83 17.082	Sidhari	35	LILO	2
7	Koilsa	GOPALGANJ	33/11 KV	1x5+0+0+0+0	5	1	N26 11.818 E82 59.383	Koilsa	20	LILO	2
		RANIPUR	33/11 KV	1x5+0+0+0+0	5	1	N26 16.260 E83 01.383	Koilsa	0.2	LILO	3
		SIKHULA	33/11 KV	1x5+0+0+0+0	5	1	N26 14.798 E82 58.011	Koilsa	31	LILO	3
		TEHSIL BURHANPUR	33/11 KV	1x5+0+0+0+0	5	1	N26 17.224 E82 59.999	Koilsa	15	Radial	3
8	Lalganj	DEOGAON	33/11 KV	1x5+0+0+0+0	5	1	N25 44.522 E82 59.939	Lalganj	7	Radial	3
		LALGANJ	33/11 KV	1x5+1x10+0+0+0	15	1	N25 47.734 E82 59.737	Lalganj	0.05	Radial	5
		JIRAKPUR	33/11 KV	1x5+0+0+0+0	5	1	N25 45.250 E82 56.864	Lalganj	17	Radial	2
		GOSAI KI BAZAR	33/11 KV	1x5+0+0+0+0	5	1	N25 51.259 E83 00.705	Lalganj	8	Radial	3
9	Mahrajanj	MAHRAJGANJ	33/11 KV	1x3+1x5+0+0+0	8	1	N26 15.231 E83 07.230	Koilsa	10	LILO	4
		KAPTANGANJ	33/11 KV	1x3+1x5+0+0+0	8	1	N26 12.381 E83 05.103	Koilsa	10	Radial	4
10	Martinganj	MARTINGANJ	33/11 KV	1x5+0+0+0+0	5	1	N25 54.5081 E82 48.4127	Lalganj	35	LILO	3
11	Mehnnagar	MEH NAGAR	33/11 KV	1x5+1x5+0+0+0	10	1	N25 53.351 E83 05.641	Meh Nagar	1	Radial	4
		KHAMARIYA	33/11 KV	1x5+0+0+0+0	5	1	N25 48.663 E83 12.235	Lalganj	32	LILO	2
12	Mirzapur	DATTATREYA	33/11 KV	1x5+0+0+0+0	5	1	N26 03.683 E83 01.383	Phoolpur	17	Radial	3

Existing REDB Infrastructure

State : UTTAR PRADESH
District : Azamgarh

S.No.	Name of Block	Name of SubStation	Type of Sub-Station (33/11 or 66/11 KV)	Power Transformer Detail (MVA)	Total Power Transformer Capacity (MVA)	Constructed Under(Scheme)	GPS Co-ordinate	Name of Feeding EHV SubStation	Distance from Feeding EHV SubStation (in KM)	Type	Existing 11 KV Bay
		SARAI MEER	33/11 KV	1x5+1x5+0+0+0	10	1	N26 01.544 E82 53.791	Phoolpur	10	Radial	3
13	Mohammadpur	CHHAU	33/11 KV	1x5+0+0+0+0	5	1	N25 56.828 E82 57.078	Lalganj	32	LILO	3
		MUHAMMAD PUR	33/11 KV	1x5+1x5+0+0+0	10	1	N25 56.902 E83 01.669	Sidhari	22	Radial	4
		GOTHAWAN	33/11 KV	1x5+0+0+0+0	5	1	N25 56.213 E82 54.166	Lalganj	20	LILO	2
14	Palhani	ZAFFARPUR	33/11 KV	1x5+1x10+0+0+0	15	1	N26 02.620 E83 09.220	Hafizpur	18	LILO	4
15	Palhna	SHEIKHPURA	33/11 KV	1x5+0+0+0+0	5	1	N26 04.284 E83 12.378	Hafizpur	2	Radial	2
		KARSARA	33/11 KV	1x5+0+0+0+0	5	1	N25 43.438 E83 05.619	Lalganj	20	LILO	3
		PALAHANA	33/11 KV	1x3+0+0+0+0	3	1	N25 45.993 E83 04.677	Lalganj	10.5	LILO	2
		BHAWAR NATH	33/11 KV	1x5+1x10+0+0+0	15	1	N26 05.621 E83 09.412	Hafizpur	5	Radial	3
		KANDHARPUR	33/11 KV	1x5+0+0+0+0	5	1	N26 08.031 E83 07.675	Hafizpur	35	Radial	2
16	Pawai	BAGH BAHAR	33/11 KV	1x5+0+0+0+0	5	1	N26 08.668 E82 42.871	Phoolpur	20	LILO	3
		PAWAI	33/11 KV	1x5+1x5+0+0+0	10	1	N26 10.523 E82 43.731	Phoolpur	17	Radial	4
17	Phulpur	PHOOLPUR	33/11 KV	1x8+1x10+0+0+0	18	1	N26 05.607 E82 52.054	Phoolpur	1	Radial	6
		GADDO PUR	33/11 KV	1x5+0+0+0+0	5	1	N26 02.598 E82 47.620	Phoolpur	20	LILO	2
		PUSHP NAGAR	33/11 KV	1x5+0+0+0+0	5	1	N26 00.345 E82 48.169	Phoolpur	16	LILO	3

Existing REDB Infrastructure

State : UTTAR PRADESH
District : Azamgarh

S.No.	Name of Block	Name of SubStation	Type of Sub-Station (33/11 or 66/11 KV)	Power Transformer Detail (MVA)	Total Power Transformer Capacity (MVA)	Constructed Under(Scheme)	GPS Co-ordinate	Name of Feeding EHV SubStation	Distance from Feeding EHV SubStation (in KM)	Type	Existing 11 KV Bay
18	Rani Ki Sarai	RANI KI SARAI	33/11 KV	1x3+1x5+0+0+0	8	1	N25 59.755 E83 05.513	Sidhari	12	LILO	3
19	Sathiyaon	MOHABBATPUR	33/11 KV	1x5+0+0+0+0	5	1	N26 03.582 E83 14.569	Hafizpur	12	LILO	2
		MUBARAKPUR	33/11 KV	1x10+1x10+0+0+0	20	1	N26 04.648 E83 17.700	Hafizpur	18	Radial	5
20	Tahbarpur	SOFIPUR	33/11 KV	1x5+1x5+0+0+0	10	1	N26 05.414 E83 04.226	Sidhari	20	Radial	4
		ORA	33/11 KV	1x3+0+0+0+0	3	1	N26 08.935 E83 03.324	Sidhari	28	LILO	3
		MANJHARI	33/11 KV	1x5+0+0+0+0	5	1	N26 06.865 E83 00.469	Phoolpur	21	LILO	3
21	Tarwa	RASEPUR	33/11 KV	1x5+0+0+0+0	5	1	N25 50.090 E83 18.898	Sidhari	50	LILO	3
		TARWA	33/11 KV	1x3+1x5+0+0+0	8	1	N25 45.858 E83 11.025	Lalganj	20	Radial	4
		MEHNAJPUR	33/11 KV	1x5+0+0+0+0	5	1	N25 40.749 E83 06.729	Lalganj	30	LILO	3
22	Thekma	BARDAH	33/11 KV	1x5+0+0+0+0	5	1	N25 48.373 E82 50.762	Lalganj	20	Radial	3
		THEKMA	33/11 KV	1x3+1x5+0+0+0	8	1	N25 51.783 E82 55.463	Lalganj	17	Radial	4
Total					398						

Block-Wise Substation

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of Block	Existing 33/11 kV Sub-Station as on 31.03.2015		33/11 kV Sub-Station already sanctioned and under execution in RGGVY/State/Other schemes as on 31.03.2015		New 33/11 kV Sub-Stations proposed under present scheme		Aug of existing 33/11kV Sub-Stations proposed in the scheme		Total 33/11 kV	
		No. of S/s (Nos)	PT Capacity (MVA)	No. of S/s (Nos)	PT Capacity (MVA)	No. of S/s (Nos)	PT Capacity (MVA)	No. of S/s (Nos)	PT Capacity (MVA)	No. of S/s (Nos)	PT Capacity (MVA)
1	Ahiraula	3	15	0	0	0	0	0	0	3	15
2	Atraulia	1	10	0	0	0	0	0	0	1	10
3	Azmatgarh	4	26	0	0	0	0	0	0	4	26
4	Bilariyaganj	2	15	0	0	0	0	0	0	2	15
5	Haraiya	2	8	0	0	0	0	0	0	2	8
6	Jahanaganj	4	30	0	0	0	0	0	0	4	30
7	Koilsa	4	20	0	0	0	0	0	0	4	20
8	Lalganj	4	30	0	0	0	0	0	0	4	30
9	Mahrajanj	2	16	0	0	0	0	0	0	2	16
10	Martinganj	1	5	0	0	0	0	0	0	1	5
11	Mehnagar	2	15	0	0	0	0	0	0	2	15
12	Mirzapur	2	15	0	0	0	0	0	0	2	15
13	Mohammadpur	3	20	0	0	0	0	0	0	3	20
14	Palhani	1	15	0	0	0	0	0	0	1	15
15	Palhna	5	33	0	0	0	0	0	0	5	33
16	Pawai	2	15	0	0	0	0	0	0	2	15
17	Phulpur	3	28	0	0	0	0	0	0	3	28
18	Rani Ki Sarai	1	8	0	0	0	0	0	0	1	8
19	Sathiyaon	2	25	0	0	0	0	0	0	2	25
20	Tahbarpur	3	18	0	0	0	0	0	0	3	18

Block-Wise Substation

State : UTTAR PRADESH
 District : Azamgarh

Sl.No.	Name of Block	Existing 33/11 kV Sub-Station as on 31.03.2015		33/11 kV Sub-Station already sanctioned and under execution in RGGVY/State/Other schemes as on 31.03.2015		New 33/11 kV Sub-Stations proposed under present scheme		Aug of existing 33/11kV Sub-Stations proposed in the scheme		Total 33/11 kV	
		No. of S/s (Nos)	PT Capacity (MVA)	No. of S/s (Nos)	PT Capacity (MVA)	No. of S/s (Nos)	PT Capacity (MVA)	No. of S/s (Nos)	PT Capacity (MVA)	No. of S/s (Nos)	PT Capacity (MVA)
21	Tarwa	3	18	0	0	0	0	0	0	3	18
22	Thekma	2	13	0	0	0	0	0	0	2	13

Eligibility for Augmentation of Existing 33/11 KV Substations

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of existing 33/11 KV substation															GPS Coordinate						Capacity of Substation (In KVA)				
1	CHANDESHWAR															N26 00.041 E83 12.475						10000				
Feeder Details :-																										
Name of PTR		Capacity (In MVA)		Total Recorded Maximum Loading on Feeders(In Amp.)																		Total (In Amp.)	Equivalent MVA Loading	Max % Loading Recorded		
				Feeder 1		Feeder 2		Feeder 3		Feeder 4		Feeder 5		Feeder 6		Feeder 7		Feeder 8		Feeder 9		Feeder 10				
				Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity			
PTR-1		5		11 KV	200	11 KV	10	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	210	4	80.02
PTR-2		5		11 KV	80	11 KV	10	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	90	1.71	34.29
PTR-3		0		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PTR-4		0		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PTR-5		0		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
2	JAHANGANJ															N25 56.529 E83 16.391						10000				
Feeder Details :-																										
Name of PTR		Capacity (In MVA)		Total Recorded Maximum Loading on Feeders(In Amp.)																		Total (In Amp.)	Equivalent MVA Loading	Max % Loading Recorded		
				Feeder 1		Feeder 2		Feeder 3		Feeder 4		Feeder 5		Feeder 6		Feeder 7		Feeder 8		Feeder 9		Feeder 10				
				Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity			
PTR-1		5		11 KV	200	11 KV	140	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	340	6.48	129.55
PTR-2		5		11 KV	110	11 KV	100	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	210	4	80.02
PTR-3		0		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PTR-4		0		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PTR-5		0		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0

Eligibility for Augmentation of Existing 33/11 KV Substations

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of existing 33/11 KV substation												GPS Coordinate								Capacity of Substation (In KVA)				
3	KANILA												N25 53.762 E83 13.272								5000				
Feeder Details :-																									
Name of PTR		Capacity (In MVA)	Total Recorded Maximum Loading on Feeders(In Amp.)																		Total (In Amp.)	Equivalent MVA Loading	Max % Loading Recorded		
		Feeder 1		Feeder 2		Feeder 3		Feeder 4		Feeder 5		Feeder 6		Feeder 7		Feeder 8		Feeder 9		Feeder 10					
		Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity				
PTR-1		5	11 KV	40	0	0	11 KV	50	11 KV	55	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PTR-2		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PTR-3		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PTR-4		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PTR-5		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
4	SHERPUR												N25 52.687 E83 17.082								5000				
Feeder Details :-																									
Name of PTR		Capacity (In MVA)	Total Recorded Maximum Loading on Feeders(In Amp.)																		Total (In Amp.)	Equivalent MVA Loading	Max % Loading Recorded		
		Feeder 1		Feeder 2		Feeder 3		Feeder 4		Feeder 5		Feeder 6		Feeder 7		Feeder 8		Feeder 9		Feeder 10					
		Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity				
PTR-1		5	11 KV	15	11 KV	5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PTR-2		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PTR-3		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PTR-4		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PTR-5		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0

Eligibility for Augmentation of Existing 33/11 KV Substations

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of existing 33/11 KV substation												GPS Coordinate								Capacity of Substation (In KVA)					
5	GOPALGANJ												N26 11.818 E82 59.383								5000					
Feeder Details :-																										
Name of PTR	Capacity (In MVA)	Total Recorded Maximum Loading on Feeders(In Amp.)																				Total (In Amp.)	Equivalent MVA Loading	Max % Loading Recorded		
		Feeder 1		Feeder 2		Feeder 3		Feeder 4		Feeder 5		Feeder 6		Feeder 7		Feeder 8		Feeder 9		Feeder 10						
		Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity					
PTR-1	5	11 KV	60	11 KV	40	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	100	1.91	38.1
PTR-2	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PTR-3	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PTR-4	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PTR-5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
6	RANIPUR												N26 16.260 E83 01.383								5000					
Feeder Details :-																										
Name of PTR	Capacity (In MVA)	Total Recorded Maximum Loading on Feeders(In Amp.)																				Total (In Amp.)	Equivalent MVA Loading	Max % Loading Recorded		
		Feeder 1		Feeder 2		Feeder 3		Feeder 4		Feeder 5		Feeder 6		Feeder 7		Feeder 8		Feeder 9		Feeder 10						
		Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity					
PTR-1	5	11 KV	5	11 KV	50	11 KV	120	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	175	3.33	66.68
PTR-2	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PTR-3	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PTR-4	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PTR-5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0

Eligibility for Augmentation of Existing 33/11 KV Substations

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of existing 33/11 KV substation															GPS Coordinate						Capacity of Substation (In KVA)				
7	SIKHULA															N26 14.798 E82 58.011						5000				
Feeder Details :-																										
Name of PTR	Capacity (In MVA)	Total Recorded Maximum Loading on Feeders(In Amp.)																				Total (In Amp.)	Equivalent MVA Loading	Max % Loading Recorded		
		Feeder 1		Feeder 2		Feeder 3		Feeder 4		Feeder 5		Feeder 6		Feeder 7		Feeder 8		Feeder 9		Feeder 10						
		Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity					
PTR-1	5	11 KV	32	11 KV	25	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	57	1.09	21.72
PTR-2	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PTR-3	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PTR-4	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PTR-5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
8	TEHSIL BURHANPUR															N26 17.224 E82 59.999						5000				
Feeder Details :-																										
Name of PTR	Capacity (In MVA)	Total Recorded Maximum Loading on Feeders(In Amp.)																				Total (In Amp.)	Equivalent MVA Loading	Max % Loading Recorded		
		Feeder 1		Feeder 2		Feeder 3		Feeder 4		Feeder 5		Feeder 6		Feeder 7		Feeder 8		Feeder 9		Feeder 10						
		Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity					
PTR-1	5	11 KV	55	11 KV	5	11 KV	70	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	130	2.48	49.54
PTR-2	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PTR-3	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PTR-4	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PTR-5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0

Eligibility for Augmentation of Existing 33/11 KV Substations

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of existing 33/11 KV substation														GPS Coordinate						Capacity of Substation (In KVA)					
9	BAGH BAHAR														N26 08.668 E82 42.871						5000					
Feeder Details :-																										
Name of PTR	Capacity (In MVA)	Total Recorded Maximum Loading on Feeders(In Amp.)																				Total (In Amp.)	Equivalent MVA Loading	Max % Loading Recorded		
		Feeder 1		Feeder 2		Feeder 3		Feeder 4		Feeder 5		Feeder 6		Feeder 7		Feeder 8		Feeder 9		Feeder 10						
		Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity					
PTR-1	5	11 KV	29	11 KV	66	11 KV	76	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	171	3.26	65.16
PTR-2	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PTR-3	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PTR-4	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PTR-5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
10	ATRAULIA														N26 20.672 E82 55.608						10000					
Feeder Details :-																										
Name of PTR	Capacity (In MVA)	Total Recorded Maximum Loading on Feeders(In Amp.)																				Total (In Amp.)	Equivalent MVA Loading	Max % Loading Recorded		
		Feeder 1		Feeder 2		Feeder 3		Feeder 4		Feeder 5		Feeder 6		Feeder 7		Feeder 8		Feeder 9		Feeder 10						
		Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity					
PTR-1	5	11 KV	70	11 KV	70	11 KV	100	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	240	4.57	91.45	
PTR-2	5	11 KV	130	11 KV	40	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	170	3.24	64.78	
PTR-3	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PTR-4	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PTR-5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0

Eligibility for Augmentation of Existing 33/11 KV Substations

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of existing 33/11 KV substation															GPS Coordinate					Capacity of Substation (In KVA)										
11	AHIRAULA															N26 12.487 E82 54.959					5000										
Feeder Details :-																															
Name of PTR	Capacity (In MVA)	Total Recorded Maximum Loading on Feeders(In Amp.)																				Total (In Amp.)	Equivalent MVA Loading	Max % Loading Recorded							
		Feeder 1		Feeder 2		Feeder 3		Feeder 4		Feeder 5		Feeder 6		Feeder 7		Feeder 8		Feeder 9		Feeder 10											
		Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity										
PTR-1	5	11 KV	200	11 KV	60	11 KV	65	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	325	6.19	123.84	
PTR-2	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
PTR-3	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
PTR-4	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
PTR-5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
12	MDIYAPAR															N26 16.104 E82 55.609					5000										
Feeder Details :-																															
Name of PTR	Capacity (In MVA)	Total Recorded Maximum Loading on Feeders(In Amp.)																				Total (In Amp.)	Equivalent MVA Loading	Max % Loading Recorded							
		Feeder 1		Feeder 2		Feeder 3		Feeder 4		Feeder 5		Feeder 6		Feeder 7		Feeder 8		Feeder 9		Feeder 10											
		Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity										
PTR-1	5	11 KV	40	11 KV	35	11 KV	20	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	95	1.81	36.2
PTR-2	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PTR-3	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PTR-4	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PTR-5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0

Eligibility for Augmentation of Existing 33/11 KV Substations

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of existing 33/11 KV substation															GPS Coordinate					Capacity of Substation (In KVA)				
13	MAHRAJGANJ															N26 15.231 E83 07.230					8000				
Feeder Details :-																									
Name of PTR		Capacity (In MVA)	Total Recorded Maximum Loading on Feeders(In Amp.)																			Total (In Amp.)	Equivalent MVA Loading	Max % Loading Recorded	
		Feeder 1		Feeder 2		Feeder 3		Feeder 4		Feeder 5		Feeder 6		Feeder 7		Feeder 8		Feeder 9		Feeder 10					
		Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity				
PTR-1		3	11 KV 65	11 KV 35	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	100	1.91	63.51
PTR-2		5	11 KV 120	11 KV 180	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	300	5.72	114.31
PTR-3		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PTR-4		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PTR-5		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
14	KAPTANGANJ															N26 12.381 E83 05.103					8000				
Feeder Details :-																									
Name of PTR		Capacity (In MVA)	Total Recorded Maximum Loading on Feeders(In Amp.)																			Total (In Amp.)	Equivalent MVA Loading	Max % Loading Recorded	
		Feeder 1		Feeder 2		Feeder 3		Feeder 4		Feeder 5		Feeder 6		Feeder 7		Feeder 8		Feeder 9		Feeder 10					
		Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity				
PTR-1		3	11 KV 60	11 KV 105	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	165	3.14	104.79
PTR-2		5	11 KV 125	11 KV 125	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	250	4.76	95.26
PTR-3		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PTR-4		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PTR-5		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0

Eligibility for Augmentation of Existing 33/11 KV Substations

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of existing 33/11 KV substation											GPS Coordinate										Capacity of Substation (In KVA)			
15	RASEPUR											N25 50.090 E83 18.898										5000			
Feeder Details :-																									
Name of PTR	Capacity (In MVA)	Total Recorded Maximum Loading on Feeders(In Amp.)																				Total (In Amp.)	Equivalent MVA Loading	Max % Loading Recorded	
		Feeder 1		Feeder 2		Feeder 3		Feeder 4		Feeder 5		Feeder 6		Feeder 7		Feeder 8		Feeder 9		Feeder 10					
		Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity				
PTR-1	5	11 KV	95	11 KV	75	11 KV	40	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	210	4	80.02
PTR-2	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PTR-3	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PTR-4	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PTR-5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
16	TARWA											N25 45.858 E83 11.025										8000			
Feeder Details :-																									
Name of PTR	Capacity (In MVA)	Total Recorded Maximum Loading on Feeders(In Amp.)																				Total (In Amp.)	Equivalent MVA Loading	Max % Loading Recorded	
		Feeder 1		Feeder 2		Feeder 3		Feeder 4		Feeder 5		Feeder 6		Feeder 7		Feeder 8		Feeder 9		Feeder 10					
		Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity				
PTR-1	3	11 KV	90	11 KV	60	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	150	2.86	95.26
PTR-2	5	11 KV	70	11 KV	130	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	200	3.81	76.21
PTR-3	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PTR-4	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PTR-5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0

Eligibility for Augmentation of Existing 33/11 KV Substations

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of existing 33/11 KV substation															GPS Coordinate					Capacity of Substation (In KVA)						
17	MEHNAJPUR															N25 40.749 E83 06.729					5000						
Feeder Details :-																											
Name of PTR	Capacity (In MVA)	Total Recorded Maximum Loading on Feeders(In Amp.)																				Total (In Amp.)	Equivalent MVA Loading	Max % Loading Recorded			
		Feeder 1		Feeder 2		Feeder 3		Feeder 4		Feeder 5		Feeder 6		Feeder 7		Feeder 8		Feeder 9		Feeder 10							
		Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity						
PTR-1	5	11 KV	145	11 KV	65	11 KV	65	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	275	5.24	104.79	
PTR-2	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PTR-3	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PTR-4	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PTR-5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
18	RAUNAPUR															N26 16.787 E83 16.983					5000						
Feeder Details :-																											
Name of PTR	Capacity (In MVA)	Total Recorded Maximum Loading on Feeders(In Amp.)																				Total (In Amp.)	Equivalent MVA Loading	Max % Loading Recorded			
		Feeder 1		Feeder 2		Feeder 3		Feeder 4		Feeder 5		Feeder 6		Feeder 7		Feeder 8		Feeder 9		Feeder 10							
		Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity						
PTR-1	5	11 KV	65	11 KV	70	11 KV	100	11 KV	20	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	255	4.86	97.17
PTR-2	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PTR-3	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PTR-4	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PTR-5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0

Eligibility for Augmentation of Existing 33/11 KV Substations

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of existing 33/11 KV substation															GPS Coordinate						Capacity of Substation (In KVA)						
19	BILARIYAGANJ															N26 11.815 E83 14.193						10000						
Feeder Details :-																												
Name of PTR		Capacity (In MVA)		Total Recorded Maximum Loading on Feeders(In Amp.)																			Total (In Amp.)	Equivalent MVA Loading	Max % Loading Recorded			
				Feeder 1		Feeder 2		Feeder 3		Feeder 4		Feeder 5		Feeder 6		Feeder 7		Feeder 8		Feeder 9		Feeder 10						
				Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity					
PTR-1		5		11 KV	90	11 KV	140	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	230	4.38	87.64
PTR-2		5		11 KV	145	11 KV	80	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	225	4.29	85.73
PTR-3		0		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PTR-4		0		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PTR-5		0		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
20	PATWADH KAUTAK															N26 09.246 E83 12.296						5000						
Feeder Details :-																												
Name of PTR		Capacity (In MVA)		Total Recorded Maximum Loading on Feeders(In Amp.)																			Total (In Amp.)	Equivalent MVA Loading	Max % Loading Recorded			
				Feeder 1		Feeder 2		Feeder 3		Feeder 4		Feeder 5		Feeder 6		Feeder 7		Feeder 8		Feeder 9		Feeder 10						
				Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity					
PTR-1		5		11 KV	120	11 KV	100	11 KV	60	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	280	5.33	106.69
PTR-2		0		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PTR-3		0		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PTR-4		0		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PTR-5		0		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0

Eligibility for Augmentation of Existing 33/11 KV Substations

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of existing 33/11 KV substation															GPS Coordinate					Capacity of Substation (In KVA)							
21	AMUWARI NARAINPUR															N26 06.496 E83 21.656					3000							
Feeder Details :-																												
Name of PTR	Capacity (In MVA)	Total Recorded Maximum Loading on Feeders(In Amp.)																				Total (In Amp.)	Equivalent MVA Loading	Max % Loading Recorded				
		Feeder 1		Feeder 2		Feeder 3		Feeder 4		Feeder 5		Feeder 6		Feeder 7		Feeder 8		Feeder 9		Feeder 10								
		Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity							
PTR-1	3	11 KV	75	11 KV	22	11 KV	35	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	132	2.51	83.83	
PTR-2	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PTR-3	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PTR-4	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PTR-5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
22	JIIYANPUR															N26 09.522 E83 20.013					10000							
Feeder Details :-																												
Name of PTR	Capacity (In MVA)	Total Recorded Maximum Loading on Feeders(In Amp.)																				Total (In Amp.)	Equivalent MVA Loading	Max % Loading Recorded				
		Feeder 1		Feeder 2		Feeder 3		Feeder 4		Feeder 5		Feeder 6		Feeder 7		Feeder 8		Feeder 9		Feeder 10								
		Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity							
PTR-1	5	11 KV	80	11 KV	80	11 KV	140	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	300	5.72	114.31	
PTR-2	5	11 KV	160	11 KV	60	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	220	4.19	83.83	
PTR-3	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PTR-4	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PTR-5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0

Eligibility for Augmentation of Existing 33/11 KV Substations

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of existing 33/11 KV substation															GPS Coordinate						Capacity of Substation (In KVA)				
23	LATGHAT															N26 13.405 E83 23.210						8000				
Feeder Details :-																										
Name of PTR		Capacity (In MVA)		Total Recorded Maximum Loading on Feeders(In Amp.)																			Total (In Amp.)	Equivalent MVA Loading	Max % Loading Recorded	
				Feeder 1		Feeder 2		Feeder 3		Feeder 4		Feeder 5		Feeder 6		Feeder 7		Feeder 8		Feeder 9		Feeder 10				
				Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity			
PTR-1		3		11 KV	70	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	70	1.33	44.45
PTR-2		5		11 KV	140	11 KV	140	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	280	5.33	106.69
PTR-3		0		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PTR-4		0		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PTR-5		0		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
24	SHEIKHPURA															N26 04.284 E83 12.378						5000				
Feeder Details :-																										
Name of PTR		Capacity (In MVA)		Total Recorded Maximum Loading on Feeders(In Amp.)																			Total (In Amp.)	Equivalent MVA Loading	Max % Loading Recorded	
				Feeder 1		Feeder 2		Feeder 3		Feeder 4		Feeder 5		Feeder 6		Feeder 7		Feeder 8		Feeder 9		Feeder 10				
				Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity			
PTR-1		5		11 KV	80	11 KV	25	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	105	2	40.01
PTR-2		0		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PTR-3		0		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PTR-4		0		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PTR-5		0		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0

Eligibility for Augmentation of Existing 33/11 KV Substations

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of existing 33/11 KV substation												GPS Coordinate								Capacity of Substation (In KVA)					
25	KARSARA												N25 43.438 E83 05.619								5000					
Feeder Details :-																										
Name of PTR		Capacity (In MVA)		Total Recorded Maximum Loading on Feeders(In Amp.)																		Total (In Amp.)	Equivalent MVA Loading	Max % Loading Recorded		
				Feeder 1		Feeder 2		Feeder 3		Feeder 4		Feeder 5		Feeder 6		Feeder 7		Feeder 8		Feeder 9					Feeder 10	
				Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity				Type	Capacity
PTR-1	5	11 KV	13	11 KV	70	11 KV	10	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	93	1.77	35.44	
PTR-2	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
PTR-3	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
PTR-4	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
PTR-5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
26	PALAHANA												N25 45.993 E83 04.677								3000					
Feeder Details :-																										
Name of PTR		Capacity (In MVA)		Total Recorded Maximum Loading on Feeders(In Amp.)																		Total (In Amp.)	Equivalent MVA Loading	Max % Loading Recorded		
				Feeder 1		Feeder 2		Feeder 3		Feeder 4		Feeder 5		Feeder 6		Feeder 7		Feeder 8		Feeder 9					Feeder 10	
				Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity				Type	Capacity
PTR-1	3	11 KV	110	11 KV	80	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	190	3.62	120.66	
PTR-2	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
PTR-3	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
PTR-4	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
PTR-5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	

Eligibility for Augmentation of Existing 33/11 KV Substations

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of existing 33/11 KV substation															GPS Coordinate						Capacity of Substation (In KVA)				
27	BHAWAR NATH															N26 05.621 E83 09.412						15000				
Feeder Details :-																										
Name of PTR		Capacity (In MVA)		Total Recorded Maximum Loading on Feeders(In Amp.)																		Total (In Amp.)	Equivalent MVA Loading	Max % Loading Recorded		
				Feeder 1		Feeder 2		Feeder 3		Feeder 4		Feeder 5		Feeder 6		Feeder 7		Feeder 8		Feeder 9		Feeder 10				
				Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity			
PTR-1		5		11 KV	160	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	160	3.05	60.97
PTR-2		10		11 KV	220	11 KV	100	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	320	6.1	60.97
PTR-3		0		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PTR-4		0		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PTR-5		0		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
28	KANDHARPUR															N26 08.031 E83 07.675						5000				
Feeder Details :-																										
Name of PTR		Capacity (In MVA)		Total Recorded Maximum Loading on Feeders(In Amp.)																		Total (In Amp.)	Equivalent MVA Loading	Max % Loading Recorded		
				Feeder 1		Feeder 2		Feeder 3		Feeder 4		Feeder 5		Feeder 6		Feeder 7		Feeder 8		Feeder 9		Feeder 10				
				Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity			
PTR-1		5		11 KV	110	11 KV	95	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	205	3.91	78.11
PTR-2		0		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PTR-3		0		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PTR-4		0		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PTR-5		0		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0

Eligibility for Augmentation of Existing 33/11 KV Substations

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of existing 33/11 KV substation															GPS Coordinate						Capacity of Substation (In KVA)						
29	SOFIPUR															N26 05.414 E83 04.226						10000						
Feeder Details :-																												
Name of PTR		Capacity (In MVA)		Total Recorded Maximum Loading on Feeders(In Amp.)																		Total (In Amp.)	Equivalent MVA Loading	Max % Loading Recorded				
				Feeder 1		Feeder 2		Feeder 3		Feeder 4		Feeder 5		Feeder 6		Feeder 7		Feeder 8		Feeder 9		Feeder 10						
				Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity					
PTR-1		5		11 KV	180	11 KV	55	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	235	4.48	89.54
PTR-2		5		11 KV	150	11 KV	10	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	160	3.05	60.97
PTR-3		0		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PTR-4		0		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PTR-5		0		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
30	ORA															N26 08.935 E83 03.324						3000						
Feeder Details :-																												
Name of PTR		Capacity (In MVA)		Total Recorded Maximum Loading on Feeders(In Amp.)																		Total (In Amp.)	Equivalent MVA Loading	Max % Loading Recorded				
				Feeder 1		Feeder 2		Feeder 3		Feeder 4		Feeder 5		Feeder 6		Feeder 7		Feeder 8		Feeder 9		Feeder 10						
				Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity					
PTR-1		3		11 KV	150	11 KV	30	11 KV	20	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	200	3.81	127.01
PTR-2		0		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PTR-3		0		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PTR-4		0		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PTR-5		0		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0

Eligibility for Augmentation of Existing 33/11 KV Substations

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of existing 33/11 KV substation												GPS Coordinate								Capacity of Substation (In KVA)						
31	MANJHARI												N26 06.865 E83 00.469								5000						
Feeder Details :-																											
Name of PTR	Capacity (In MVA)	Total Recorded Maximum Loading on Feeders(In Amp.)																				Total (In Amp.)	Equivalent MVA Loading	Max % Loading Recorded			
		Feeder 1		Feeder 2		Feeder 3		Feeder 4		Feeder 5		Feeder 6		Feeder 7		Feeder 8		Feeder 9		Feeder 10							
		Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity						
PTR-1	5	11 KV	50	11 KV	20	11 KV	40	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	110	2.1	41.91
PTR-2	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PTR-3	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PTR-4	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PTR-5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
32	DATTATREYA												N26 03.683 E83 01.383								5000						
Feeder Details :-																											
Name of PTR	Capacity (In MVA)	Total Recorded Maximum Loading on Feeders(In Amp.)																				Total (In Amp.)	Equivalent MVA Loading	Max % Loading Recorded			
		Feeder 1		Feeder 2		Feeder 3		Feeder 4		Feeder 5		Feeder 6		Feeder 7		Feeder 8		Feeder 9		Feeder 10							
		Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity						
PTR-1	5	11 KV	50	11 KV	150	11 KV	85	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	285	5.43	108.6
PTR-2	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PTR-3	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PTR-4	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PTR-5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0

Eligibility for Augmentation of Existing 33/11 KV Substations

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of existing 33/11 KV substation															GPS Coordinate						Capacity of Substation (In KVA)						
33	SARAI MEER															N26 01.544 E82 53.791						10000						
Feeder Details :-																												
Name of PTR		Capacity (In MVA)		Total Recorded Maximum Loading on Feeders(In Amp.)																		Total (In Amp.)	Equivalent MVA Loading	Max % Loading Recorded				
				Feeder 1		Feeder 2		Feeder 3		Feeder 4		Feeder 5		Feeder 6		Feeder 7		Feeder 8		Feeder 9		Feeder 10						
				Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity					
PTR-1		5		11 KV	150	11 KV	180	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	330	6.29	125.74
PTR-2		5		11 KV	200	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	200	3.81	76.21
PTR-3		0		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PTR-4		0		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PTR-5		0		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
34	RANI KI SARAI															N25 59.755 E83 05.513						8000						
Feeder Details :-																												
Name of PTR		Capacity (In MVA)		Total Recorded Maximum Loading on Feeders(In Amp.)																		Total (In Amp.)	Equivalent MVA Loading	Max % Loading Recorded				
				Feeder 1		Feeder 2		Feeder 3		Feeder 4		Feeder 5		Feeder 6		Feeder 7		Feeder 8		Feeder 9		Feeder 10						
				Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity					
PTR-1		3		11 KV	145	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	145	2.76	92.08
PTR-2		5		11 KV	60	11 KV	150	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	210	4	80.02
PTR-3		0		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PTR-4		0		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PTR-5		0		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0

Eligibility for Augmentation of Existing 33/11 KV Substations

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of existing 33/11 KV substation														GPS Coordinate						Capacity of Substation (In KVA)				
35	MOHABBATPUR														N26 03.582 E83 14.569						5000				
Feeder Details :-																									
Name of PTR	Capacity (In MVA)	Total Recorded Maximum Loading on Feeders(In Amp.)																				Total (In Amp.)	Equivalent MVA Loading	Max % Loading Recorded	
		Feeder 1		Feeder 2		Feeder 3		Feeder 4		Feeder 5		Feeder 6		Feeder 7		Feeder 8		Feeder 9		Feeder 10					
		Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity				
PTR-1	5	11 KV	95	11 KV	100	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	195	3.72	74.3
PTR-2	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PTR-3	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PTR-4	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PTR-5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
36	MUBARAKPUR														N26 04.648 E83 17.700						20000				
Feeder Details :-																									
Name of PTR	Capacity (In MVA)	Total Recorded Maximum Loading on Feeders(In Amp.)																				Total (In Amp.)	Equivalent MVA Loading	Max % Loading Recorded	
		Feeder 1		Feeder 2		Feeder 3		Feeder 4		Feeder 5		Feeder 6		Feeder 7		Feeder 8		Feeder 9		Feeder 10					
		Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity				
PTR-1	10	11 KV	210	11 KV	200	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	410	7.81	78.11	
PTR-2	10	11 KV	160	11 KV	180	11 KV	180	0	0	0	0	0	0	0	0	0	0	0	0	0	0	520	9.91	99.07	
PTR-3	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PTR-4	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PTR-5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0

Eligibility for Augmentation of Existing 33/11 KV Substations

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of existing 33/11 KV substation															GPS Coordinate					Capacity of Substation (In KVA)							
37	ZAFFARPUR															N26 02.620 E83 09.220					15000							
Feeder Details :-																												
Name of PTR		Capacity (In MVA)		Total Recorded Maximum Loading on Feeders(In Amp.)																		Total (In Amp.)	Equivalent MVA Loading	Max % Loading Recorded				
				Feeder 1		Feeder 2		Feeder 3		Feeder 4		Feeder 5		Feeder 6		Feeder 7		Feeder 8		Feeder 9		Feeder 10						
				Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity					
PTR-1		5		11 KV	20	11 KV	145	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	165	3.14	62.87
PTR-2		10		11 KV	200	11 KV	200	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	400	7.62	76.21
PTR-3		0		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PTR-4		0		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PTR-5		0		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
38	CHHAU															N25 56.828 E82 57.078					5000							
Feeder Details :-																												
Name of PTR		Capacity (In MVA)		Total Recorded Maximum Loading on Feeders(In Amp.)																		Total (In Amp.)	Equivalent MVA Loading	Max % Loading Recorded				
				Feeder 1		Feeder 2		Feeder 3		Feeder 4		Feeder 5		Feeder 6		Feeder 7		Feeder 8		Feeder 9		Feeder 10						
				Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity					
PTR-1		5		11 KV	145	11 KV	30	11 KV	65	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	240	4.57	91.45
PTR-2		0		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PTR-3		0		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PTR-4		0		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PTR-5		0		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0

Eligibility for Augmentation of Existing 33/11 KV Substations

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of existing 33/11 KV substation															GPS Coordinate						Capacity of Substation (In KVA)						
39	MUHAMMAD PUR															N25 56.902 E83 01.669						10000						
Feeder Details :-																												
Name of PTR		Capacity (In MVA)		Total Recorded Maximum Loading on Feeders(In Amp.)																		Total (In Amp.)	Equivalent MVA Loading	Max % Loading Recorded				
				Feeder 1		Feeder 2		Feeder 3		Feeder 4		Feeder 5		Feeder 6		Feeder 7		Feeder 8		Feeder 9		Feeder 10						
				Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity					
PTR-1		5		11 KV	255	11 KV	20	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	275	5.24	104.79
PTR-2		5		11 KV	135	11 KV	275	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	410	7.81	156.23
PTR-3		0		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PTR-4		0		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PTR-5		0		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
40	GOTHAWAN															N25 56.213 E82 54.166						5000						
Feeder Details :-																												
Name of PTR		Capacity (In MVA)		Total Recorded Maximum Loading on Feeders(In Amp.)																		Total (In Amp.)	Equivalent MVA Loading	Max % Loading Recorded				
				Feeder 1		Feeder 2		Feeder 3		Feeder 4		Feeder 5		Feeder 6		Feeder 7		Feeder 8		Feeder 9		Feeder 10						
				Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity					
PTR-1		5		11 KV	42	11 KV	58	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	100	1.91	38.1
PTR-2		0		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PTR-3		0		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PTR-4		0		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PTR-5		0		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0

Eligibility for Augmentation of Existing 33/11 KV Substations

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of existing 33/11 KV substation												GPS Coordinate								Capacity of Substation (In KVA)			
41	BARDAH												N25 48.373 E82 50.762								5000			
Feeder Details :-																								
Name of PTR		Capacity (In MVA)	Total Recorded Maximum Loading on Feeders(In Amp.)																		Total (In Amp.)	Equivalent MVA Loading	Max % Loading Recorded	
		Feeder 1		Feeder 2		Feeder 3		Feeder 4		Feeder 5		Feeder 6		Feeder 7		Feeder 8		Feeder 9		Feeder 10				
		Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity			
PTR-1		5	11 KV 110	11 KV 75	11 KV 50	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	235	4.48	89.54
PTR-2		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PTR-3		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PTR-4		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PTR-5		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
42	THEKMA												N25 51.783 E82 55.463								8000			
Feeder Details :-																								
Name of PTR		Capacity (In MVA)	Total Recorded Maximum Loading on Feeders(In Amp.)																		Total (In Amp.)	Equivalent MVA Loading	Max % Loading Recorded	
		Feeder 1		Feeder 2		Feeder 3		Feeder 4		Feeder 5		Feeder 6		Feeder 7		Feeder 8		Feeder 9		Feeder 10				
		Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity			
PTR-1		3	11 KV 100	11 KV 65	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	165	3.14	104.79
PTR-2		5	11 KV 110	11 KV 140	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	250	4.76	95.26
PTR-3		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PTR-4		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PTR-5		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0

Eligibility for Augmentation of Existing 33/11 KV Substations

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of existing 33/11 KV substation												GPS Coordinate								Capacity of Substation (In KVA)								
43	DEOGAON												N25 44.522 E82 59.939								5000								
Feeder Details :-																													
Name of PTR	Capacity (In MVA)	Total Recorded Maximum Loading on Feeders(In Amp.)																				Total (In Amp.)	Equivalent MVA Loading	Max % Loading Recorded					
		Feeder 1		Feeder 2		Feeder 3		Feeder 4		Feeder 5		Feeder 6		Feeder 7		Feeder 8		Feeder 9		Feeder 10									
		Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity								
PTR-1	5	11 KV	150	11 KV	100	11 KV	60	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	310	5.91	118.12
PTR-2	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PTR-3	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PTR-4	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PTR-5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
44	LALGANJ												N25 47.734 E82 59.737								15000								
Feeder Details :-																													
Name of PTR	Capacity (In MVA)	Total Recorded Maximum Loading on Feeders(In Amp.)																				Total (In Amp.)	Equivalent MVA Loading	Max % Loading Recorded					
		Feeder 1		Feeder 2		Feeder 3		Feeder 4		Feeder 5		Feeder 6		Feeder 7		Feeder 8		Feeder 9		Feeder 10									
		Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity								
PTR-1	5	11 KV	170	11 KV	220	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	390	7.43	148.61
PTR-2	10	11 KV	100	11 KV	120	11 KV	220	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	440	8.38	83.83
PTR-3	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PTR-4	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PTR-5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0

Eligibility for Augmentation of Existing 33/11 KV Substations

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of existing 33/11 KV substation												GPS Coordinate								Capacity of Substation (In KVA)					
45	JIRAKPUR												N25 45.250 E82 56.864								5000					
Feeder Details :-																										
Name of PTR	Capacity (In MVA)	Total Recorded Maximum Loading on Feeders(In Amp.)																				Total (In Amp.)	Equivalent MVA Loading	Max % Loading Recorded		
		Feeder 1		Feeder 2		Feeder 3		Feeder 4		Feeder 5		Feeder 6		Feeder 7		Feeder 8		Feeder 9		Feeder 10						
		Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity					
PTR-1	5	11 KV	70	11 KV	45	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	115	2.19	43.82
PTR-2	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PTR-3	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PTR-4	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PTR-5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
46	GOSAI KI BAZAR												N25 51.259 E83 00.705								5000					
Feeder Details :-																										
Name of PTR	Capacity (In MVA)	Total Recorded Maximum Loading on Feeders(In Amp.)																				Total (In Amp.)	Equivalent MVA Loading	Max % Loading Recorded		
		Feeder 1		Feeder 2		Feeder 3		Feeder 4		Feeder 5		Feeder 6		Feeder 7		Feeder 8		Feeder 9		Feeder 10						
		Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity					
PTR-1	5	11 KV	26	11 KV	60	11 KV	47	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	133	2.53	50.68
PTR-2	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PTR-3	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PTR-4	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PTR-5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0

Eligibility for Augmentation of Existing 33/11 KV Substations

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of existing 33/11 KV substation															GPS Coordinate						Capacity of Substation (In KVA)				
47	MEH NAGAR															N25 53.351 E83 05.641						10000				
Feeder Details :-																										
Name of PTR	Capacity (In MVA)	Total Recorded Maximum Loading on Feeders(In Amp.)																				Total (In Amp.)	Equivalent MVA Loading	Max % Loading Recorded		
		Feeder 1		Feeder 2		Feeder 3		Feeder 4		Feeder 5		Feeder 6		Feeder 7		Feeder 8		Feeder 9		Feeder 10						
		Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity					
PTR-1	5	11 KV	80	11 KV	160	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	240	4.57	91.45
PTR-2	5	11 KV	70	11 KV	90	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	160	3.05	60.97
PTR-3	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PTR-4	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PTR-5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
48	KHAMARIYA															N25 48.663 E83 12.235						5000				
Feeder Details :-																										
Name of PTR	Capacity (In MVA)	Total Recorded Maximum Loading on Feeders(In Amp.)																				Total (In Amp.)	Equivalent MVA Loading	Max % Loading Recorded		
		Feeder 1		Feeder 2		Feeder 3		Feeder 4		Feeder 5		Feeder 6		Feeder 7		Feeder 8		Feeder 9		Feeder 10						
		Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity					
PTR-1	5	11 KV	200	11 KV	200	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	400	7.62	152.42
PTR-2	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PTR-3	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PTR-4	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PTR-5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0

Eligibility for Augmentation of Existing 33/11 KV Substations

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of existing 33/11 KV substation															GPS Coordinate						Capacity of Substation (In KVA)			
49	PHOOLPUR															N26 05.607 E82 52.054						18000			
Feeder Details :-																									
Name of PTR		Capacity (In MVA)	Total Recorded Maximum Loading on Feeders(In Amp.)																			Total (In Amp.)	Equivalent MVA Loading	Max % Loading Recorded	
		Feeder 1		Feeder 2		Feeder 3		Feeder 4		Feeder 5		Feeder 6		Feeder 7		Feeder 8		Feeder 9		Feeder 10					
		Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity				
PTR-1		8	11 KV 140	11 KV 110	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	250	4.76	59.54	
PTR-2		10	11 KV 290	11 KV 260	11 KV 150	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	700	13.34	133.36	
PTR-3		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
PTR-4		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
PTR-5		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
50	GADDO PUR															N26 02.598 E82 47.620						5000			
Feeder Details :-																									
Name of PTR		Capacity (In MVA)	Total Recorded Maximum Loading on Feeders(In Amp.)																			Total (In Amp.)	Equivalent MVA Loading	Max % Loading Recorded	
		Feeder 1		Feeder 2		Feeder 3		Feeder 4		Feeder 5		Feeder 6		Feeder 7		Feeder 8		Feeder 9		Feeder 10					
		Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity				
PTR-1		5	11 KV 60	11 KV 55	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	115	2.19	43.82	
PTR-2		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
PTR-3		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
PTR-4		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
PTR-5		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	

Eligibility for Augmentation of Existing 33/11 KV Substations

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of existing 33/11 KV substation															GPS Coordinate						Capacity of Substation (In KVA)						
51	PAWAI															N26 10.523 E82 43.731						10000						
Feeder Details :-																												
Name of PTR		Capacity (In MVA)		Total Recorded Maximum Loading on Feeders(In Amp.)																		Total (In Amp.)	Equivalent MVA Loading	Max % Loading Recorded				
				Feeder 1		Feeder 2		Feeder 3		Feeder 4		Feeder 5		Feeder 6		Feeder 7		Feeder 8		Feeder 9		Feeder 10						
				Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity					
PTR-1		5		11 KV	150	11 KV	80	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	230	4.38	87.64
PTR-2		5		11 KV	135	11 KV	25	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	160	3.05	60.97
PTR-3		0		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PTR-4		0		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PTR-5		0		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
52	MAHUL															N26 08.473 E82 48.518						5000						
Feeder Details :-																												
Name of PTR		Capacity (In MVA)		Total Recorded Maximum Loading on Feeders(In Amp.)																		Total (In Amp.)	Equivalent MVA Loading	Max % Loading Recorded				
				Feeder 1		Feeder 2		Feeder 3		Feeder 4		Feeder 5		Feeder 6		Feeder 7		Feeder 8		Feeder 9		Feeder 10						
				Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity					
PTR-1		5		11 KV	170	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	170	3.24	64.78
PTR-2		0		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PTR-3		0		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PTR-4		0		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PTR-5		0		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0

Eligibility for Augmentation of Existing 33/11 KV Substations

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of existing 33/11 KV substation															GPS Coordinate						Capacity of Substation (In KVA)								
53	MAU KUTUBPUR															N26 14.693 E83 17.184						3000								
Feeder Details :-																														
Name of PTR		Capacity (In MVA)	Total Recorded Maximum Loading on Feeders(In Amp.)																				Total (In Amp.)	Equivalent MVA Loading	Max % Loading Recorded					
				Feeder 1		Feeder 2		Feeder 3		Feeder 4		Feeder 5		Feeder 6		Feeder 7		Feeder 8		Feeder 9		Feeder 10								
				Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity							
PTR-1		3	11 KV	25	11 KV	15	11 KV	90	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	130	2.48	82.56	
PTR-2		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
PTR-3		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
PTR-4		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
PTR-5		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
54	MALTADI															N26 10.689 E83 17.335						5000								
Feeder Details :-																														
Name of PTR		Capacity (In MVA)	Total Recorded Maximum Loading on Feeders(In Amp.)																				Total (In Amp.)	Equivalent MVA Loading	Max % Loading Recorded					
				Feeder 1		Feeder 2		Feeder 3		Feeder 4		Feeder 5		Feeder 6		Feeder 7		Feeder 8		Feeder 9		Feeder 10								
				Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity							
PTR-1		5	11 KV	100	11 KV	50	11 KV	50	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	200	3.81	76.21
PTR-2		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
PTR-3		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
PTR-4		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
PTR-5		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	

Eligibility for Augmentation of Existing 33/11 KV Substations

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of existing 33/11 KV substation															GPS Coordinate						Capacity of Substation (In KVA)				
55	PUSHP NAGAR															N26 00.345 E82 48.169						5000				
Feeder Details :-																										
Name of PTR		Capacity (In MVA)		Total Recorded Maximum Loading on Feeders(In Amp.)																				Total (In Amp.)	Equivalent MVA Loading	Max % Loading Recorded
				Feeder 1		Feeder 2		Feeder 3		Feeder 4		Feeder 5		Feeder 6		Feeder 7		Feeder 8		Feeder 9		Feeder 10				
				Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity			
PTR-1	5	11 KV	70	11 KV	45	11 KV	70	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	185	3.52	70.49	
PTR-2	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
PTR-3	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
PTR-4	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
PTR-5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
56	MARTINGANJ															N25 54.5081 E82 48.4127						5000				
Feeder Details :-																										
Name of PTR		Capacity (In MVA)		Total Recorded Maximum Loading on Feeders(In Amp.)																				Total (In Amp.)	Equivalent MVA Loading	Max % Loading Recorded
				Feeder 1		Feeder 2		Feeder 3		Feeder 4		Feeder 5		Feeder 6		Feeder 7		Feeder 8		Feeder 9		Feeder 10				
				Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity			
PTR-1	5	11 KV	100	11 KV	60	11 KV	120	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	280	5.33	106.69	
PTR-2	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
PTR-3	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
PTR-4	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
PTR-5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	

Feederwise DTs

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of Block	Name of 33/11 KV Source Substation	Name of 11 KV or 22 KV Feeder	Existing Distribution Transformer (DTs) as on 31.03.2015		Already sanctioned and under execution in RGGVY/State/Other schemes		DTs proposed to be installed under present scheme		Total DT capacity	
1	Ahiraula	AHIRAULA	Ahiraula	100	5.89	37	0.96	0	0	100	5.89
		AHIRAULA	Atraulia	83	2.41	31	0.81	0	0	83	2.41
		AHIRAULA	Kaptanganj	73	1.87	28	0.74	0	0	73	1.87
		MDIYAPAR	Karsara	69	1.78	25	0.63	0	0	69	1.78
		MDIYAPAR	Bhedaura	98	2.64	37	0.96	0	0	98	2.64
		MDIYAPAR	Badhiya	51	1.63	19	0.48	0	0	51	1.63
		MAHUL	Bazar Gosai	98	2.02	37	0.96	0	0	98	2.02
2	Atraulia	ATRAULIA	ATRAULIA	96	2.83	36	0.94	0	0	96	2.83
		ATRAULIA	WEST	77	2.09	29	0.76	0	0	77	2.09
		ATRAULIA	EAST	72	2	27	0.71	0	0	72	2
		ATRAULIA	NORTH	85	3.32	32	0.84	0	0	85	3.32
		ATRAULIA	West 2	56	2.61	20	0.5	0	0	56	2.61
3	Azmatgarh	AMUWARI NARAINPUR	East	74	3.5	28	0.74	0	0	74	3.5
		AMUWARI NARAINPUR	West	70	2.06	25	0.63	0	0	70	2.06
		AMUWARI NARAINPUR	Bhuana	76	2.84	29	0.76	0	0	76	2.84
		JIYANPUR	North	53	2.79	19	0.48	0	0	53	2.79
		JIYANPUR	East	90	3.04	34	0.89	0	0	90	3.04
		JIYANPUR	West	88	2.43	33	0.86	0	0	88	2.43
		LATGHAT	Kaithauli	109	2.71	41	1.06	0	0	109	2.71
		LATGHAT	Mahula	94	2.27	35	0.91	0	0	94	2.27
		LATGHAT	Bardeeha	74	2.11	28	0.74	0	0	74	2.11

Feederwise DTs

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of Block	Name of 33/11 KV Source Substation	Name of 11 KV or 22 KV Feeder	Existing Distribution Transformer (DTs) as on 31.03.2015		Already sanctioned and under execution in RGGVY/State/Other schemes		DTs proposed to be installed under present scheme		Total DT capacity	
		MALTADI	Basgaon	105	4.33	39	1.01	0	0	105	4.33
		MALTADI	North	74	1.8	28	0.74	0	0	74	1.8
		MALTADI	West	82	2.08	31	0.81	0	0	82	2.08
4	Bilariyaganj	BILARIYAGANJ	North	94	3.6	35	0.91	0	0	94	3.6
		BILARIYAGANJ	East	84	4.48	32	0.84	0	0	84	4.48
		BILARIYAGANJ	West	114	4.41	42	1.09	0	0	114	4.41
		PATWADH KAUTAK	EAST	98	2.85	37	0.96	0	0	98	2.85
		PATWADH KAUTAK	West	93	3.72	35	0.91	0	0	93	3.72
		PATWADH KAUTAK	South	97	2.95	36	0.94	0	0	97	2.95
5	Haraiya	RAUNAPUR	West	78	2.69	29	0.76	0	0	78	2.69
		RAUNAPUR	East	85	3.11	32	0.84	0	0	85	3.11
		RAUNAPUR	South	132	5.1	49	1.26	0	0	132	5.1
		MAU KUTUBPUR	North	41	0.74	15	0.38	0	0	41	0.74
		MAU KUTUBPUR	West	33	0.72	12	0.3	0	0	33	0.72
		MAU KUTUBPUR	Bazar Gosai	83	4.04	31	0.81	0	0	83	4.04
6	Jahanaganj	CHANDESHWAR	Nibi	90	4.85	34	0.89	0	0	90	4.85
		CHANDESHWAR	Sameda	55	0.77	20	0.5	0	0	55	0.77
		CHANDESHWAR	Karanpur	74	3.63	28	0.74	0	0	74	3.63
		JAHANGANJ	Jahanaganj	78	2.26	29	0.76	0	0	78	2.26
		JAHANGANJ	Parasi	66	2.95	24	0.6	0	0	66	2.95
		JAHANGANJ	Godhawra	66	3.24	24	0.6	0	0	66	3.24

Feederwise DTs

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of Block	Name of 33/11 KV Source Substation	Name of 11 KV or 22 KV Feeder	Existing Distribution Transformer (DTs) as on 31.03.2015		Already sanctioned and under execution in RGGVY/State/Other schemes		DTs proposed to be installed under present scheme		Total DT capacity	
		JAHANGANJ	Sumbhi	109	3.97	41	1.06	0	0	109	3.97
		KANILA	Barora	99	3.78	37	0.96	0	0	99	3.78
		KANILA	Jigarsandi	87	2.79	33	0.86	0	0	87	2.79
		SHERPUR	Sherpur Kuti	35	0.9	13	0.33	0	0	35	0.9
		SHERPUR	Parsaha	29	0.56	11	0.28	0	0	29	0.56
7	Koilsa	GOPALGANJ	Gopalganj	92	2.76	34	0.89	0	0	92	2.76
		GOPALGANJ	Marfora	68	2.1	25	0.63	0	0	68	2.1
		RANIPUR	Khatoliya Feeder	47	0.92	17	0.43	0	0	47	0.92
		RANIPUR	Tonari Feeder	72	1.6	27	0.71	0	0	72	1.6
		RANIPUR	Koilsa Feeder	92	3.77	34	0.89	0	0	92	3.77
		SIKHULA	Sultanipuri	97	2.14	36	0.94	0	0	97	2.14
		SIKHULA	Chimkuni	58	0.94	21	0.53	0	0	58	0.94
		TEHSIL BURHANPUR	Basgan	80	2.89	30	0.79	0	0	80	2.89
		TEHSIL BURHANPUR	Bheelampur	48	1.24	17	0.43	0	0	48	1.24
		TEHSIL BURHANPUR	Makhanaha	72	2	42	1.09	0	0	72	2
8	Lalganj	DEOGAON	Deogaon	74	2.04	28	0.74	0	0	74	2.04
		DEOGAON	Kanhjit	121	4.1	45	1.16	0	0	121	4.1
		DEOGAON	Basahi	91	2.64	34	0.89	0	0	91	2.64
		LALGANJ	Sonwar	89	2.77	33	0.86	0	0	89	2.77
		LALGANJ	Gosai bazar	93	2.94	35	0.91	0	0	93	2.94
		LALGANJ	Devgaon	77	1.8	29	0.76	0	0	77	1.8

Feederwise DTs

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of Block	Name of 33/11 KV Source Substation	Name of 11 KV or 22 KV Feeder	Existing Distribution Transformer (DTs) as on 31.03.2015		Already sanctioned and under execution in RGGVY/State/Other schemes		DTs proposed to be installed under present scheme		Total DT capacity	
		LALGANJ	Lumbhua	97	3.05	36	0.94	0	0	97	3.05
		JIRAKPUR	Sikraura	83	2.77	31	0.81	0	0	83	2.77
		JIRAKPUR	Agehta	55	2.36	20	0.5	0	0	55	2.36
		GOSAI KI BAZAR	Ubarpur	73	1.7	28	0.74	0	0	73	1.7
		GOSAI KI BAZAR	Gosai ki Bazar	79	1.55	30	0.79	0	0	79	1.55
		GOSAI KI BAZAR	Pandaha	92	3.06	34	0.89	0	0	92	3.06
9	Mahrajanj	MAHRAJGANJ	West	84	3.27	32	0.84	0	0	84	3.27
		MAHRAJGANJ	East	111	7.62	41	1.06	0	0	111	7.62
		MAHRAJGANJ	North	81	3.62	30	0.79	0	0	81	3.62
		MAHRAJGANJ	World bank	60	1.8	22	0.55	0	0	60	1.8
		KAPTANGANJ	Bhawanpur	85	2.45	32	0.84	0	0	85	2.45
		KAPTANGANJ	kaptanganj	43	1.42	16	0.4	0	0	43	1.42
		KAPTANGANJ	Deoria	86	2.32	32	0.84	0	0	86	2.32
		KAPTANGANJ	Mehmauni	74	2.04	28	0.74	0	0	74	2.04
10	Martinganj	MARTINGANJ	Bakhara Feeder	66	2.93	24	0.6	0	0	66	2.93
		MARTINGANJ	Siswara Feeder	66	2.09	24	0.6	0	0	66	2.09
		MARTINGANJ	Belwana Feeder	112	5.54	42	1.09	0	0	112	5.54
11	Mehnagar	MEH NAGAR	Laudah	87	2.5	33	0.86	0	0	87	2.5
		MEH NAGAR	Chakwara	75	1.4	28	0.74	0	0	75	1.4
		MEH NAGAR	Kharag Pur	39	1.34	14	0.35	0	0	39	1.34
		KHAMARIYA	Khatahan	110	2.87	40	1	0	0	110	2.87

Feederwise DTs

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of Block	Name of 33/11 KV Source Substation	Name of 11 KV or 22 KV Feeder	Existing Distribution Transformer (DTs) as on 31.03.2015		Already sanctioned and under execution in RGGVY/State/Other schemes		DTs proposed to be installed under present scheme		Total DT capacity	
		KHAMARIYA	Kamharia	128	4.06	47	1.18	0	0	128	4.06
12	Mirzapur	DATTATREYA	Nizamabad	64	2.09	23	0.58	0	0	64	2.09
		DATTATREYA	Mirzapur	102	3.17	38	0.99	0	0	102	3.17
		DATTATREYA	Mohnathpur	90	2.87	34	0.89	0	0	90	2.87
		SARAI MEER	Basti	64	1.49	23	0.58	0	0	64	1.49
		SARAI MEER	Nandau	90	3.18	34	0.89	0	0	90	3.18
13	Mohammadpur	CHHAU	Belu	149	5.92	55	1.41	0	0	149	5.92
		CHHAU	Chhau	60	1.69	22	0.55	0	0	60	1.69
		CHHAU	Gambhirpur	51	1.13	19	0.48	0	0	51	1.13
		MUHAMMAD PUR	North	51	1.58	19	0.48	0	0	51	1.58
		MUHAMMAD PUR	South	136	4.68	51	1.31	0	0	136	4.68
		MUHAMMAD PUR	Rowa	101	3.82	38	0.99	0	0	101	3.82
		MUHAMMAD PUR	Bindra Bazar	21	0.3	8	0.2	0	0	21	0.3
		GOTHAWAN	Gothawan	87	2.27	33	0.86	0	0	87	2.27
		GOTHAWAN	Nandaoh	65	2.87	24	0.6	0	0	65	2.87
14	Palhani	ZAFFARPUR	South	186	5.35	69	1.76	0	0	186	5.35
15	Palhna	SHEIKHPURA	Ahopatti	109	4.76	41	1.06	0	0	109	4.76
		SHEIKHPURA	Badhopur	62	1.74	23	0.58	0	0	62	1.74
		KARSARA	Chutara	29	0.73	11	0.28	0	0	29	0.73
		KARSARA	Karsara	154	5.84	57	1.46	0	0	154	5.84
		KARSARA	Bela	42	0.61	15	0.38	0	0	42	0.61

Feederwise DTs

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of Block	Name of 33/11 KV Source Substation	Name of 11 KV or 22 KV Feeder	Existing Distribution Transformer (DTs) as on 31.03.2015		Already sanctioned and under execution in RGGVY/State/Other schemes		DTs proposed to be installed under present scheme		Total DT capacity	
		PALAHANA	Palahana	77	2.48	28	0.7	0	0	77	2.48
		PALAHANA	Lhua	107	4.12	39	0.98	0	0	107	4.12
		BHAWAR NATH	Heera palti	111	2.53	41	1.06	0	0	111	2.53
		BHAWAR NATH	Kandharapur	88	2.11	33	0.86	0	0	88	2.11
		KANDHARPUR	Azampur	75	1.71	28	0.74	0	0	75	1.71
		KANDHARPUR	Kandharpur	69	1.99	25	0.63	0	0	69	1.99
16	Pawai	BAGH BAHAR	Kalan	72	2.34	27	0.71	0	0	72	2.34
		BAGH BAHAR	Sahdulla	68	2.91	25	0.63	0	0	68	2.91
		BAGH BAHAR	Khairuddinpur	82	2.59	31	0.81	0	0	82	2.59
		PAWAI	Mahul Feeder	85	5.22	32	0.84	0	0	85	5.22
		PAWAI	Belwai Feeder	102	4.53	38	0.99	0	0	102	4.53
		PAWAI	Balaipur Feeder	78	4.02	29	0.76	0	0	78	4.02
		PAWAI	Pawai	62	1.41	23	0.58	0	0	62	1.41
17	Phulpur	PHOOLPUR	North	109	2.91	41	1.06	0	0	109	2.91
		PHOOLPUR	West	71	3.03	26	0.65	0	0	71	3.03
		PHOOLPUR	East	71	1.77	26	0.65	0	0	71	1.77
		PHOOLPUR	South	71	1.92	26	0.65	0	0	71	1.92
		GADDO PUR	Palthi	60	3.19	22	0.55	0	0	60	3.19
		GADDO PUR	Gaddo Pur	85	2.86	31	0.78	0	0	85	2.86
		PUSHP NAGAR	Deedarganj	73	2.52	27	0.68	0	0	73	2.52
		PUSHP NAGAR	Sikraura	37	1.27	13	0.33	0	0	37	1.27

Feederwise DTs

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of Block	Name of 33/11 KV Source Substation	Name of 11 KV or 22 KV Feeder	Existing Distribution Transformer (DTs) as on 31.03.2015		Already sanctioned and under execution in RGGVY/State/Other schemes		DTs proposed to be installed under present scheme		Total DT capacity	
18	Rani Ki Sarai	RANI KI SARAI	Rani ki sarai	74	2.16	28	0.74	0	0	74	2.16
		RANI KI SARAI	Sonwara	111	3.76	41	1.06	0	0	111	3.76
		RANI KI SARAI	Vasti	75	2.09	28	0.74	0	0	75	2.09
19	Sathiyaon	MOHABBATPUR	Shahgarh	77	2.09	29	0.76	0	0	77	2.09
		MOHABBATPUR	Bamhaur	91	3.32	34	0.89	0	0	91	3.32
		MUBARAKPUR	Newada Rural	98	3.57	37	0.96	0	0	98	3.57
		MUBARAKPUR	Sthiyaon	79	2.52	30	0.79	0	0	79	2.52
20	Tahbarpur	SOFIPUR	Nizamabad	101	3.82	38	0.99	0	0	101	3.82
		SOFIPUR	Semari	51	1.24	19	0.48	0	0	51	1.24
		SOFIPUR	Nizamabad 2	86	3.37	32	0.84	0	0	86	3.37
		SOFIPUR	Tahbarpur	90	4.36	34	0.89	0	0	90	4.36
		ORA	Ora	75	1.37	28	0.74	0	0	75	1.37
		ORA	Deohatta	35	0.78	13	0.33	0	0	35	0.78
		ORA	Sarai Barkat	30	1.05	11	0.28	0	0	30	1.05
		MANJHARI	Dhania kundi	37	1.01	13	0.33	0	0	37	1.01
		MANJHARI	Manjhari	19	0.27	7	0.18	0	0	19	0.27
		MANJHARI	Kariawar	39	1.22	14	0.35	0	0	39	1.22
21	Tarwa	RASEPUR	Kanchanpur	89	4.11	33	0.86	0	0	89	4.11
		RASEPUR	Sherpur	102	3.86	38	0.99	0	0	102	3.86
		RASEPUR	Bongariya	86	2.73	32	0.84	0	0	86	2.73
		TARWA	Sidhauna	93	2.8	35	0.91	0	0	93	2.8

Feederwise DTs

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of Block	Name of 33/11 KV Source Substation	Name of 11 KV or 22 KV Feeder	Existing Distribution Transformer (DTs) as on 31.03.2015		Already sanctioned and under execution in RGGVY/State/Other schemes		DTs proposed to be installed under present scheme		Total DT capacity	
		TARWA	Meh Nagar	43	0.98	16	0.4	0	0	43	0.98
		TARWA	Mehnajpur	17	0.49	6	0.15	0	0	17	0.49
		MEHNAJPUR	Nath PUR	79	2.66	30	0.79	0	0	79	2.66
		MEHNAJPUR	Rowa para	86	3.03	32	0.84	0	0	86	3.03
		MEHNAJPUR	Mehnaj Pur	84	2.71	32	0.84	0	0	84	2.71
22	Thekma	BARDAH	Bardah	67	2.15	24	0.6	0	0	67	2.15
		BARDAH	Bahadurpur	109	3.82	41	1.06	0	0	109	3.82
		BARDAH	Jiblee	70	2.03	25	0.63	0	0	70	2.03
		THEKMA	Tahbarpur	105	3.14	38	0.95	0	0	105	3.14
		THEKMA	Sarai Mohan	85	2.65	31	0.78	0	0	85	2.65
		THEKMA	Thekma	112	3.98	42	1.09	0	0	112	3.98

Metering

State : UTTAR PRADESH

District : Azamgarh

DTR Metering

State : UTTAR PRADESH
District : Azamgarh

S.No.	Name of Block	Name of Sub-station	Name of Feeder	Description	No. of DTR installed	No. of DTR metered	No. of DTR meters already installed and to be installed under ongoing approved schemes (RGGVY/State/Other)	No. of DTR meter Proposed in DDUJY
1	Ahiraula	AHIRAULA	Ahiraula	10 KVA	21	3	0	3
				16 KVA	14	1	0	2
				25 KVA	18	3	0	3
				40 KVA	0	0	0	0
				63 KVA	20	1	0	3
				100 KVA	20	4	0	3
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	7	2	0	1
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
630 KVA	0	0	0	0				
2	Ahiraula	AHIRAULA	Atraulia	10 KVA	0	0	0	0
				16 KVA	31	2	0	5
				25 KVA	31	5	0	4
				40 KVA	0	0	0	0
				63 KVA	21	1	0	4
				100 KVA	0	0	0	0
				160 KVA	0	0	0	0

DTR Metering

State : UTTAR PRADESH
District : Azamgarh

				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
3	Ahiraula	AHIRAULA	Kaptanganj	10 KVA	32	4	0	5
				16 KVA	5	0	0	1
				25 KVA	21	3	0	3
				40 KVA	0	0	0	0
				63 KVA	15	1	0	3
				100 KVA	0	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
4	Ahiraula	MDIYAPAR	Karsara	10 KVA	25	3	0	4
				16 KVA	11	1	0	2
				25 KVA	20	3	0	3
				40 KVA	0	0	0	0
				63 KVA	12	1	0	2

DTR Metering

State : UTTAR PRADESH
District : Azamgarh

				100 KVA	1	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
5	Ahiraula	MDIYAPAR	Bhedaura	10 KVA	37	4	0	6
				16 KVA	14	1	0	2
				25 KVA	30	5	0	4
				40 KVA	0	0	0	0
				63 KVA	15	1	0	3
				100 KVA	1	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	1	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
6	Ahiraula	MDIYAPAR	Badhiya	10 KVA	22	3	0	3
				16 KVA	12	1	0	2
				25 KVA	11	2	0	2

DTR Metering

State : UTTAR PRADESH
District : Azamgarh

				40 KVA	0	0	0	0
				63 KVA	3	0	0	1
				100 KVA	1	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	1	0	0	0
				315 KVA	0	0	0	0
				400 KVA	1	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
7	Ahiraula	MAHUL	Bazar Gosai	10 KVA	55	7	0	9
				16 KVA	11	1	0	2
				25 KVA	20	3	0	3
				40 KVA	0	0	0	0
				63 KVA	11	1	0	2
				100 KVA	1	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
8	Atraulia	ATRAULIA	ATRAULIA	10 KVA	25	3	0	4

DTR Metering

State : UTTAR PRADESH
District : Azamgarh

				16 KVA	11	1	0	2
				25 KVA	41	6	0	6
				40 KVA	0	0	0	0
				63 KVA	14	1	0	2
				100 KVA	5	1	0	1
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
9	Atraulia	ATRAULIA	WEST	10 KVA	37	4	0	6
				16 KVA	16	1	0	3
				25 KVA	12	2	0	2
				40 KVA	0	0	0	0
				63 KVA	5	0	0	1
				100 KVA	6	1	0	1
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	1	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0

DTR Metering

State : UTTAR PRADESH
District : Azamgarh

				630 KVA	0	0	0	0
10	Atraulia	ATRAULIA	EAST	10 KVA	39	5	0	6
				16 KVA	5	0	0	1
				25 KVA	18	3	0	3
				40 KVA	0	0	0	0
				63 KVA	2	0	0	0
				100 KVA	7	1	0	1
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	1	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
11	Atraulia	ATRAULIA	NORTH	10 KVA	31	4	0	5
				16 KVA	5	0	0	1
				25 KVA	20	3	0	3
				40 KVA	0	0	0	0
				63 KVA	25	2	0	4
				100 KVA	1	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	3	1	0	0
				315 KVA	0	0	0	0

DTR Metering

State : UTTAR PRADESH
District : Azamgarh

				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
12	Atraulia	ATRAULIA	West 2	10 KVA	11	1	0	2
				16 KVA	6	0	0	1
				25 KVA	20	3	0	3
				40 KVA	0	0	0	0
				63 KVA	4	0	0	1
				100 KVA	14	3	0	2
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	1	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
13	Azmatgarh	AMUWARI NARAINPUR	East	10 KVA	25	3	0	4
				16 KVA	0	0	0	0
				25 KVA	25	4	0	4
				40 KVA	0	0	0	0
				63 KVA	6	0	0	1
				100 KVA	15	3	0	2
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0

DTR Metering

State : UTTAR PRADESH
District : Azamgarh

				250 KVA	3	1	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
14	Azmatgarh	AMUWARI NARAINPUR	West	10 KVA	22	3	0	3
				16 KVA	17	1	0	3
				25 KVA	16	2	0	2
				40 KVA	0	0	0	0
				63 KVA	13	1	0	2
				100 KVA	1	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	1	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
15	Azmatgarh	AMUWARI NARAINPUR	Bhuana	10 KVA	20	2	0	3
				16 KVA	17	1	0	3
				25 KVA	14	2	0	2
				40 KVA	0	0	0	0
				63 KVA	17	1	0	3
				100 KVA	7	1	0	1

DTR Metering

State : UTTAR PRADESH
District : Azamgarh

				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	1	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
16	Azmatgarh	JIYANPUR	North	10 KVA	21	3	0	3
				16 KVA	3	0	0	1
				25 KVA	11	2	0	2
				40 KVA	0	0	0	0
				63 KVA	8	1	0	1
				100 KVA	5	1	0	1
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	5	2	0	1
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
17	Azmatgarh	JIYANPUR	East	10 KVA	35	4	0	6
				16 KVA	5	0	0	1
				25 KVA	24	4	0	3
				40 KVA	0	0	0	0

DTR Metering

State : UTTAR PRADESH
District : Azamgarh

				63 KVA	20	1	0	3
				100 KVA	5	1	0	1
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	1	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
18	Azmatgarh	JIYANPUR	West	10 KVA	45	5	0	7
				16 KVA	4	0	0	1
				25 KVA	21	3	0	3
				40 KVA	0	0	0	0
				63 KVA	15	1	0	3
				100 KVA	2	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	1	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
19	Azmatgarh	LATGHAT	Kaithauli	10 KVA	50	6	0	8
				16 KVA	11	1	0	2

DTR Metering

State : UTTAR PRADESH
District : Azamgarh

				25 KVA	32	5	0	5
				40 KVA	0	0	0	0
				63 KVA	14	1	0	2
				100 KVA	1	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	1	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
20	Azmatgarh	LATGHAT	Mahula	10 KVA	57	7	0	9
				16 KVA	14	1	0	2
				25 KVA	10	2	0	1
				40 KVA	0	0	0	0
				63 KVA	6	0	0	1
				100 KVA	6	1	0	1
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	1	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0

DTR Metering

State : UTTAR PRADESH
District : Azamgarh

21	Azmatgarh	LATGHAT	Bardeeha	10 KVA	29	3	0	5
				16 KVA	7	1	0	1
				25 KVA	24	4	0	3
				40 KVA	0	0	0	0
				63 KVA	12	1	0	2
				100 KVA	1	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	1	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
22	Azmatgarh	MALTADI	Basgaon	10 KVA	40	5	0	6
				16 KVA	11	1	0	2
				25 KVA	30	5	0	4
				40 KVA	0	0	0	0
				63 KVA	8	1	0	1
				100 KVA	11	2	0	2
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	4	1	0	1
				315 KVA	0	0	0	0
				400 KVA	1	0	0	0

DTR Metering

State : UTTAR PRADESH
District : Azamgarh

				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
23	Azmatgarh	MALTADI	North	10 KVA	27	3	0	4
				16 KVA	11	1	0	2
				25 KVA	25	4	0	4
				40 KVA	0	0	0	0
				63 KVA	10	1	0	2
				100 KVA	1	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
24	Azmatgarh	MALTADI	West	10 KVA	29	3	0	5
				16 KVA	16	1	0	3
				25 KVA	22	3	0	3
				40 KVA	0	0	0	0
				63 KVA	14	1	0	2
				100 KVA	1	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0

DTR Metering

State : UTTAR PRADESH
District : Azamgarh

				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
25	Bilariyaganj	BILARIYAGANJ	North	10 KVA	25	3	0	4
				16 KVA	12	1	0	2
				25 KVA	29	4	0	4
				40 KVA	0	0	0	0
				63 KVA	14	1	0	2
				100 KVA	13	3	0	2
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	1	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
26	Bilariyaganj	BILARIYAGANJ	East	10 KVA	26	3	0	4
				16 KVA	10	1	0	2
				25 KVA	22	3	0	3
				40 KVA	0	0	0	0
				63 KVA	12	1	0	2
				100 KVA	7	1	0	1
				160 KVA	0	0	0	0

DTR Metering

State : UTTAR PRADESH
District : Azamgarh

				200 KVA	0	0	0	0
				250 KVA	5	2	0	1
				315 KVA	0	0	0	0
				400 KVA	2	1	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
27	Bilariyaganj	BILARIYAGANJ	West	10 KVA	40	5	0	6
				16 KVA	8	1	0	1
				25 KVA	27	4	0	4
				40 KVA	0	0	0	0
				63 KVA	31	2	0	5
				100 KVA	5	1	0	1
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	3	1	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
28	Bilariyaganj	PATWADH KAUTAK	EAST	10 KVA	45	5	0	7
				16 KVA	11	1	0	2
				25 KVA	22	3	0	3
				40 KVA	0	0	0	0
				63 KVA	17	1	0	3

DTR Metering

State : UTTAR PRADESH
District : Azamgarh

				100 KVA	1	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	2	1	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
29	Bilariyaganj	PATWADH KAUTAK	West	10 KVA	37	4	0	6
				16 KVA	13	1	0	2
				25 KVA	26	4	0	4
				40 KVA	0	0	0	0
				63 KVA	7	0	0	1
				100 KVA	6	1	0	1
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	1	0	0	0
				315 KVA	0	0	0	0
				400 KVA	3	1	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
30	Bilariyaganj	PATWADH KAUTAK	South	10 KVA	36	4	0	6
				16 KVA	16	1	0	3
				25 KVA	24	4	0	3

DTR Metering

State : UTTAR PRADESH
District : Azamgarh

				40 KVA	0	0	0	0
				63 KVA	18	1	0	3
				100 KVA	1	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	2	1	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
31	Haraiya	RAUNAPUR	West	10 KVA	20	2	0	3
				16 KVA	10	1	0	2
				25 KVA	29	4	0	4
				40 KVA	0	0	0	0
				63 KVA	16	1	0	3
				100 KVA	1	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	2	1	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
32	Haraiya	RAUNAPUR	East	10 KVA	40	5	0	6

DTR Metering

State : UTTAR PRADESH
District : Azamgarh

				16 KVA	16	1	0	3
				25 KVA	11	2	0	2
				40 KVA	0	0	0	0
				63 KVA	10	1	0	2
				100 KVA	4	1	0	1
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	3	1	0	0
				315 KVA	0	0	0	0
				400 KVA	1	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
33	Haraiya	RAUNAPUR	South	10 KVA	38	5	0	6
				16 KVA	18	1	0	3
				25 KVA	29	4	0	4
				40 KVA	0	0	0	0
				63 KVA	39	3	0	6
				100 KVA	5	1	0	1
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	3	1	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0

DTR Metering

State : UTTAR PRADESH
District : Azamgarh

				630 KVA	0	0	0	0
34	Haraiya	MAU KUTUBPUR	North	10 KVA	21	3	0	3
				16 KVA	14	1	0	2
				25 KVA	3	0	0	1
				40 KVA	0	0	0	0
				63 KVA	2	0	0	0
				100 KVA	1	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
35	Haraiya	MAU KUTUBPUR	West	10 KVA	13	2	0	2
				16 KVA	7	1	0	1
				25 KVA	9	1	0	1
				40 KVA	0	0	0	0
				63 KVA	4	0	0	1
				100 KVA	0	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0

DTR Metering

State : UTTAR PRADESH
District : Azamgarh

				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
36	Haraiya	MAU KUTUBPUR	Bazar Gosai	10 KVA	11	1	0	2
				16 KVA	6	0	0	1
				25 KVA	32	5	0	5
				40 KVA	0	0	0	0
				63 KVA	22	2	0	4
				100 KVA	9	2	0	1
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	3	1	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
37	Jahanaganj	CHANDESHWAR	Nibi	10 KVA	23	3	0	4
				16 KVA	11	1	0	2
				25 KVA	22	3	0	3
				40 KVA	0	0	0	0
				63 KVA	19	1	0	3
				100 KVA	8	2	0	1
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0

DTR Metering

State : UTTAR PRADESH
District : Azamgarh

				250 KVA	6	2	0	1
				315 KVA	0	0	0	0
				400 KVA	1	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
38	Jahanaganj	CHANDESHWAR	Sameda	10 KVA	32	4	0	5
				16 KVA	14	1	0	2
				25 KVA	9	1	0	1
				40 KVA	0	0	0	0
				63 KVA	0	0	0	0
				100 KVA	0	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
39	Jahanaganj	CHANDESHWAR	Karanpur	10 KVA	24	3	0	4
				16 KVA	5	0	0	1
				25 KVA	19	3	0	3
				40 KVA	0	0	0	0
				63 KVA	14	1	0	2
				100 KVA	8	2	0	1

DTR Metering

State : UTTAR PRADESH
District : Azamgarh

				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	3	1	0	0
				315 KVA	0	0	0	0
				400 KVA	1	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
40	Jahanaganj	JAHANGANJ	Parasi	10 KVA	28	3	0	5
				16 KVA	10	1	0	2
				25 KVA	7	1	0	1
				40 KVA	0	0	0	0
				63 KVA	10	1	0	2
				100 KVA	7	1	0	1
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	4	1	0	1
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
41	Jahanaganj	JAHANGANJ	Godhawra	10 KVA	21	3	0	3
				16 KVA	14	1	0	2
				25 KVA	11	2	0	2
				40 KVA	0	0	0	0

DTR Metering

State : UTTAR PRADESH
District : Azamgarh

				63 KVA	10	1	0	2
				100 KVA	5	1	0	1
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	4	1	0	1
				315 KVA	0	0	0	0
				400 KVA	1	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
42	Jahanaganj	JAHANGANJ	Sumbhi	10 KVA	25	3	0	4
				16 KVA	13	1	0	2
				25 KVA	45	7	0	6
				40 KVA	0	0	0	0
				63 KVA	18	1	0	3
				100 KVA	5	1	0	1
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	3	1	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
43	Jahanaganj	KANILA	Barora	10 KVA	31	4	0	5
				16 KVA	17	1	0	3

DTR Metering

State : UTTAR PRADESH
District : Azamgarh

				25 KVA	15	2	0	2
				40 KVA	0	0	0	0
				63 KVA	29	2	0	5
				100 KVA	5	1	0	1
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	2	1	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
44	Jahanaganj	KANILA	Jigarsandi	10 KVA	37	4	0	6
				16 KVA	16	1	0	3
				25 KVA	20	3	0	3
				40 KVA	0	0	0	0
				63 KVA	5	0	0	1
				100 KVA	6	1	0	1
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	3	1	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0

DTR Metering

State : UTTAR PRADESH
District : Azamgarh

45	Jahanaganj	SHERPUR	Sherpur Kuti	10 KVA	6	1	0	1
				16 KVA	8	1	0	1
				25 KVA	16	2	0	2
				40 KVA	0	0	0	0
				63 KVA	5	0	0	1
				100 KVA	0	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
46	Jahanaganj	SHERPUR	Parsaha	10 KVA	10	1	0	2
				16 KVA	6	0	0	1
				25 KVA	12	2	0	2
				40 KVA	0	0	0	0
				63 KVA	1	0	0	0
				100 KVA	0	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0

DTR Metering

State : UTTAR PRADESH
District : Azamgarh

				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
47	Koilsa	GOPALGANJ	Gopalganj	10 KVA	25	3	0	4
				16 KVA	12	1	0	2
				25 KVA	39	6	0	6
				40 KVA	0	0	0	0
				63 KVA	11	1	0	2
				100 KVA	4	1	0	1
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	1	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
48	Koilsa	GOPALGANJ	Marfora	10 KVA	26	3	0	4
				16 KVA	17	1	0	3
				25 KVA	12	2	0	2
				40 KVA	0	0	0	0
				63 KVA	5	0	0	1
				100 KVA	7	1	0	1
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	1	0	0	0

DTR Metering

State : UTTAR PRADESH
District : Azamgarh

				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
49	Koilsa	RANIPUR	Khatoliya Feeder	10 KVA	25	3	0	4
				16 KVA	12	1	0	2
				25 KVA	4	1	0	1
				40 KVA	0	0	0	0
				63 KVA	6	0	0	1
				100 KVA	0	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
50	Koilsa	RANIPUR	Tonari Feeder	10 KVA	36	4	0	6
				16 KVA	16	1	0	3
				25 KVA	15	2	0	2
				40 KVA	0	0	0	0
				63 KVA	1	0	0	0
				100 KVA	3	1	0	0
				160 KVA	0	0	0	0

DTR Metering

State : UTTAR PRADESH
District : Azamgarh

				200 KVA	0	0	0	0
				250 KVA	1	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
51	Koilsa	RANIPUR	Koilsa Feeder	10 KVA	22	3	0	3
				16 KVA	14	1	0	2
				25 KVA	28	4	0	4
				40 KVA	0	0	0	0
				63 KVA	21	1	0	4
				100 KVA	3	1	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	4	1	0	1
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
52	Koilsa	SIKHULA	Sultanipuri	10 KVA	31	4	0	5
				16 KVA	22	2	0	3
				25 KVA	34	5	0	5
				40 KVA	0	0	0	0
				63 KVA	10	1	0	2

DTR Metering

State : UTTAR PRADESH
District : Azamgarh

				100 KVA	0	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
53	Koilsa	SIKHULA	Chimkuni	10 KVA	31	4	0	5
				16 KVA	14	1	0	2
				25 KVA	11	2	0	2
				40 KVA	0	0	0	0
				63 KVA	2	0	0	0
				100 KVA	0	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
54	Koilsa	TEHSIL BURHANPUR	Basgan	10 KVA	10	1	0	2
				16 KVA	11	1	0	2
				25 KVA	30	5	0	4

DTR Metering

State : UTTAR PRADESH
District : Azamgarh

				40 KVA	0	0	0	0
				63 KVA	28	2	0	5
				100 KVA	1	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
55	Koilsa	TEHSIL BURHANPUR	Bheelampur	10 KVA	12	1	0	2
				16 KVA	5	0	0	1
				25 KVA	24	4	0	3
				40 KVA	0	0	0	0
				63 KVA	7	0	0	1
				100 KVA	0	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
56	Koilsa	TEHSIL BURHANPUR	Makhanaha	10 KVA	30	4	0	5

DTR Metering

State : UTTAR PRADESH
District : Azamgarh

				16 KVA	20	2	0	3
				25 KVA	13	2	0	2
				40 KVA	0	0	0	0
				63 KVA	4	0	0	1
				100 KVA	3	1	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	2	1	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
57	Lalganj	DEOGAON	Deogaon	10 KVA	40	5	0	6
				16 KVA	12	1	0	2
				25 KVA	14	2	0	2
				40 KVA	0	0	0	0
				63 KVA	4	0	0	1
				100 KVA	1	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	3	1	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0

DTR Metering

State : UTTAR PRADESH
District : Azamgarh

				630 KVA	0	0	0	0
58	Lalganj	DEOGAON	Kanhjit	10 KVA	27	3	0	4
				16 KVA	12	1	0	2
				25 KVA	51	8	0	7
				40 KVA	0	0	0	0
				63 KVA	24	2	0	4
				100 KVA	6	1	0	1
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	1	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
59	Lalganj	DEOGAON	Basahi	10 KVA	29	3	0	5
				16 KVA	4	0	0	1
				25 KVA	42	6	0	6
				40 KVA	0	0	0	0
				63 KVA	14	1	0	2
				100 KVA	1	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	1	0	0	0
				315 KVA	0	0	0	0

DTR Metering

State : UTTAR PRADESH
District : Azamgarh

				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
60	Lalganj	LALGANJ	Sonwar	10 KVA	26	3	0	4
				16 KVA	14	1	0	2
				25 KVA	28	4	0	4
				40 KVA	0	0	0	0
				63 KVA	18	1	0	3
				100 KVA	2	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	1	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
61	Lalganj	LALGANJ	Gosai bazar	10 KVA	25	3	0	4
				16 KVA	12	1	0	2
				25 KVA	34	5	0	5
				40 KVA	0	0	0	0
				63 KVA	19	1	0	3
				100 KVA	2	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0

DTR Metering

State : UTTAR PRADESH
District : Azamgarh

				250 KVA	1	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
62	Lalganj	LALGANJ	Devgaon	10 KVA	35	4	0	6
				16 KVA	18	1	0	3
				25 KVA	16	2	0	2
				40 KVA	0	0	0	0
				63 KVA	5	0	0	1
				100 KVA	2	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	1	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
63	Lalganj	LALGANJ	Lumbhua	10 KVA	44	5	0	7
				16 KVA	0	0	0	0
				25 KVA	31	5	0	4
				40 KVA	0	0	0	0
				63 KVA	14	1	0	2
				100 KVA	7	1	0	1

DTR Metering

State : UTTAR PRADESH
District : Azamgarh

				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	1	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
64	Lalganj	JIRAKPUR	Sikraura	10 KVA	21	3	0	3
				16 KVA	14	1	0	2
				25 KVA	28	4	0	4
				40 KVA	0	0	0	0
				63 KVA	14	1	0	2
				100 KVA	5	1	0	1
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	1	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
65	Lalganj	JIRAKPUR	Agehta	10 KVA	11	1	0	2
				16 KVA	2	0	0	0
				25 KVA	21	3	0	3
				40 KVA	0	0	0	0

DTR Metering

State : UTTAR PRADESH
District : Azamgarh

				63 KVA	15	1	0	3
				100 KVA	5	1	0	1
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	1	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
66	Lalganj	GOSAI KI BAZAR	Ubarpur	10 KVA	29	3	0	5
				16 KVA	12	1	0	2
				25 KVA	21	3	0	3
				40 KVA	0	0	0	0
				63 KVA	11	1	0	2
				100 KVA	0	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
67	Lalganj	GOSAI KI BAZAR	Gosai ki Bazar	10 KVA	48	6	0	8
				16 KVA	17	1	0	3

DTR Metering

State : UTTAR PRADESH
District : Azamgarh

				25 KVA	8	1	0	1
				40 KVA	0	0	0	0
				63 KVA	4	0	0	1
				100 KVA	1	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	1	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
68	Lalganj	GOSAI KI BAZAR	Pandaha	10 KVA	28	3	0	5
				16 KVA	16	1	0	3
				25 KVA	20	3	0	3
				40 KVA	0	0	0	0
				63 KVA	25	2	0	2
				100 KVA	2	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	1	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0

DTR Metering

State : UTTAR PRADESH
District : Azamgarh

69	Mahrajganj	MAHRAJGANJ	West	10 KVA	27	3	0	4
				16 KVA	17	1	0	3
				25 KVA	18	3	0	3
				40 KVA	0	0	0	0
				63 KVA	10	1	0	2
				100 KVA	9	2	0	1
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	3	1	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
70	Mahrajganj	MAHRAJGANJ	East	10 KVA	32	4	0	5
				16 KVA	5	0	0	1
				25 KVA	25	4	0	4
				40 KVA	0	0	0	0
				63 KVA	19	1	0	3
				100 KVA	15	3	0	2
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	14	4	0	2
				315 KVA	0	0	0	0
				400 KVA	1	0	0	0

DTR Metering

State : UTTAR PRADESH
District : Azamgarh

				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
71	Mahrajganj	MAHRAJGANJ	North	10 KVA	34	4	0	5
				16 KVA	4	0	0	1
				25 KVA	26	4	0	4
				40 KVA	0	0	0	0
				63 KVA	5	0	0	1
				100 KVA	5	1	0	1
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	7	2	0	1
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
72	Mahrajganj	MAHRAJGANJ	World bank	10 KVA	23	3	0	4
				16 KVA	4	0	0	1
				25 KVA	20	3	0	3
				40 KVA	0	0	0	0
				63 KVA	8	1	0	1
				100 KVA	5	1	0	1
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0

DTR Metering

State : UTTAR PRADESH
District : Azamgarh

				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
73	Mahrajganj	KAPTANGANJ	Bhawanpur	10 KVA	54	6	0	9
				16 KVA	3	0	0	1
				25 KVA	16	2	0	2
				40 KVA	0	0	0	0
				63 KVA	5	0	0	1
				100 KVA	5	1	0	1
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	1	0	0	0
				315 KVA	0	0	0	0
				400 KVA	1	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
74	Mahrajganj	KAPTANGANJ	kaptanganj	10 KVA	20	2	0	3
				16 KVA	4	0	0	1
				25 KVA	11	2	0	2
				40 KVA	0	0	0	0
				63 KVA	2	0	0	0
				100 KVA	5	1	0	1
				160 KVA	0	0	0	0

DTR Metering

State : UTTAR PRADESH
District : Azamgarh

				200 KVA	0	0	0	0
				250 KVA	1	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
75	Mahrajganj	KAPTANGANJ	Deoria	10 KVA	40	5	0	6
				16 KVA	7	1	0	1
				25 KVA	23	3	0	3
				40 KVA	0	0	0	0
				63 KVA	14	1	0	2
				100 KVA	1	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	1	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
76	Mahrajganj	KAPTANGANJ	Mehmauni	10 KVA	38	5	0	6
				16 KVA	4	0	0	1
				25 KVA	17	3	0	2
				40 KVA	0	0	0	0
				63 KVA	13	1	0	2

DTR Metering

State : UTTAR PRADESH
District : Azamgarh

				100 KVA	1	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	1	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
77	Martinganj	MARTINGANJ	Bakhara Feeder	10 KVA	19	2	0	3
				16 KVA	10	1	0	2
				25 KVA	13	2	0	2
				40 KVA	0	0	0	0
				63 KVA	8	1	0	1
				100 KVA	15	3	0	2
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	1	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
78	Martinganj	MARTINGANJ	Siswara Feeder	10 KVA	38	5	0	6
				16 KVA	5	0	0	1
				25 KVA	11	2	0	2

DTR Metering

State : UTTAR PRADESH
District : Azamgarh

				40 KVA	0	0	0	0
				63 KVA	8	1	0	1
				100 KVA	1	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	3	1	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
79	Martinganj	MARTINGANJ	Belwana Feeder	10 KVA	18	2	0	3
				16 KVA	5	0	0	1
				25 KVA	43	6	0	6
				40 KVA	0	0	0	0
				63 KVA	27	2	0	5
				100 KVA	15	3	0	2
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	4	1	0	1
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
80	Mehnagar	MEH NAGAR	Laudah	10 KVA	23	3	0	4

DTR Metering

State : UTTAR PRADESH
District : Azamgarh

				16 KVA	14	1	0	2
				25 KVA	36	5	0	5
				40 KVA	0	0	0	0
				63 KVA	11	1	0	2
				100 KVA	2	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	1	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
81	Mehnar	MEH NAGAR	Chakwara	10 KVA	51	6	0	8
				16 KVA	10	1	0	2
				25 KVA	10	2	0	1
				40 KVA	0	0	0	0
				63 KVA	2	0	0	0
				100 KVA	1	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	1	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0

DTR Metering

State : UTTAR PRADESH
District : Azamgarh

				630 KVA	0	0	0	0
82	Mehnagar	MEH NAGAR	Kharag Pur	10 KVA	5	1	0	1
				16 KVA	29	2	0	5
				25 KVA	3	0	0	1
				40 KVA	0	0	0	0
				63 KVA	1	0	0	0
				100 KVA	1	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
83	Mehnagar	KHAMARIYA	Khatahan	10 KVA	50	6	0	8
				16 KVA	4	0	0	1
				25 KVA	39	6	0	6
				40 KVA	0	0	0	0
				63 KVA	14	1	0	2
				100 KVA	2	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	1	0	0	0
				315 KVA	0	0	0	0

DTR Metering

State : UTTAR PRADESH
District : Azamgarh

				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
84	Mehrnagar	KHAMARIYA	Kamharia	10 KVA	46	6	0	7
				16 KVA	17	1	0	3
				25 KVA	32	5	0	5
				40 KVA	0	0	0	0
				63 KVA	25	2	0	2
				100 KVA	7	1	0	1
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	1	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
85	Mirzapur	DATTATREYA	Nizamabad	10 KVA	23	3	0	4
				16 KVA	12	1	0	2
				25 KVA	17	3	0	2
				40 KVA	0	0	0	0
				63 KVA	3	0	0	1
				100 KVA	8	2	0	1
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0

DTR Metering

State : UTTAR PRADESH
District : Azamgarh

				250 KVA	1	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
86	Mirzapur	DATTATREYA	Mirzapur	10 KVA	41	5	0	6
				16 KVA	10	1	0	2
				25 KVA	26	4	0	4
				40 KVA	0	0	0	0
				63 KVA	19	1	0	3
				100 KVA	5	1	0	1
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	1	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
87	Mirzapur	DATTATREYA	Mohnathpur	10 KVA	24	3	0	4
				16 KVA	17	1	0	3
				25 KVA	28	4	0	4
				40 KVA	0	0	0	0
				63 KVA	16	1	0	3
				100 KVA	4	1	0	1

DTR Metering

State : UTTAR PRADESH
District : Azamgarh

				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	1	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
88	Mirzapur	SARAI MEER	Basti	10 KVA	23	3	0	4
				16 KVA	12	1	0	2
				25 KVA	21	3	0	3
				40 KVA	0	0	0	0
				63 KVA	7	0	0	1
				100 KVA	1	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
89	Mirzapur	SARAI MEER	Nandau	10 KVA	24	3	0	4
				16 KVA	16	1	0	3
				25 KVA	26	4	0	4
				40 KVA	0	0	0	0

DTR Metering

State : UTTAR PRADESH
District : Azamgarh

				63 KVA	18	1	0	3
				100 KVA	4	1	0	1
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	2	1	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
90	Mohammadpur	CHHAU	Belu	10 KVA	30	4	0	5
				16 KVA	11	1	0	2
				25 KVA	73	11	0	11
				40 KVA	0	0	0	0
				63 KVA	21	1	0	4
				100 KVA	9	2	0	1
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	4	1	0	1
				315 KVA	0	0	0	0
				400 KVA	1	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
91	Mohammadpur	CHHAU	Chhau	10 KVA	17	2	0	3
				16 KVA	14	1	0	2

DTR Metering

State : UTTAR PRADESH
District : Azamgarh

				25 KVA	14	2	0	2
				40 KVA	0	0	0	0
				63 KVA	15	1	0	3
				100 KVA	0	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
92	Mohammadpur	CHHAU	Gambhirpur	10 KVA	29	3	0	5
				16 KVA	10	1	0	2
				25 KVA	8	1	0	1
				40 KVA	0	0	0	0
				63 KVA	2	0	0	0
				100 KVA	1	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	1	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0

DTR Metering

State : UTTAR PRADESH
District : Azamgarh

93	Mohammadpur	MUHAMMAD PUR	North	10 KVA	25	3	0	4
				16 KVA	8	1	0	1
				25 KVA	13	2	0	2
				40 KVA	0	0	0	0
				63 KVA	2	0	0	0
				100 KVA	1	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	1	0	0	0
				315 KVA	0	0	0	0
				400 KVA	1	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
94	Mohammadpur	MUHAMMAD PUR	South	10 KVA	46	6	0	7
				16 KVA	17	1	0	3
				25 KVA	29	4	0	4
				40 KVA	0	0	0	0
				63 KVA	36	3	0	6
				100 KVA	7	1	0	1
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	1	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0

DTR Metering

State : UTTAR PRADESH
District : Azamgarh

				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
95	Mohammadpur	MUHAMMAD PUR	Rowa	10 KVA	35	4	0	6
				16 KVA	8	1	0	1
				25 KVA	23	3	0	3
				40 KVA	0	0	0	0
				63 KVA	28	2	0	5
				100 KVA	5	1	0	1
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	2	1	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
96	Mohammadpur	MUHAMMAD PUR	Bindra Bazar	10 KVA	15	2	0	2
				16 KVA	4	0	0	1
				25 KVA	1	0	0	0
				40 KVA	0	0	0	0
				63 KVA	1	0	0	0
				100 KVA	0	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0

DTR Metering

State : UTTAR PRADESH
District : Azamgarh

				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
97	Mohammadpur	GOTHAWAN	Gothawan	10 KVA	30	4	0	5
				16 KVA	19	2	0	3
				25 KVA	25	4	0	4
				40 KVA	0	0	0	0
				63 KVA	11	1	0	2
				100 KVA	1	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	1	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
98	Mohammadpur	GOTHAWAN	Nandaoh	10 KVA	17	2	0	3
				16 KVA	5	0	0	1
				25 KVA	22	3	0	3
				40 KVA	0	0	0	0
				63 KVA	13	1	0	2
				100 KVA	6	1	0	1
				160 KVA	0	0	0	0

DTR Metering

State : UTTAR PRADESH
District : Azamgarh

				200 KVA	0	0	0	0
				250 KVA	1	0	0	0
				315 KVA	0	0	0	0
				400 KVA	1	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
99	Palhani	ZAFFARPUR	South	10 KVA	77	9	0	12
				16 KVA	20	2	0	3
				25 KVA	53	8	0	8
				40 KVA	0	0	0	0
				63 KVA	26	2	0	4
				100 KVA	8	2	0	1
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	2	1	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
100	Palhna	SHEIKHPURA	Ahopatti	10 KVA	23	3	0	4
				16 KVA	12	1	0	2
				25 KVA	41	6	0	6
				40 KVA	0	0	0	0
				63 KVA	20	1	0	3

DTR Metering

State : UTTAR PRADESH
District : Azamgarh

				100 KVA	8	2	0	1
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	5	2	0	1
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
101	Palhna	SHEIKHPURA	Badhopur	10 KVA	22	3	0	3
				16 KVA	14	1	0	2
				25 KVA	15	2	0	2
				40 KVA	0	0	0	0
				63 KVA	9	1	0	1
				100 KVA	1	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	1	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
102	Palhna	KARSARA	Chutara	10 KVA	10	1	0	2
				16 KVA	4	0	0	1
				25 KVA	10	2	0	1

DTR Metering

State : UTTAR PRADESH
District : Azamgarh

				40 KVA	0	0	0	0
				63 KVA	5	0	0	1
				100 KVA	0	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
103	Palhna	KARSARA	Karsara	10 KVA	37	4	0	6
				16 KVA	15	1	0	2
				25 KVA	55	8	0	8
				40 KVA	0	0	0	0
				63 KVA	35	2	0	6
				100 KVA	9	2	0	1
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	3	1	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
104	Palhna	KARSARA	Bela	10 KVA	29	3	0	5

DTR Metering

State : UTTAR PRADESH
District : Azamgarh

				16 KVA	9	1	0	1
				25 KVA	2	0	0	0
				40 KVA	0	0	0	0
				63 KVA	2	0	0	0
				100 KVA	0	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
105	Palhna	PALAHANA	Palahana	10 KVA	30	4	0	5
				16 KVA	9	1	0	1
				25 KVA	25	4	0	4
				40 KVA	0	0	0	0
				63 KVA	1	0	0	0
				100 KVA	11	2	0	2
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	1	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0

DTR Metering

State : UTTAR PRADESH
District : Azamgarh

				630 KVA	0	0	0	0
106	Palhna	PALAHANA	Lhua	10 KVA	14	2	0	2
				16 KVA	9	1	0	1
				25 KVA	52	8	0	7
				40 KVA	0	0	0	0
				63 KVA	22	2	0	4
				100 KVA	9	2	0	1
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	1	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
107	Palhna	BHAWAR NATH	Heera palti	10 KVA	50	6	0	8
				16 KVA	11	1	0	2
				25 KVA	35	5	0	5
				40 KVA	0	0	0	0
				63 KVA	14	1	0	2
				100 KVA	1	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0

DTR Metering

State : UTTAR PRADESH
District : Azamgarh

				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
108	Palhna	BHAWAR NATH	Kandharapur	10 KVA	39	5	0	6
				16 KVA	16	1	0	3
				25 KVA	22	3	0	3
				40 KVA	0	0	0	0
				63 KVA	9	1	0	1
				100 KVA	1	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	1	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
109	Palhna	KANDHARPUR	Azampur	10 KVA	45	5	0	7
				16 KVA	6	0	0	1
				25 KVA	15	2	0	2
				40 KVA	0	0	0	0
				63 KVA	7	0	0	1
				100 KVA	1	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0

DTR Metering

State : UTTAR PRADESH
District : Azamgarh

				250 KVA	1	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
110	Palhna	KANDHARPUR	Kandharpur	10 KVA	31	4	0	5
				16 KVA	7	1	0	1
				25 KVA	18	3	0	3
				40 KVA	0	0	0	0
				63 KVA	9	1	0	1
				100 KVA	3	1	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	1	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
111	Pawai	BAGH BAHAR	Kalan	10 KVA	30	4	0	5
				16 KVA	11	1	0	2
				25 KVA	15	2	0	2
				40 KVA	0	0	0	0
				63 KVA	11	1	0	2
				100 KVA	3	1	0	0

DTR Metering

State : UTTAR PRADESH
District : Azamgarh

				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	2	1	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
112	Pawai	BAGH BAHAR	Sahdulla	10 KVA	17	2	0	3
				16 KVA	17	1	0	3
				25 KVA	20	3	0	3
				40 KVA	0	0	0	0
				63 KVA	5	0	0	1
				100 KVA	6	1	0	1
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	1	0	0	0
				315 KVA	0	0	0	0
				400 KVA	2	1	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
113	Pawai	BAGH BAHAR	Khairuddinpur	10 KVA	29	3	0	5
				16 KVA	9	1	0	1
				25 KVA	22	3	0	3
				40 KVA	0	0	0	0

DTR Metering

State : UTTAR PRADESH
District : Azamgarh

				63 KVA	20	1	0	3
				100 KVA	1	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	1	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
114	Pawai	PAWAI	Mahul Feeder	10 KVA	15	2	0	2
				16 KVA	11	1	0	2
				25 KVA	22	3	0	3
				40 KVA	0	0	0	0
				63 KVA	11	1	0	2
				100 KVA	19	4	0	3
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	7	2	0	1
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
115	Pawai	PAWAI	Belwai Feeder	10 KVA	27	3	0	4
				16 KVA	15	1	0	2

DTR Metering

State : UTTAR PRADESH
District : Azamgarh

				25 KVA	29	4	0	4
				40 KVA	0	0	0	0
				63 KVA	15	1	0	3
				100 KVA	12	2	0	2
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	3	1	0	0
				315 KVA	0	0	0	0
				400 KVA	1	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
116	Pawai	PAWAI	Balaipur Feeder	10 KVA	19	2	0	3
				16 KVA	5	0	0	1
				25 KVA	26	4	0	4
				40 KVA	0	0	0	0
				63 KVA	8	1	0	1
				100 KVA	17	3	0	3
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	2	1	0	0
				315 KVA	0	0	0	0
				400 KVA	1	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0

DTR Metering

State : UTTAR PRADESH
District : Azamgarh

117	Pawai	PAWAI	Pawai	10 KVA	29	3	0	5
				16 KVA	5	0	0	1
				25 KVA	20	3	0	3
				40 KVA	0	0	0	0
				63 KVA	7	0	0	1
				100 KVA	1	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
118	Phulpur	PHOOLPUR	North	10 KVA	46	6	0	7
				16 KVA	16	1	0	3
				25 KVA	32	5	0	5
				40 KVA	0	0	0	0
				63 KVA	7	0	0	1
				100 KVA	7	1	0	1
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	1	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0

DTR Metering

State : UTTAR PRADESH
District : Azamgarh

				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
119	Phulpur	PHOOLPUR	West	10 KVA	15	2	0	2
				16 KVA	7	1	0	1
				25 KVA	24	4	0	3
				40 KVA	0	0	0	0
				63 KVA	13	1	0	1
				100 KVA	11	2	0	2
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	1	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
120	Phulpur	PHOOLPUR	East	10 KVA	38	5	0	6
				16 KVA	8	1	0	1
				25 KVA	15	2	0	2
				40 KVA	0	0	0	0
				63 KVA	7	0	0	1
				100 KVA	2	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	1	0	0	0

DTR Metering

State : UTTAR PRADESH
District : Azamgarh

				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
121	Phulpur	PHOOLPUR	South	10 KVA	35	4	0	6
				16 KVA	9	1	0	1
				25 KVA	16	2	0	2
				40 KVA	0	0	0	0
				63 KVA	6	0	0	1
				100 KVA	4	1	0	1
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	1	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
122	Phulpur	GADDO PUR	Palthi	10 KVA	15	2	0	2
				16 KVA	0	0	0	0
				25 KVA	21	3	0	3
				40 KVA	0	0	0	0
				63 KVA	13	1	0	1
				100 KVA	7	1	0	1
				160 KVA	0	0	0	0

DTR Metering

State : UTTAR PRADESH
District : Azamgarh

				200 KVA	0	0	0	0
				250 KVA	4	1	0	1
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
123	Phulpur	GADDO PUR	Gaddo Pur	10 KVA	21	3	0	3
				16 KVA	17	1	0	3
				25 KVA	27	4	0	4
				40 KVA	0	0	0	0
				63 KVA	12	1	0	1
				100 KVA	7	1	0	1
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	1	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
124	Phulpur	PUSHP NAGAR	Deedarganj	10 KVA	21	3	0	3
				16 KVA	14	1	0	2
				25 KVA	18	3	0	3
				40 KVA	0	0	0	0
				63 KVA	14	1	0	1

DTR Metering

State : UTTAR PRADESH
District : Azamgarh

				100 KVA	5	1	0	1
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	1	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
125	Phulpur	PUSHP NAGAR	Sikraura	10 KVA	11	1	0	2
				16 KVA	6	0	0	1
				25 KVA	12	2	0	2
				40 KVA	0	0	0	0
				63 KVA	5	0	0	1
				100 KVA	2	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	1	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
126	Rani Ki Sarai	RANI KI SARAI	Rani ki sarai	10 KVA	29	3	0	5
				16 KVA	10	1	0	2
				25 KVA	19	3	0	3

DTR Metering

State : UTTAR PRADESH
District : Azamgarh

				40 KVA	0	0	0	0
				63 KVA	14	1	0	2
				100 KVA	1	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	1	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
127	Rani Ki Sarai	RANI KI SARAI	Sonwara	10 KVA	58	7	0	9
				16 KVA	15	1	0	2
				25 KVA	21	3	0	3
				40 KVA	0	0	0	0
				63 KVA	9	1	0	1
				100 KVA	1	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	7	2	0	1
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
128	Rani Ki Sarai	RANI KI SARAI	Vasti	10 KVA	40	5	0	6

DTR Metering

State : UTTAR PRADESH
District : Azamgarh

				16 KVA	6	0	0	1
				25 KVA	15	2	0	2
				40 KVA	0	0	0	0
				63 KVA	9	1	0	1
				100 KVA	4	1	0	1
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	1	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
129	Sathiyaon	MOHABBATPUR	Shahgarh	10 KVA	30	4	0	5
				16 KVA	11	1	0	2
				25 KVA	23	3	0	3
				40 KVA	0	0	0	0
				63 KVA	11	1	0	2
				100 KVA	1	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	1	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0

DTR Metering

State : UTTAR PRADESH
District : Azamgarh

				630 KVA	0	0	0	0
130	Sathiyaon	MOHABBATPUR	Bamhaur	10 KVA	37	4	0	6
				16 KVA	14	1	0	2
				25 KVA	20	3	0	3
				40 KVA	0	0	0	0
				63 KVA	10	1	0	2
				100 KVA	6	1	0	1
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	4	1	0	1
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
131	Sathiyaon	MUBARAKPUR	Newada Rural	10 KVA	35	4	0	6
				16 KVA	6	0	0	1
				25 KVA	31	5	0	4
				40 KVA	0	0	0	0
				63 KVA	19	1	0	3
				100 KVA	4	1	0	1
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	3	1	0	0
				315 KVA	0	0	0	0

DTR Metering

State : UTTAR PRADESH
District : Azamgarh

				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
132	Sathiyaon	MUBARAKPUR	Sthiyaon	10 KVA	24	3	0	4
				16 KVA	9	1	0	1
				25 KVA	28	4	0	4
				40 KVA	0	0	0	0
				63 KVA	14	1	0	2
				100 KVA	3	1	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	1	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
133	Tahbarpur	SOFIPUR	Nizamabad	10 KVA	21	3	0	3
				16 KVA	14	1	0	2
				25 KVA	30	5	0	4
				40 KVA	0	0	0	0
				63 KVA	30	2	0	5
				100 KVA	5	1	0	1
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0

DTR Metering

State : UTTAR PRADESH
District : Azamgarh

				250 KVA	1	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
134	Tahbarpur	SOFIPUR	Semari	10 KVA	31	4	0	5
				16 KVA	3	0	0	1
				25 KVA	5	1	0	1
				40 KVA	0	0	0	0
				63 KVA	12	1	0	2
				100 KVA	0	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
135	Tahbarpur	SOFIPUR	Nizamabad 2	10 KVA	45	5	0	7
				16 KVA	3	0	0	1
				25 KVA	16	2	0	2
				40 KVA	0	0	0	0
				63 KVA	9	1	0	1
				100 KVA	9	2	0	1

DTR Metering

State : UTTAR PRADESH
District : Azamgarh

				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	4	1	0	1
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
136	Tahbarpur	SOFIPUR	Tahbarpur	10 KVA	27	3	0	4
				16 KVA	17	1	0	3
				25 KVA	18	3	0	3
				40 KVA	0	0	0	0
				63 KVA	13	1	0	2
				100 KVA	8	2	0	1
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	7	2	0	1
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
137	Tahbarpur	ORA	Ora	10 KVA	55	7	0	9
				16 KVA	6	0	0	1
				25 KVA	10	2	0	1
				40 KVA	0	0	0	0

DTR Metering

State : UTTAR PRADESH
District : Azamgarh

				63 KVA	2	0	0	0
				100 KVA	1	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	1	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
138	Tahbarpur	ORA	Deohatta	10 KVA	11	1	0	2
				16 KVA	9	1	0	1
				25 KVA	11	2	0	2
				40 KVA	0	0	0	0
				63 KVA	4	0	0	1
				100 KVA	0	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
139	Tahbarpur	ORA	Sarai Barkat	10 KVA	11	1	0	2
				16 KVA	3	0	0	1

DTR Metering

State : UTTAR PRADESH
District : Azamgarh

				25 KVA	9	1	0	1
				40 KVA	0	0	0	0
				63 KVA	5	0	0	1
				100 KVA	1	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	1	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
140	Tahbarpur	MANJHARI	Dhania kundi	10 KVA	8	1	0	1
				16 KVA	7	1	0	1
				25 KVA	16	2	0	2
				40 KVA	0	0	0	0
				63 KVA	5	0	0	1
				100 KVA	1	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0

DTR Metering

State : UTTAR PRADESH
District : Azamgarh

141	Tahbarpur	MANJHARI	Manjhari	10 KVA	10	1	0	2
				16 KVA	6	0	0	1
				25 KVA	3	0	0	1
				40 KVA	0	0	0	0
				63 KVA	0	0	0	0
				100 KVA	0	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
142	Tahbarpur	MANJHARI	Kariawar	10 KVA	11	1	0	2
				16 KVA	5	0	0	1
				25 KVA	12	2	0	2
				40 KVA	0	0	0	0
				63 KVA	10	1	0	2
				100 KVA	1	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0

DTR Metering

State : UTTAR PRADESH
District : Azamgarh

				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
143	Tarwa	RASEPUR	Kanchanpur	10 KVA	25	3	0	4
				16 KVA	12	1	0	2
				25 KVA	29	4	0	4
				40 KVA	0	0	0	0
				63 KVA	7	0	0	1
				100 KVA	11	2	0	2
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	4	1	0	1
				315 KVA	0	0	0	0
				400 KVA	1	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
144	Tarwa	RASEPUR	Sherpur	10 KVA	26	3	0	4
				16 KVA	17	1	0	3
				25 KVA	22	3	0	3
				40 KVA	0	0	0	0
				63 KVA	29	2	0	5
				100 KVA	7	1	0	1
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	1	0	0	0

DTR Metering

State : UTTAR PRADESH
District : Azamgarh

				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
145	Tarwa	RASEPUR	Bongariya	10 KVA	37	4	0	6
				16 KVA	4	0	0	1
				25 KVA	19	3	0	3
				40 KVA	0	0	0	0
				63 KVA	21	1	0	4
				100 KVA	5	1	0	1
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
146	Tarwa	TARWA	Sidhauna	10 KVA	30	4	0	5
				16 KVA	11	1	0	2
				25 KVA	31	5	0	4
				40 KVA	0	0	0	0
				63 KVA	19	1	0	3
				100 KVA	1	0	0	0
				160 KVA	0	0	0	0

DTR Metering

State : UTTAR PRADESH
District : Azamgarh

				200 KVA	0	0	0	0
				250 KVA	1	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
147	Tarwa	TARWA	Meh Nagar	10 KVA	29	3	0	5
				16 KVA	4	0	0	1
				25 KVA	6	1	0	1
				40 KVA	0	0	0	0
				63 KVA	2	0	0	0
				100 KVA	1	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	1	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
148	Tarwa	TARWA	Mehnajpur	10 KVA	2	0	0	0
				16 KVA	2	0	0	0
				25 KVA	10	2	0	1
				40 KVA	0	0	0	0
				63 KVA	3	0	0	1

DTR Metering

State : UTTAR PRADESH
District : Azamgarh

				100 KVA	0	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
149	Tarwa	MEHNAJPUR	Nath PUR	10 KVA	38	5	0	6
				16 KVA	11	1	0	2
				25 KVA	20	3	0	3
				40 KVA	0	0	0	0
				63 KVA	4	0	0	1
				100 KVA	1	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	5	2	0	1
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
150	Tarwa	MEHNAJPUR	Rowa para	10 KVA	17	2	0	3
				16 KVA	8	1	0	1
				25 KVA	40	6	0	6

DTR Metering

State : UTTAR PRADESH
District : Azamgarh

				40 KVA	0	0	0	0
				63 KVA	14	1	0	2
				100 KVA	6	1	0	1
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	1	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
151	Tarwa	MEHNAJPUR	Mehnaj Pur	10 KVA	29	3	0	5
				16 KVA	6	0	0	1
				25 KVA	27	4	0	4
				40 KVA	0	0	0	0
				63 KVA	19	1	0	3
				100 KVA	2	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	1	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
152	Thekma	BARDAH	Bardah	10 KVA	30	7	0	4

DTR Metering

State : UTTAR PRADESH
District : Azamgarh

				16 KVA	14	1	0	2
				25 KVA	10	2	0	1
				40 KVA	0	0	0	0
				63 KVA	6	0	0	1
				100 KVA	5	1	0	1
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	2	1	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
153	Thekma	BARDAH	Bahadurpur	10 KVA	17	8	0	2
				16 KVA	18	1	0	3
				25 KVA	45	7	0	6
				40 KVA	0	0	0	0
				63 KVA	22	2	0	4
				100 KVA	6	1	0	1
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	1	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0

DTR Metering

State : UTTAR PRADESH
District : Azamgarh

				630 KVA	0	0	0	0
154	Thekma	BARDAH	Jiblee	10 KVA	29	3	0	5
				16 KVA	5	0	0	1
				25 KVA	22	3	0	3
				40 KVA	0	0	0	0
				63 KVA	12	1	0	2
				100 KVA	1	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	1	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
155	Thekma	THEKMA	Tahbarpur	10 KVA	35	4	0	6
				16 KVA	11	1	0	2
				25 KVA	35	5	0	5
				40 KVA	0	0	0	0
				63 KVA	22	2	0	4
				100 KVA	1	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	1	0	0	0
				315 KVA	0	0	0	0

DTR Metering

State : UTTAR PRADESH
District : Azamgarh

				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
156	Thekma	THEKMA	Sarai Mohan	10 KVA	40	5	0	6
				16 KVA	5	0	0	1
				25 KVA	20	3	0	3
				40 KVA	0	0	0	0
				63 KVA	13	1	0	2
				100 KVA	6	1	0	1
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	1	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
157	Thekma	THEKMA	Thekma	10 KVA	53	6	0	8
				16 KVA	15	1	0	2
				25 KVA	21	3	0	3
				40 KVA	0	0	0	0
				63 KVA	10	1	0	2
				100 KVA	8	2	0	1
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0

DTR Metering

State : UTTAR PRADESH
District : Azamgarh

				250 KVA	5	2	0	1
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
158	Jahanaganj	JAHANGANJ	Jahanaganj	10 KVA	35	4	0	6
				16 KVA	8	1	0	1
				25 KVA	21	3	0	3
				40 KVA	0	0	0	0
				63 KVA	8	1	0	1
				100 KVA	5	1	0	1
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	1	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0

Consumer Metering

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of Block	Description	1-Ph Domestic & Commercial	3-Ph Domestic & Commercial	3-Ph Water works	3-Ph Agriculture
1	Ahiraula	Existing Consumers	7361	861	0	0
		Defective Meters	0	0	0	0
		Un-metered	7361	658	0	0
		Existing Electro-Mechanical Meters	0	0	0	0
		Installation of New Meters	582	20	0	0
		Replacement of Defective Meters	0	0	0	0
		Replacement of Electro-Mechanical Meters	0	0	0	0
2	Atraulia	Existing Consumers	4306	503	0	0
		Defective Meters	0	0	0	0
		Un-metered	4306	385	0	0
		Existing Electro-Mechanical Meters	0	0	0	0
		Installation of New Meters	340	16	0	0
		Replacement of Defective Meters	0	0	0	0
		Replacement of Electro-Mechanical Meters	0	0	0	0
3	Azmatgarh	Existing Consumers	8038	940	0	0
		Defective Meters	0	0	0	0
		Un-metered	8038	719	0	0
		Existing Electro-Mechanical Meters	0	0	0	0
		Installation of New Meters	635	22	0	0
		Replacement of Defective Meters	0	0	0	0
		Replacement of Electro-Mechanical Meters	0	0	0	0
4	Bilariyaganj	Existing Consumers	8112	949	0	0
		Defective Meters	0	0	0	0

Consumer Metering

State : UTTAR PRADESH
District : Azamgarh

		Un-metered	8112	726	0	0
		Existing Electro-Mechanical Meters	0	0	0	0
		Installation of New Meters	641	22	0	0
		Replacement of Defective Meters	0	0	0	0
		Replacement of Electro-Mechanical Meters	0	0	0	0
5	Haraiya	Existing Consumers	7164	839	0	0
		Defective Meters	0	0	0	0
		Un-metered	7164	641	0	0
		Existing Electro-Mechanical Meters	0	0	0	0
		Installation of New Meters	566	19	0	0
		Replacement of Defective Meters	0	0	0	0
		Replacement of Electro-Mechanical Meters	0	0	0	0
6	Jahanaganj	Existing Consumers	6519	762	0	0
		Defective Meters	0	0	0	0
		Un-metered	6519	583	0	0
		Existing Electro-Mechanical Meters	0	0	0	0
		Installation of New Meters	515	17	0	0
		Replacement of Defective Meters	0	0	0	0
		Replacement of Electro-Mechanical Meters	0	0	0	0
7	Koilsa	Existing Consumers	6777	792	0	0
		Defective Meters	0	0	0	0
		Un-metered	6777	606	0	0
		Existing Electro-Mechanical Meters	0	0	0	0
		Installation of New Meters	535	18	0	0

Consumer Metering

State : UTTAR PRADESH
District : Azamgarh

		Replacement of Defective Meters	0	0	0	0
		Replacement of Electro-Mechanical Meters	0	0	0	0
8	Lalganj	Existing Consumers	7530	881	0	0
		Defective Meters	0	0	0	0
		Un-metered	7530	674	0	0
		Existing Electro-Mechanical Meters	0	0	0	0
		Installation of New Meters	602	20	0	0
		Replacement of Defective Meters	0	0	0	0
		Replacement of Electro-Mechanical Meters	0	0	0	0
9	Mahrajanj	Existing Consumers	7257	849	0	0
		Defective Meters	0	0	0	0
		Un-metered	7257	649	0	0
		Existing Electro-Mechanical Meters	0	0	0	0
		Installation of New Meters	581	19	0	0
		Replacement of Defective Meters	0	0	0	0
		Replacement of Electro-Mechanical Meters	0	0	0	0
10	Martinganj	Existing Consumers	6499	760	0	0
		Defective Meters	0	0	0	0
		Un-metered	6499	581	0	0
		Existing Electro-Mechanical Meters	0	0	0	0
		Installation of New Meters	520	17	0	0
		Replacement of Defective Meters	0	0	0	0
		Replacement of Electro-Mechanical Meters	0	0	0	0
11	Mehnagar	Existing Consumers	6588	770	0	0

Consumer Metering

State : UTTAR PRADESH
District : Azamgarh

		Defective Meters	0	0	0	0
		Un-metered	6588	589	0	0
		Existing Electro-Mechanical Meters	0	0	0	0
		Installation of New Meters	527	18	0	0
		Replacement of Defective Meters	0	0	0	0
		Replacement of Electro-Mechanical Meters	0	0	0	0
12	Mirzapur	Existing Consumers	7124	833	0	0
		Defective Meters	0	0	0	0
		Un-metered	7124	637	0	0
		Existing Electro-Mechanical Meters	0	0	0	0
		Installation of New Meters	570	19	0	0
		Replacement of Defective Meters	0	0	0	0
		Replacement of Electro-Mechanical Meters	0	0	0	0
13	Mohammadpur	Existing Consumers	6242	730	0	0
		Defective Meters	0	0	0	0
		Un-metered	6242	558	0	0
		Existing Electro-Mechanical Meters	0	0	0	0
		Installation of New Meters	499	17	0	0
		Replacement of Defective Meters	0	0	0	0
		Replacement of Electro-Mechanical Meters	0	0	0	0
14	Palhani	Existing Consumers	6806	796	0	0
		Defective Meters	0	0	0	0
		Un-metered	6806	609	0	0
		Existing Electro-Mechanical Meters	0	0	0	0

Consumer Metering

State : UTTAR PRADESH
District : Azamgarh

		Installation of New Meters	544	18	0	0
		Replacement of Defective Meters	0	0	0	0
		Replacement of Electro-Mechanical Meters	0	0	0	0
15	Palhna	Existing Consumers	3961	463	0	0
		Defective Meters	0	0	0	0
		Un-metered	3961	354	0	0
		Existing Electro-Mechanical Meters	0	0	0	0
		Installation of New Meters	317	11	0	0
		Replacement of Defective Meters	0	0	0	0
		Replacement of Electro-Mechanical Meters	0	0	0	0
16	Pawai	Existing Consumers	7130	834	0	0
		Defective Meters	0	0	0	0
		Un-metered	7130	638	0	0
		Existing Electro-Mechanical Meters	0	0	0	0
		Installation of New Meters	570	19	0	0
		Replacement of Defective Meters	0	0	0	0
		Replacement of Electro-Mechanical Meters	0	0	0	0
17	Phulpur	Existing Consumers	6970	816	0	0
		Defective Meters	0	0	0	0
		Un-metered	6970	624	0	0
		Existing Electro-Mechanical Meters	0	0	0	0
		Installation of New Meters	558	19	0	0
		Replacement of Defective Meters	0	0	0	0
		Replacement of Electro-Mechanical Meters	0	0	0	0

Consumer Metering

State : UTTAR PRADESH
District : Azamgarh

18	Rani Ki Sarai	Existing Consumers	8010	937	0	0
		Defective Meters	0	0	0	0
		Un-metered	8010	717	0	0
		Existing Electro-Mechanical Meters	0	0	0	0
		Installation of New Meters	641	22	0	0
		Replacement of Defective Meters	0	0	0	0
		Replacement of Electro-Mechanical Meters	0	0	0	0
19	Sathiyaon	Existing Consumers	7799	913	0	0
		Defective Meters	0	0	0	0
		Un-metered	7799	698	0	0
		Existing Electro-Mechanical Meters	0	0	0	0
		Installation of New Meters	624	21	0	0
		Replacement of Defective Meters	0	0	0	0
		Replacement of Electro-Mechanical Meters	0	0	0	0
20	Tahbarpur	Existing Consumers	6414	750	0	0
		Defective Meters	0	0	0	0
		Un-metered	6414	574	0	0
		Existing Electro-Mechanical Meters	0	0	0	0
		Installation of New Meters	513	17	0	0
		Replacement of Defective Meters	0	0	0	0
		Replacement of Electro-Mechanical Meters	0	0	0	0
21	Tarwa	Existing Consumers	7297	854	0	0
		Defective Meters	0	0	0	0
		Un-metered	7297	653	0	0

Consumer Metering

State : UTTAR PRADESH
District : Azamgarh

		Existing Electro-Mechanical Meters	0	0	0	0
		Installation of New Meters	584	20	0	0
		Replacement of Defective Meters	0	0	0	0
		Replacement of Electro-Mechanical Meters	0	0	0	0
22	Thekma	Existing Consumers	6760	790	0	0
		Defective Meters	0	0	0	0
		Un-metered	6760	604	0	0
		Existing Electro-Mechanical Meters	0	0	0	0
		Installation of New Meters	541	18	0	0
		Replacement of Defective Meters	0	0	0	0
		Replacement of Electro-Mechanical Meters	0	0	0	0

Feeder Metering

State : UTTAR PRADESH
District : Azamgarh

Sl.No	Name of Block	33 KV Feeder									11 KV or 22 KV Feeder				
		No of Feeders(Existing Under Execution and Proposed)	Meters Already Installed		Balance for Meterization		Defective Meter		Meters Required for Meterization		No of Feeders(Existing Under Execution and Proposed)	Meters Already Installed	Defective Meter	Meters Required	
			At 132 KV S/s End	At 33/11 KV S/s	At 132 KV S/s End	At 33/11 KV S/s	At 132 KV S/s End	At 33/11 KV S/s	With CT/PT	Without CT/PT				With CT/PT	Without CT/PT
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
1	Ahiraula	3	3	3	0	0	0	0	0	1	7	7	3	0	3
2	Atraulia	1	1	1	0	0	0	0	0	0	5	5	2	0	2
3	Azmatgarh	4	4	4	0	0	0	0	0	0	14	9	1	0	6
4	Bilariyaganj	2	2	2	0	0	0	0	0	0	7	7	3	0	3
5	Haraiya	2	2	2	0	0	0	0	0	0	7	7	3	0	3
6	Jahanaganj	4	4	4	0	0	0	0	0	0	13	13	5	0	5
7	Koilsa	4	4	4	0	0	0	0	0	0	11	11	6	0	6
8	Lalganj	4	4	4	0	0	0	0	0	0	13	7	1	0	5
9	Mahrajganj	2	2	2	0	0	0	0	0	0	8	6	2	0	3
10	Martinganj	1	1	1	0	0	0	0	0	1	3	3	1	0	1
11	Mehnagar	2	2	2	0	0	0	0	0	0	6	6	3	0	3
12	Mirzapur	2	2	2	0	0	0	0	0	0	6	6	3	0	3
13	Mohammadpur	3	3	3	0	0	0	0	0	0	9	9	4	0	4
14	Palhani	1	1	1	0	0	0	0	0	0	4	4	2	0	2
15	Palhna	5	5	5	0	0	0	0	0	1	12	9	2	0	5
16	Pawai	2	2	2	0	0	0	0	0	0	7	7	3	0	3

Feeder Metering

State : UTTAR PRADESH
District : Azamgarh

Sl.No	Name of Block	33 KV Feeder								11 KV or 22 KV Feeder					
		No of Feeders(Existing Under Execution and Proposed)	Meters Already Installed		Balance for Meterization		Defective Meter		Meters Required for Meterization		No of Feeders(Existing Under Execution and Proposed)	Meters Already Installed	Defective Meter	Meters Required	
			At 132 KV S/s End	At 33/11 KV S/s	At 132 KV S/s End	At 33/11 KV S/s	At 132 KV S/s End	At 33/11 KV S/s	With CT/PT	Without CT/PT				With CT/PT	Without CT/PT
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
17	Phulpur	3	3	3	0	0	0	0	0	0	11	11	4	0	4
18	Rani Ki Sarai	1	1	1	0	0	0	0	0	0	3	3	1	0	1
19	Sathiyaon	2	2	2	0	0	0	0	0	0	7	7	3	0	3
20	Tahbarpur	3	3	3	0	0	0	0	0	0	10	10	5	0	5
21	Tarwa	3	3	3	0	0	0	0	0	0	10	10	4	0	4
22	Thekma	2	2	2	0	0	0	0	0	0	7	7	3	0	3
Total		56	56	56	0	0	0	0	0	3	180	164	64	0	77

System Strengthening and Augmentation

State : UTTAR PRADESH

District : Azamgarh

Block-Wise Substation

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of Block	Existing 33/11 kV Sub-Station as on 31.03.2015		33/11 kV Sub-Station already sanctioned and under execution in RGGVY/State/Other schemes as on 31.03.2015		New 33/11 kV Sub-Stations proposed under present scheme		Aug of existing 33/11kV Sub-Stations proposed in the scheme		Total 33/11 kV	
		No. of S/s (Nos)	PT Capacity (MVA)	No. of S/s (Nos)	PT Capacity (MVA)	No. of S/s (Nos)	PT Capacity (MVA)	No. of S/s (Nos)	PT Capacity (MVA)	No. of S/s (Nos)	PT Capacity (MVA)
1	Ahiraula	3	15	0	0	0	0	3	18	6	33
2	Atraulia	1	10	0	0	0	0	1	5	2	15
3	Azmatgarh	4	26	0	0	0	0	4	23	8	49
4	Bilariyaganj	2	15	0	0	0	0	2	15	4	30
5	Haraiya	2	8	0	0	0	0	2	10	4	18
6	Jahanaganj	4	30	0	0	0	0	4	29	8	59
7	Koilsa	4	20	0	0	0	0	4	32	8	52
8	Lalganj	4	30	0	0	0	0	4	39	8	69
9	Mahrajanj	2	16	0	0	0	0	2	16	4	32
10	Martinganj	1	5	0	0	0	0	1	8	2	13
11	Mehnagar	2	15	0	0	0	0	2	16	4	31
12	Mirzapur	2	15	0	0	0	0	2	16	4	31
13	Mohammadpur	3	20	0	0	0	0	3	24	6	44
14	Palhani	1	15	0	0	0	0	1	8	2	23
15	Palhna	5	33	0	0	0	0	5	40	10	73
16	Pawai	2	15	0	0	0	0	2	16	4	31
17	Phulpur	3	28	0	0	0	0	3	24	6	52
18	Rani Ki Sarai	1	8	0	0	0	0	1	8	2	16
19	Sathiyaon	2	25	0	0	1	5	2	28	5	58
20	Tahbarpur	3	18	0	0	0	0	3	24	6	42

Block-Wise Substation

State : UTTAR PRADESH
 District : Azamgarh

Sl.No.	Name of Block	Existing 33/11 kV Sub-Station as on 31.03.2015		33/11 kV Sub-Station already sanctioned and under execution in RGGVY/State/Other schemes as on 31.03.2015		New 33/11 kV Sub-Stations proposed under present scheme		Aug of existing 33/11kV Sub-Stations proposed in the scheme		Total 33/11 kV	
		No. of S/s (Nos)	PT Capacity (MVA)	No. of S/s (Nos)	PT Capacity (MVA)	No. of S/s (Nos)	PT Capacity (MVA)	No. of S/s (Nos)	PT Capacity (MVA)	No. of S/s (Nos)	PT Capacity (MVA)
21	Tarwa	3	18	0	0	0	0	3	24	6	42
22	Thekma	2	13	0	0	0	0	2	16	4	29

New 33 (or 66) KV REDB Works Proposed

State : UTTAR PRADESH
 District : Azamgarh

S.No.	Name of Block	Name of Proposed 33/11kV Substation	Type of Substation	Power Transformer Detail (MVA)	Total Capacity (MVA)	Status of Availability of Land	Other Issues Like Row, Railway Crossing etc	LT Capacitor	Capacitor Bank
1	2	3	4	5	6	7	8	9	10
1	Sathiyaon	Sathiyav (Amilo)	33/11 KV	1x5	5	Yes		0	0
Total					5			0	0

Proposed Augumentation of Existing Sub-station

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of Block	Name of Existing sub-station	Existing Transformer in S/s	Present capacity of S/s	Proposed Transformer augmentation	
			MVA	MVA	Proposed Transformer in S/s	Proposed capacity after augmentation (MVA)
1	Atraulia	ATRAULIA	1x5+1x5+0+0+0	10	1x5+1x10+0+0+0	5
Details of Augmentation :-						
		Sl.No.	Description		Quantity	
		1	AUGMENTATION OF POWER TRANSFORMER FROM 5 MVA TO 10 MVA		1	
		2	T-OFF (for FSP)		33	
2	Azmatgarh	AMUWARI NARAINPUR	1x3+0+0+0+0	3	1x5+0+0+0+0	5
Details of Augmentation :-						
		Sl.No.	Description		Quantity	
		1	AUGMENTATION OF POWER TRANSFORMER USING OLD X-MER WITH 2 NO. ADDL BAY ON 11 KV SIDE 3.15 MVA TO 5.0 MVA		1	
		2	T-OFF (for FSP)		24	
3	Azmatgarh	JIYANPUR	1x5+1x5+0+0+0	10	1x5+1x10+0+0+0	8
Details of Augmentation :-						
		Sl.No.	Description		Quantity	
		1	AUGMENTATION OF POWER TRANSFORMER FROM 5 MVA TO 10 MVA		1	
		2	T-OFF (for FSP)		47	
4	Azmatgarh	LATGHAT	1x3+1x5+0+0+0	8	1x5+0+0+0+0	5
Details of Augmentation :-						
		Sl.No.	Description		Quantity	
		1	AUGMENTATION OF POWER TRANSFORMER USING OLD X-MER WITH 2 NO. ADDL BAY ON 11 KV SIDE 3.15 MVA TO 5.0 MVA		1	
		2	T-OFF (for FSP)		46	

Proposed Augumentation of Existing Sub-station

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of Block	Name of Existing sub-station	Existing Transformer in S/s	Present capacity of S/s	Proposed Transformer augmentation	
			MVA	MVA	Proposed Transformer in S/s	Proposed capacity after augmentation (MVA)
5	Haraiya	RAUNAPUR	1x5+0+0+0+0	5	1x5+1x10+0+0+0	5
Details of Augmentation :-						
		Sl.No.	Description		Quantity	
		1	AUGMENTATION OF POWER TRANSFORMER FROM 5 MVA TO 10 MVA		1	
		2	T-OFF (for FSP)		37	
6	Haraiya	MAU KUTUBPUR	1x3+0+0+0+0	3	1x5+0+0+0+0	5
Details of Augmentation :-						
		Sl.No.	Description		Quantity	
		1	AUGMENTATION OF POWER TRANSFORMER USING OLD X-MER WITH 2 NO. ADDL BAY ON 11 KV SIDE 3.15 MVA TO 5.0 MVA		1	
		2	T-OFF (for FSP)		21	
7	Jahanaganj	CHANDESHWAR	1x5+1x5+0+0+0	10	1x5+1x10+0+0+0	8
Details of Augmentation :-						
		Sl.No.	Description		Quantity	
		1	AUGMENTATION OF POWER TRANSFORMER FROM 5 MVA TO 10 MVA		1	
		2	T-OFF (for FSP)		40	

EHV Substation Feeding the District

State : UTTAR PRADESH
 District : Azamgarh

Sl.No.	Name of existing 33/11 KV substation															GPS Coordinate						Capacity of Substation (In KVA)				
1	Phoolpur															N26 05.607 E82 52.054						60000				
Feeder Details :-																										
Name of PTR	Capacity (In MVA)	Total Recorded Maximum Loading on Feeders(In Amp.)																				Total (In Amp.)	Equivalent MVA Loading	Max % Loading Recorded		
		Feeder 1		Feeder 2		Feeder 3		Feeder 4		Feeder 5		Feeder 6		Feeder 7		Feeder 8		Feeder 9		Feeder 10						
		Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity					
PTR-1	20	33 KV	340	33 KV	100	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	440	25.15	125.74
PTR-2	40	33 KV	250	33 KV	125	33 KV	340	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	715	40.87	102.17
PTR-3	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PTR-4	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PTR-5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
2	Hafizpur															N26 05.232 E83 12.438						80000				
Feeder Details :-																										
Name of PTR	Capacity (In MVA)	Total Recorded Maximum Loading on Feeders(In Amp.)																				Total (In Amp.)	Equivalent MVA Loading	Max % Loading Recorded		
		Feeder 1		Feeder 2		Feeder 3		Feeder 4		Feeder 5		Feeder 6		Feeder 7		Feeder 8		Feeder 9		Feeder 10						
		Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity					
PTR-1	40	33 KV	380	33 KV	280	33 KV	400	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	1060	60.59	151.46
PTR-2	40	33 KV	380	33 KV	84	33 KV	290	33 KV	35	0	0	0	0	0	0	0	0	0	0	0	0	0	0	789	45.1	112.74
PTR-3	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PTR-4	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PTR-5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0

EHV Substation Feeding the District

State : UTTAR PRADESH
 District : Azamgarh

Sl.No.	Name of existing 33/11 KV substation															GPS Coordinate						Capacity of Substation (In KVA)			
3	Sidhari															N26 02.538 E83 11.693						103000			
Feeder Details :-																									
Name of PTR	Capacity (In MVA)	Total Recorded Maximum Loading on Feeders(In Amp.)																				Total (In Amp.)	Equivalent MVA Loading	Max % Loading Recorded	
		Feeder 1		Feeder 2		Feeder 3		Feeder 4		Feeder 5		Feeder 6		Feeder 7		Feeder 8		Feeder 9		Feeder 10					
		Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity				
PTR-1	40	33 KV	130	33 KV	100	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	230	13.15	32.86
PTR-2	63	33 KV	130	33 KV	320	33 KV	320	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	770	44.01	69.86
PTR-3	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PTR-4	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PTR-5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
4	Lalganj															N25 47.734 E82 59.737						80000			
Feeder Details :-																									
Name of PTR	Capacity (In MVA)	Total Recorded Maximum Loading on Feeders(In Amp.)																				Total (In Amp.)	Equivalent MVA Loading	Max % Loading Recorded	
		Feeder 1		Feeder 2		Feeder 3		Feeder 4		Feeder 5		Feeder 6		Feeder 7		Feeder 8		Feeder 9		Feeder 10					
		Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity				
PTR-1	40	33 KV	30	33 KV	30	33 KV	340	33 KV	85	0	0	0	0	0	0	0	0	0	0	0	0	0	485	27.72	69.3
PTR-2	40	33 KV	170	33 KV	100	33 KV	300	33 KV	180	33 KV	40	0	0	0	0	0	0	0	0	0	0	0	790	45.15	112.88
PTR-3	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PTR-4	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PTR-5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0

EHV Substation Feeding the District

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of existing 33/11 KV substation												GPS Coordinate								Capacity of Substation (In KVA)				
5	Atrauliya												N26 20.729 E82 55.609								40000				
Feeder Details :-																									
Name of PTR	Capacity (In MVA)	Total Recorded Maximum Loading on Feeders(In Amp.)																				Total (In Amp.)	Equivalent MVA Loading	Max % Loading Recorded	
		Feeder 1		Feeder 2		Feeder 3		Feeder 4		Feeder 5		Feeder 6		Feeder 7		Feeder 8		Feeder 9		Feeder 10					
		Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity				
PTR-1	20	33 KV	210	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	210	12	60.01
PTR-2	20	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PTR-3	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PTR-4	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PTR-5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
6	Koilsa												N26 16.171 E83 01.294								40000				
Feeder Details :-																									
Name of PTR	Capacity (In MVA)	Total Recorded Maximum Loading on Feeders(In Amp.)																				Total (In Amp.)	Equivalent MVA Loading	Max % Loading Recorded	
		Feeder 1		Feeder 2		Feeder 3		Feeder 4		Feeder 5		Feeder 6		Feeder 7		Feeder 8		Feeder 9		Feeder 10					
		Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity				
PTR-1	20	33 KV	280	33 KV	100	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	380	21.72	108.6
PTR-2	20	33 KV	120	33 KV	240	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	360	20.58	102.88
PTR-3	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PTR-4	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PTR-5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0

EHV Substation Feeding the District

State : UTTAR PRADESH
 District : Azamgarh

Sl.No.	Name of existing 33/11 KV substation												GPS Coordinate								Capacity of Substation (In KVA)				
7	Meh Nagar												N25 53.351 E83 05.641								40000				
Feeder Details :-																									
Name of PTR	Capacity (In MVA)	Total Recorded Maximum Loading on Feeders(In Amp.)																				Total (In Amp.)	Equivalent MVA Loading	Max % Loading Recorded	
		Feeder 1		Feeder 2		Feeder 3		Feeder 4		Feeder 5		Feeder 6		Feeder 7		Feeder 8		Feeder 9		Feeder 10					
		Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity				
PTR-1	20	33 KV	160	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	160	9.14	45.72
PTR-2	20	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PTR-3	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PTR-4	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PTR-5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
8	Dohri ghat (Mau District)												26.24305,83.5116949								80000				
Feeder Details :-																									
Name of PTR	Capacity (In MVA)	Total Recorded Maximum Loading on Feeders(In Amp.)																				Total (In Amp.)	Equivalent MVA Loading	Max % Loading Recorded	
		Feeder 1		Feeder 2		Feeder 3		Feeder 4		Feeder 5		Feeder 6		Feeder 7		Feeder 8		Feeder 9		Feeder 10					
		Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity				
PTR-1	40	11 KV	8	11 KV	20	11 KV	10	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	38	0.72	1.81
PTR-2	40	11 KV	30	11 KV	30	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	60	1.14	2.86
PTR-3	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PTR-4	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PTR-5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0

EHV Substation Feeding the District

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of existing 33/11 KV substation															GPS Coordinate					Capacity of Substation (In KVA)					
9	Kudeshwar GSS (Ghazipur District)															25 36 51.51N, 83 49 16.22E					60000					
Feeder Details :-																										
Name of PTR	Capacity (In MVA)	Total Recorded Maximum Loading on Feeders(In Amp.)																				Total (In Amp.)	Equivalent MVA Loading	Max % Loading Recorded		
		Feeder 1		Feeder 2		Feeder 3		Feeder 4		Feeder 5		Feeder 6		Feeder 7		Feeder 8		Feeder 9		Feeder 10						
		Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity					
PTR-1	40	33 KV	160	33 KV	300	33 KV	450	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	910	52.01	130.03
PTR-2	20	33 KV	340	33 KV	450	33 KV	160	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	950	54.3	271.49
PTR-3	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PTR-4	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PTR-5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0

Districtwise Details of Existing 66 KV or 33 KV Lines

State : UTTAR PRADESH
District : Azamgarh

S.No.	Name of Block	Name of 132/33 kV Source Substation	Name of Destination Substation	Line Type	Length of line(kms.)
1	2	3	4	5	6
2	Ahraula	Phoolpur	AHIRAULA	33KV LINE ON PCC POLES WITH DOG CONDUCTOR	22
		Koilsa	MDIYAPAR	33KV LINE ON PCC POLES WITH DOG CONDUCTOR	18
		PAWAI	MAHUL	33KV LINE ON PCC POLES WITH DOG CONDUCTOR	8
6	Atraulia	Atrauliya	ATRAULIA	33KV LINE ON PCC POLES WITH DOG CONDUCTOR	0.2
8	Azmatgarh	LATGHAT	MALTADI	33KV LINE ON PCC POLES WITH DOG CONDUCTOR	25
		JIYANPUR	AMUWARI NARAINPUR	33KV LINE ON PCC POLES WITH DOG CONDUCTOR	35
		Hafizpur	JIYANPUR	33KV LINE ON PCC POLES WITH DOG CONDUCTOR	19
		Dohri ghat (Mau District)	LATGHAT	33KV LINE ON PCC POLES WITH DOG CONDUCTOR	12
13	Bilariyaganj	Hafizpur	BILARIYAGANJ	33KV LINE ON PCC POLES WITH DOG CONDUCTOR	17
		BILARIYAGANJ	PATWADH KAUTAK	33KV LINE ON PCC POLES WITH DOG CONDUCTOR	10
16	Haraiya	BILARIYAGANJ	RAUNAPUR	33KV LINE ON PCC POLES WITH DOG CONDUCTOR	30
		LATGHAT	MAU KUTUBPUR	33KV LINE ON PCC POLES WITH DOG CONDUCTOR	7
19	Jahanaganj	Sidhari	CHANDESHWAR	33KV LINE ON PCC POLES WITH DOG CONDUCTOR	7
		Sidhari	JAHANGANJ	33KV LINE ON PCC POLES WITH DOG CONDUCTOR	20
		CHANDESHWAR	KANILA	33KV LINE ON PCC POLES WITH DOG CONDUCTOR	20
		JAHANGANJ	SHERPUR	33KV LINE ON PCC POLES WITH DOG CONDUCTOR	35
24	Koilsa	KAPTANGANJ	GOPALGANJ	33KV LINE ON PCC POLES WITH DOG CONDUCTOR	20
		Koilsa	RANIPUR	33KV LINE ON PCC POLES WITH DOG CONDUCTOR	0.2
		MADIYAPAR	SIKHULA	33KV LINE ON PCC POLES WITH DOG CONDUCTOR	31
		Koilsa	TEHSIL BURHANPUR	33KV LINE ON PCC POLES WITH DOG CONDUCTOR	15
29	Lalganj	Lalganj	DEOGAON	33KV LINE ON PCC POLES WITH DOG CONDUCTOR	7
		Lalganj	LALGANJ	33KV LINE ON PCC POLES WITH DOG CONDUCTOR	0.1

Districtwise Details of Existing 66 KV or 33 KV Lines

State : UTTAR PRADESH
District : Azamgarh

S.No.	Name of Block	Name of 132/33 kV Source Substation	Name of Destination Substation	Line Type	Length of line(kms.)
1	2	3	4	5	6
		Lalganj	JIRAKPUR	33KV LINE ON PCC POLES WITH DOG CONDUCTOR	15
		Lalganj	GOSAI KI BAZAR	33KV LINE ON PCC POLES WITH DOG CONDUCTOR	8
34	Mahrajanj	RANIPUR	MAHRAJGANJ	33KV LINE ON PCC POLES WITH DOG CONDUCTOR	10
		Koilsa	KAPTANGANJ	33KV LINE ON PCC POLES WITH DOG CONDUCTOR	10
37	Martinganj	BARDAH	MARTINGANJ	33KV LINE ON PCC POLES WITH DOG CONDUCTOR	35
39	Mehnagar	Meh Nagar	MEH NAGAR	33KV LINE ON PCC POLES WITH DOG CONDUCTOR	1
		TARWA	KHAMARIYA	33KV LINE ON PCC POLES WITH DOG CONDUCTOR	32
42	Mirzapur	Phoolpur	DATTATREYA	33KV LINE ON PCC POLES WITH DOG CONDUCTOR	17
		Phoolpur	SARAI MEER	33KV LINE ON PCC POLES WITH DOG CONDUCTOR	10
45	Mohammadpur	Sidhari	CHHAU	33KV LINE ON PCC POLES WITH DOG CONDUCTOR	32
		THEKMA	GOTHAWAN	33KV LINE ON PCC POLES WITH DOG CONDUCTOR	20
		Sidhari	MUHAMMAD PUR	33KV LINE ON PCC POLES WITH DOG CONDUCTOR	22
49	Palhani	BHAWARNATH	ZAFFARPUR	33KV LINE ON PCC POLES WITH DOG CONDUCTOR	18
51	Palhna	Hafizpur	SHEIKHPURA	33KV LINE ON PCC POLES WITH DOG CONDUCTOR	2
		DEOGAON	KARSARA	33KV LINE ON PCC POLES WITH DOG CONDUCTOR	20
		TARWA	PALAHANA	33KV LINE ON PCC POLES WITH DOG CONDUCTOR	10
		Hafizpur	BHAWAR NATH	33KV LINE ON PCC POLES WITH DOG CONDUCTOR	5
		Hafizpur	KANDHARPUR	33KV LINE ON PCC POLES WITH DOG CONDUCTOR	35
57	Pawai	Phoolpur	PAWAI	33KV LINE ON PCC POLES WITH DOG CONDUCTOR	17
		PAWAI	BAGH BAHAR	33KV LINE ON PCC POLES WITH DOG CONDUCTOR	20
60	Phulpur	Phoolpur	PHOOLPUR	33KV LINE ON PCC POLES WITH DOG CONDUCTOR	1
		SARAI MEER	GADDO PUR	33KV LINE ON PCC POLES WITH DOG CONDUCTOR	20

Districtwise Details of Existing 66 KV or 33 KV Lines

State : UTTAR PRADESH
District : Azamgarh

S.No.	Name of Block	Name of 132/33 kV Source Substation	Name of Destination Substation	Line Type	Length of line(kms.)
1	2	3	4	5	6
		SARAI MEER	PUSHP NAGAR	33KV LINE ON PCC POLES WITH DOG CONDUCTOR	16
64	Rani Ki Sarai	MUHAMMAD PUR	RANI KI SARAI	33KV LINE ON PCC POLES WITH DOG CONDUCTOR	12
66	Sathiyaon	MUBARAKPUR	MOHABBATPUR	33KV LINE ON PCC POLES WITH DOG CONDUCTOR	12
		Hafizpur	MUBARAKPUR	33KV LINE ON PCC POLES WITH DOG CONDUCTOR	18
69	Tahbarpur	Sidhari	SOFIPUR	33KV LINE ON PCC POLES WITH DOG CONDUCTOR	20
		SOFIPUR	ORA	33KV LINE ON PCC POLES WITH DOG CONDUCTOR	28
		DATTATREYA	MANJHARI	33KV LINE ON PCC POLES WITH DOG CONDUCTOR	21
73	Tarwa	JAHANGANJ	RASEPUR	33KV LINE ON PCC POLES WITH DOG CONDUCTOR	50
		Lalganj	TARWA	33KV LINE ON PCC POLES WITH DOG CONDUCTOR	20
		TARWA	MEHNAJPUR	33KV LINE ON PCC POLES WITH DOG CONDUCTOR	30
77	Thekma	Lalganj	BARDAH	33KV LINE ON PCC POLES WITH DOG CONDUCTOR	20
		Lalganj	THEKMA	33KV LINE ON PCC POLES WITH DOG CONDUCTOR	17
Total					982.5

Districtwise Details of Existing 11 KV or 22 KV Lines

State : UTTAR PRADESH
District : Azamgarh

S.No.	Name of Block	Name of Substation	Name of Feeder	Conductor Name	Pole Type	Length(kms.)
1	2	3	4	5	6	7
1	Ahiraula	AHIRAULA	Ahiraula	Weasel-30 sqmm.	PCC	12
		AHIRAULA	Atraulia	Weasel-30 sqmm.	PCC	28
		AHIRAULA	Kaptanganj	Weasel-30 sqmm.	PCC	10
		MDIYAPAR	Karsara	Weasel-30 sqmm.	PCC	15
		MDIYAPAR	Bhedaura	Weasel-30 sqmm.	PCC	27
		MDIYAPAR	Badhiya	Weasel-30 sqmm.	PCC	10
		MAHUL	Bazar Gosai	Weasel-30 sqmm.	PCC	24
2	Atraulia	ATRAULIA	ATRAULIA	Weasel-30 sqmm.	PCC	20
		ATRAULIA	WEST	Weasel-30 sqmm.	PCC	13
		ATRAULIA	EAST	Weasel-30 sqmm.	PCC	8
		ATRAULIA	NORTH	Weasel-30 sqmm.	PCC	15
		ATRAULIA	West 2	Weasel-30 sqmm.	PCC	14
3	Azmatgarh	AMUWARI NARAINPUR	East	Weasel-30 sqmm.	PCC	20
		AMUWARI NARAINPUR	West	Weasel-30 sqmm.	PCC	25
		AMUWARI NARAINPUR	Bhuana	Weasel-30 sqmm.	PCC	10
		JIYANPUR	North	Weasel-30 sqmm.	PCC	12
		JIYANPUR	East	Weasel-30 sqmm.	PCC	20
		JIYANPUR	West	Weasel-30 sqmm.	PCC	25
		LATGHAT	Kaithauli	Weasel-30 sqmm.	PCC	19
		LATGHAT	Mahula	Weasel-30 sqmm.	PCC	9
		LATGHAT	Bardeeha	Weasel-30 sqmm.	PCC	26
		MALTADI	Basgaon	Weasel-30 sqmm.	PCC	9

Districtwise Details of Existing 11 KV or 22 KV Lines

State : UTTAR PRADESH
District : Azamgarh

S.No.	Name of Block	Name of Substation	Name of Feeder	Conductor Name	Pole Type	Length(kms.)
1	2	3	4	5	6	7
1		MALTADI	North	Weasel-30 sqmm.	PCC	26
		MALTADI	West	Weasel-30 sqmm.	PCC	5
4	Bilariyaganj	BILARIYAGANJ	North	Weasel-30 sqmm.	PCC	12
		BILARIYAGANJ	East	Weasel-30 sqmm.	PCC	17
		BILARIYAGANJ	West	Weasel-30 sqmm.	PCC	18
		PATWADH KAUTAK	EAST	Weasel-30 sqmm.	PCC	15
		PATWADH KAUTAK	West	Weasel-30 sqmm.	PCC	20
		PATWADH KAUTAK	South	Weasel-30 sqmm.	PCC	16
5	Haraiya	RAUNAPUR	West	Weasel-30 sqmm.	PCC	20
		RAUNAPUR	East	Weasel-30 sqmm.	PCC	30
		RAUNAPUR	South	Weasel-30 sqmm.	PCC	8
		MAU KUTUBPUR	North	Weasel-30 sqmm.	PCC	15
		MAU KUTUBPUR	West	Weasel-30 sqmm.	PCC	28
		MAU KUTUBPUR	Bazar Gosai	Weasel-30 sqmm.	PCC	25
6	Jahanaganj	CHANDESHWAR	Nibi	Weasel-30 sqmm.	PCC	35
		CHANDESHWAR	Sameda	Weasel-30 sqmm.	PCC	30
		CHANDESHWAR	Karanpur	Weasel-30 sqmm.	PCC	30
		JAHANGANJ	Jahanaganj	Weasel-30 sqmm.	PCC	15
		JAHANGANJ	Parasi	Weasel-30 sqmm.	PCC	20
		JAHANGANJ	Godhawra	Weasel-30 sqmm.	PCC	12
		JAHANGANJ	Sumbhi	Weasel-30 sqmm.	PCC	15
		KANILA	Barora	Weasel-30 sqmm.	PCC	12

Districtwise Details of Existing 11 KV or 22 KV Lines

State : UTTAR PRADESH
District : Azamgarh

S.No.	Name of Block	Name of Substation	Name of Feeder	Conductor Name	Pole Type	Length(kms.)
1	2	3	4	5	6	7
1		KANILA	Jigarsandi	Weasel-30 sqmm.	PCC	12
		SHERPUR	Sherpur Kuti	Weasel-30 sqmm.	PCC	10
		SHERPUR	Parsaha	Weasel-30 sqmm.	PCC	2
7	Koilsa	GOPALGANJ	Gopalganj	Weasel-30 sqmm.	PCC	18
		GOPALGANJ	Marfora	Weasel-30 sqmm.	PCC	15
		RANIPUR	Khatoliya Feeder	Weasel-30 sqmm.	PCC	25
		RANIPUR	Tonari Feeder	Weasel-30 sqmm.	PCC	10
		RANIPUR	Koilsa Feeder	Weasel-30 sqmm.	PCC	25
		SIKHULA	Sultanipuri	Weasel-30 sqmm.	PCC	35
		SIKHULA	Chimkuni	Weasel-30 sqmm.	PCC	18
		TEHSIL BURHANPUR	Basgan	Weasel-30 sqmm.	PCC	20
		TEHSIL BURHANPUR	Bheelampur	Weasel-30 sqmm.	PCC	4
		TEHSIL BURHANPUR	Makhanaha	Weasel-30 sqmm.	PCC	10
8	Lalganj	DEOGAON	Deogaon	Weasel-30 sqmm.	PCC	6
		DEOGAON	Kanhjit	Weasel-30 sqmm.	PCC	10
		DEOGAON	Basahi	Weasel-30 sqmm.	PCC	11
		LALGANJ	Sonwar	Weasel-30 sqmm.	PCC	20
		LALGANJ	Gosai bazar	Weasel-30 sqmm.	PCC	30
		LALGANJ	Devgaon	Weasel-30 sqmm.	PCC	35
		LALGANJ	Lumbhua	Weasel-30 sqmm.	PCC	25
		JIRAKPUR	Sikraura	Weasel-30 sqmm.	PCC	13
		JIRAKPUR	Agehta	Weasel-30 sqmm.	PCC	18

Districtwise Details of Existing 11 KV or 22 KV Lines

State : UTTAR PRADESH
District : Azamgarh

S.No.	Name of Block	Name of Substation	Name of Feeder	Conductor Name	Pole Type	Length(kms.)
1	2	3	4	5	6	7
		GOSAI KI BAZAR	Ubarpur	Weasel-30 sqmm.	PCC	21
		GOSAI KI BAZAR	Gosai ki Bazar	Weasel-30 sqmm.	PCC	15
		GOSAI KI BAZAR	Pandaha	Weasel-30 sqmm.	PCC	24
9	Mahrajanj	MAHRAJGANJ	West	Weasel-30 sqmm.	PCC	10
		MAHRAJGANJ	East	Weasel-30 sqmm.	PCC	20
		MAHRAJGANJ	North	Weasel-30 sqmm.	PCC	15
		MAHRAJGANJ	World bank	Weasel-30 sqmm.	PCC	25
		KAPTANGANJ	Bhawanpur	Weasel-30 sqmm.	PCC	14
		KAPTANGANJ	kaptanganj	Weasel-30 sqmm.	PCC	5
		KAPTANGANJ	Deoria	Weasel-30 sqmm.	PCC	18
		KAPTANGANJ	Mehmauni	Weasel-30 sqmm.	PCC	14
10	Martinganj	MARTINGANJ	Bakhara Feeder	Weasel-30 sqmm.	PCC	45
		MARTINGANJ	Siswara Feeder	Weasel-30 sqmm.	PCC	30
		MARTINGANJ	Belwana Feeder	Weasel-30 sqmm.	PCC	60
11	Mehnagar	MEH NAGAR	Laudah	Weasel-30 sqmm.	PCC	18
		MEH NAGAR	Chakwara	Weasel-30 sqmm.	PCC	20
		MEH NAGAR	Kharag Pur	Weasel-30 sqmm.	PCC	12
		KHAMARIYA	Khatahan	Weasel-30 sqmm.	PCC	18
		KHAMARIYA	Kamharia	Weasel-30 sqmm.	PCC	18
12	Mirzapur	DATTATREYA	Nizamabad	Weasel-30 sqmm.	PCC	9
		DATTATREYA	Mirzapur	Weasel-30 sqmm.	PCC	9
		DATTATREYA	Mohnathpur	Weasel-30 sqmm.	PCC	17

Districtwise Details of Existing 11 KV or 22 KV Lines

State : UTTAR PRADESH
District : Azamgarh

S.No.	Name of Block	Name of Substation	Name of Feeder	Conductor Name	Pole Type	Length(kms.)
1	2	3	4	5	6	7
1		SARAI MEER	Basti	Weasel-30 sqmm.	PCC	20
		SARAI MEER	Nandau	Weasel-30 sqmm.	PCC	15
13	Mohammadpur	CHHAU	Belu	Weasel-30 sqmm.	PCC	6
		CHHAU	Chhau	Weasel-30 sqmm.	PCC	20
		CHHAU	Gambhirpur	Weasel-30 sqmm.	PCC	10
		MUHAMMAD PUR	North	Weasel-30 sqmm.	PCC	35
		MUHAMMAD PUR	South	Weasel-30 sqmm.	PCC	50
		MUHAMMAD PUR	Rowa	Weasel-30 sqmm.	PCC	19
		MUHAMMAD PUR	Bindra Bazar	Weasel-30 sqmm.	PCC	4
		GOTHAWAN	Gothawan	Weasel-30 sqmm.	PCC	26
		GOTHAWAN	Nandaoh	Weasel-30 sqmm.	PCC	24
14	Palhani	ZAFFARPUR	South	Weasel-30 sqmm.	PCC	18
15	Palhna	SHEIKHPURA	Ahopatti	Weasel-30 sqmm.	PCC	12
		SHEIKHPURA	Badhopur	Weasel-30 sqmm.	PCC	14
		KARSARA	Chutara	Weasel-30 sqmm.	PCC	14
		KARSARA	Karsara	Weasel-30 sqmm.	PCC	10
		KARSARA	Bela	Weasel-30 sqmm.	PCC	4
		PALAHANA	Palahana	Weasel-30 sqmm.	PCC	12
		PALAHANA	Lhua	Weasel-30 sqmm.	PCC	18
		BHAWAR NATH	Heera palti	Weasel-30 sqmm.	PCC	24
		BHAWAR NATH	Kandharapur	Weasel-30 sqmm.	PCC	27
		KANDHARPUR	Azampur	Weasel-30 sqmm.	PCC	15

Districtwise Details of Existing 11 KV or 22 KV Lines

State : UTTAR PRADESH
District : Azamgarh

S.No.	Name of Block	Name of Substation	Name of Feeder	Conductor Name	Pole Type	Length(kms.)
1	2	3	4	5	6	7
		KANDHARPUR	Kandharpur	Weasel-30 sqmm.	PCC	18
16	Pawai	BAGH BAHAR	Kalan	Weasel-30 sqmm.	PCC	13
		BAGH BAHAR	Sahdulla	Weasel-30 sqmm.	PCC	16
		BAGH BAHAR	Khairuddinpur	Weasel-30 sqmm.	PCC	19
		PAWAI	Mahul Feeder	Weasel-30 sqmm.	PCC	10
		PAWAI	Belwai Feeder	Weasel-30 sqmm.	PCC	8
		PAWAI	Balaipur Feeder	Weasel-30 sqmm.	PCC	12
		PAWAI	Pawai	Weasel-30 sqmm.	PCC	23
17	Phulpur	PHOOLPUR	North	Weasel-30 sqmm.	PCC	12
		PHOOLPUR	West	Weasel-30 sqmm.	PCC	40
		PHOOLPUR	East	Weasel-30 sqmm.	PCC	24
		PHOOLPUR	South	Weasel-30 sqmm.	PCC	20
		GADDO PUR	Palthi	Weasel-30 sqmm.	PCC	7
		GADDO PUR	Gaddo Pur	Weasel-30 sqmm.	PCC	28
		PUSHP NAGAR	Deedarganj	Weasel-30 sqmm.	PCC	15
		PUSHP NAGAR	Sikraura	Weasel-30 sqmm.	PCC	13
18	Rani Ki Sarai	RANI KI SARAI	Rani ki sarai	Weasel-30 sqmm.	PCC	23
		RANI KI SARAI	Sonwara	Weasel-30 sqmm.	PCC	10
		RANI KI SARAI	Vasti	Weasel-30 sqmm.	PCC	14
19	Sathiyaon	MOHABBATPUR	Shahgarh	Weasel-30 sqmm.	PCC	26
		MOHABBATPUR	Bamhaur	Weasel-30 sqmm.	PCC	17
		MUBARAKPUR	Newada Rural	Weasel-30 sqmm.	PCC	25

Districtwise Details of Existing 11 KV or 22 KV Lines

State : UTTAR PRADESH
District : Azamgarh

S.No.	Name of Block	Name of Substation	Name of Feeder	Conductor Name	Pole Type	Length(kms.)
1	2	3	4	5	6	7
		MUBARAKPUR	Sthiyaon	Weasel-30 sqmm.	PCC	30
20	Tahbarpur	SOFIPUR	Nizamabad	Weasel-30 sqmm.	PCC	10
		SOFIPUR	Semari	Weasel-30 sqmm.	PCC	22
		SOFIPUR	Nizamabad 2	Weasel-30 sqmm.	PCC	15
		SOFIPUR	Tahbarpur	Weasel-30 sqmm.	PCC	15
		ORA	Ora	Weasel-30 sqmm.	PCC	10
		ORA	Deohatta	Weasel-30 sqmm.	PCC	28
		ORA	Sarai Barkat	Weasel-30 sqmm.	PCC	4
		MANJHARI	Dhania kundi	Weasel-30 sqmm.	PCC	6
		MANJHARI	Manjhari	Weasel-30 sqmm.	PCC	3
		MANJHARI	Kariawar	Weasel-30 sqmm.	PCC	12
21	Tarwa	RASEPUR	Kanchanpur	Weasel-30 sqmm.	PCC	35
		RASEPUR	Sherpur	Weasel-30 sqmm.	PCC	25
		RASEPUR	Bongariya	Weasel-30 sqmm.	PCC	15
		TARWA	Sidhauna	Weasel-30 sqmm.	PCC	10
		TARWA	Meh Nagar	Weasel-30 sqmm.	PCC	15
		TARWA	Mehnajpur	Weasel-30 sqmm.	PCC	18
		MEHNAJPUR	Nath PUR	Weasel-30 sqmm.	PCC	24
		MEHNAJPUR	Rowa para	Weasel-30 sqmm.	PCC	13
		MEHNAJPUR	Mehnaj Pur	Weasel-30 sqmm.	PCC	26
22	Thekma	BARDAH	Bardah	Weasel-30 sqmm.	PCC	60
		BARDAH	Bahadurpur	Weasel-30 sqmm.	PCC	55

Districtwise Details of Existing 11 KV or 22 KV Lines

State : UTTAR PRADESH
District : Azamgarh

S.No.	Name of Block	Name of Substation	Name of Feeder	Conductor Name	Pole Type	Length(kms.)
1	2	3	4	5	6	7
		BARDAH	Jiblee	Weasel-30 sqmm.	PCC	35
		THEKMA	Tahbarpur	Weasel-30 sqmm.	PCC	18
		THEKMA	Sarai Mohan	Weasel-30 sqmm.	PCC	10
		THEKMA	Thekma	Weasel-30 sqmm.	PCC	20
Total						2928

Details of New 66 KV or 33 KV Lines

State : UTTAR PRADESH
 District : Azamgarh

S.No.	Name of Block	Name of Source Substation	Name of Destination Substation	Line Type	Length(kms.)	11KV Bay(If required)	Remarks
1	2	3	4	5	6	7	8
1	Sathiyaon	Hafizpur	Sathiyav (Amilo)(NEW)	33KV LINE ON PCC POLES WITH DOG CONDUCTOR	16	1	
Total					16		

Details of New 11 KV or 22 KV Lines

State : UTTAR PRADESH
District : Azamgarh

S.No.	Name of Block	Name of Emanating Substation	Name of feeder	Section of Feeder		Line Type	Length(k ms.)	Nos of Bay (If required)	Remarks	Line on ABC cable in Forest Area/Populated Area	Length of ABC cable (Kms.)
				From Location	To Location						
1	2	3	4	5	6	7	8	9	10	11	12
1	Sathiyaon	Sathiyav (Amilo)	New Feeder 1	Sathiyav (Amilo)	New Location	PCC POLES WITH RABBIT CONDUCTOR	4	0			0
		Sathiyav (Amilo)	New Feeder 2	Sathiyav (Amilo)	New Location	PCC POLES WITH RABBIT CONDUCTOR	3	0			0
		Sathiyav (Amilo)	New Feeder 3	Sathiyav (Amilo)	New Location	PCC POLES WITH RABBIT CONDUCTOR	4.37	0			0
Total							11.37				0

Augmentation of 66 KV or 33 KV Lines

State : UTTAR PRADESH
District : Azamgarh

Sl.No.	Name of Block	Name of Feeder	Type of Item	Length (Ckt.Kms)	Section	Existing Load in Overload ed Section(In n MW)	Section Start From	Section Upto	Length (In Kms.)	Existing Conductor	%age Loading	Renovated Conductor	Intermediatory pole(Nos.)
1	Tarwa	From TARWA to MEHNAJPUR	33KV LINE ON PCC POLES WITH DOG CONDUCTOR	30	Section 1	3.65	Tarwa	Mehnajpur	7	Dog-100 sqmm.	0	Dog-100 sqmm.	0

SAGY

State : UTTAR PRADESH

District : Azamgarh

Block-wise coverage of villages

State : UTTAR PRADESH
District : Azamgarh

S.No.	Name of Block	Total no. of villages as per census	Villages proposed under present scheme	Habitations proposed under present scheme	Total RHhs (Incl. BPL Hhs)	No of RHhs already electrified upto 31.03.15	% Electrification as on 31.03.15	RHhs(Incl. BPL) Already sanctioned and under execution in erstwhile RGGVY/State/ other schemes	Balance to be electrified	RHhs Proposed under present scheme	BPL Proposed under present scheme
1	2	3	4	5	6	7	8	9	10	11	12
1	Ahiraula	0	0	0	0	0	0	0	0	0	0
2	Atraulia	1	1	10	522	441	84.48	0	81	81	22
3	Azmatgarh	0	0	0	0	0	0	0	0	0	0
4	Bilariyaganj	0	0	0	0	0	0	0	0	0	0
5	Haraiya	0	0	0	0	0	0	0	0	0	0
6	Jahanaganj	0	0	0	0	0	0	0	0	0	0
7	Koilsa	0	0	0	0	0	0	0	0	0	0
8	Lalganj	0	0	0	0	0	0	0	0	0	0
9	Mahrajganj	0	0	0	0	0	0	0	0	0	0
10	Martinganj	0	0	0	0	0	0	0	0	0	0
11	Mehnagar	0	0	0	0	0	0	0	0	0	0
12	Mirzapur	0	0	0	0	0	0	0	0	0	0
13	Mohammadpur	0	0	0	0	0	0	0	0	0	0
14	Palhani	1	1	9	610	546	89.51	0	64	64	21
15	Palhna	1	1	4	82	23	28.05	0	59	59	10
16	Pawai	0	0	0	0	0	0	0	0	0	0
17	Phulpur	0	0	0	0	0	0	0	0	0	0
18	Rani Ki Sarai	0	0	0	0	0	0	0	0	0	0
19	Sathiyaon	0	0	0	0	0	0	0	0	0	0
20	Tahbarpur	0	0	0	0	0	0	0	0	0	0

Block-wise coverage of villages

State : UTTAR PRADESH
 District : Azamgarh

S.No.	Name of Block	Total no. of villages as per census	Villages proposed under present scheme	Habitations proposed under present scheme	Total RHhs (Incl. BPL Hhs)	No of RHhs already electrified upto 31.03.15	% Electrification as on 31.03.15	RHhs(Incl. BPL) Already sanctioned and under execution in erstwhile RGGVY/State/ other schemes	Balance to be electrified	RHhs Proposed under present scheme	BPL Proposed under present scheme
1	2	3	4	5	6	7	8	9	10	11	12
21	Tarwa	0	0	0	0	0	0	0	0	0	0
22	Thekma	0	0	0	0	0	0	0	0	0	0
Total		3	3	23	1214	1010	83.2	0	204	204	53

Villagewise/Habitation wise coverage

State : UTTAR PRADESH
District : Azamgarh

Sl.No. (Vill.)	Name of Village (all villages as per census)	Census Code (2011)	Name of Habitation including main villages	Habitation Code	Total No. of RHs	No of RHs electrified as on 31.03.2015	Balance Nos. of RHH to be electrified as on 31.03.2015	Total BPL already sanctioned under execution in erstwhile RGGVY/State/Ce ntral Scheme as on 31/3/2015	No of RHs proposed to be electrified including BPL	No of BPL Hhs proposed to be electrified
1	2	3	4	5	6	7	8	9	10	11
Block :: Atraulia										
1	Lohra	191955	Bharsani Purva	191955-009	12	10	2	0	2	0
			Dharwa Yadav Basti	191955-010	80	74	6	0	6	0
			Dharwa Harijan Basti	191955-011	70	65	5	0	5	0
			Dharwa Thakur Basti	191955-012	40	35	5	0	5	0
			Thakurpur Nishad Basti	191955-013	10	6	4	0	4	0
			Lohra Harijan Basti	191955-016	160	155	5	0	5	1
			Pikkia nala ke kinare Harijan Basti	191955-019	15	0	15	0	15	10
			Pikkia nala ke Kinare Nishad Basti	191955-020	15	0	15	0	15	10
			Dhihwa	191955-021	70	60	10	0	10	1
			Kariwa Tar Nishad Basti	191955-022	50	36	14	0	14	0
Total - Atraulia					522	441	81	0	81	22
Block :: Palhani										
1	Tamauli	193694	Purab ka Pura	193694-011	150	130	20	0	20	9

Villagewise/Habitation wise coverage

State : UTTAR PRADESH
District : Azamgarh

Sl.No. (Vill.)	Name of Village (all villages as per census)	Census Code (2011)	Name of Habitation including main villages	Habitation Code	Total No. of RHs	No of RHs electrified as on 31.03.2015	Balance Nos. of RHH to be electrified as on 31.03.2015	Total BPL already sanctioned under execution in erstwhile RGGVY/State/Central Scheme as on 31/3/2015	No of RHs proposed to be electrified including BPL	No of BPL Hhs proposed to be electrified
1	2	3	4	5	6	7	8	9	10	11
			Pachim ka Pura	193694-012	150	135	15	0	15	6
			Chayana	193694-013	150	140	10	0	10	1
			Mafi harijan basti	193694-014	25	23	2	0	2	0
			Chiryawan ka Pura	193694-016	35	31	4	0	4	1
			Kunhar Basti	193694-017	20	17	3	0	3	1
			Purab ki Harijan	193694-018	35	32	3	0	3	1
			Mari mayan Harijan Basti	193694-019	30	26	4	0	4	1
			Bdhai ka Pura	193694-020	15	12	3	0	3	1
Total - Palhani					610	546	64	0	64	21
Block :: Palhna										
1	Lahuwa Khurd	195593	CHIRAJPUR	195593-017	17	5	12	0	12	2
			LATEHARA	195593-019	21	6	15	0	15	3
			MADYA RAJBHAR BASTI	195593-022	33	9	24	0	24	4
			MADYA KOHRANA	195593-023	11	3	8	0	8	1
Total - Palhna					82	23	59	0	59	10
Summary										
Atraulia					522	441	81	0	81	22

Villagewise/Habitation wise coverage

State : UTTAR PRADESH
District : Azamgarh

Sl.No. (Vill.)	Name of Village (all villages as per census)	Census Code (2011)	Name of Habitation including main villages	Habitation Code	Total No. of RHhs	No of RHhs electrified as on 31.03.2015	Balance Nos. of RHH to be electrified as on 31.03.2015	Total BPL already sanctioned under execution in erstwhile RGGVY/State/Ce ntral Scheme as on 31/3/2015	No of RHhs proposed to be electrified including BPL	No of BPL Hhs proposed to be electrified
1	2	3	4	5	6	7	8	9	10	11
Palhani					610	546	64	0	64	21
Palhna					82	23	59	0	59	10
Grand Total					1214	1010	204	0	204	53

Existing Habitation Wise Infrastructure

State : UTTAR PRADESH
District : Azamgarh

Sl.No. (Vill.)	Name of Village (all villages as per census)	Census Code (2011)	Name of Habitation including main villages	Habitation Code	Existing LT Networks (in Kms)				Existing Distribution Transformers (DT)	Total (DT)
					Overhead	AB cable	Overhead	AB cable		
1	2	3	4	5	6	7	8	9	10	11
Block :: Atraulia										
1	Lohra	191955	Bharsani Purva	191955-009	0	0.02	0	0		0
			Dharwa Yadav Basti	191955-010	0	1.14	0	0.21	1 * (25 KVA (3 Ph)) + 1 * (16 KVA (1 Ph))	2
			Dharwa Harijan Basti	191955-011	0	1.16	0	0.34	1 * (25 KVA (3 Ph)) + 1 * (16 KVA (1 Ph))	2
			Dharwa Thakur Basti	191955-012	0	1.08	0	0.89	1 * (25 KVA (3 Ph))	1
			Thakurpur Nishad Basti	191955-013	0	1.02	0	0		0
			Lohra Harijan Basti	191955-016	0	1.24	0	0.44	1 * (250 KVA (3 Ph)) + 1 * (16 KVA (1 Ph))	2
			Pikkia nala ke kinare Harijan Basti	191955-019	0	0.34	0	0		0
			Pikkia nala ke Kinare Nishad Basti	191955-020	0	0.38	0	0		0
			Dhihwa	191955-021	0	1.42	0	0.1	1 * (25 KVA (3 Ph)) + 1 * (63 KVA (3 Ph))	2
			Kariwa Tar Nishad Basti	191955-022	0	1.02	0	0.42	1 * (63 KVA (3 Ph)) + 1 * (16 KVA (3 Ph))	2
Total - Atraulia					0	8.82	0	2.4		
Block :: Palhani										
1	Tamauli	193694	Purab ka Pura	193694-011	0	1.22	0	0.24	1 * (100 KVA (3 Ph)) + 1 * (63 KVA (3 Ph))	2
			Pachim ka Pura	193694-012	0	1.9	0	0.28	1 * (63 KVA (3 Ph))	1

Existing Habitation Wise Infrastructure

State : UTTAR PRADESH
District : Azamgarh

Sl.No. (Vill.)	Name of Village (all villages as per census)	Census Code (2011)	Name of Habitation including main villages	Habitation Code	Existing LT Networks (in Kms)				Existing Distribution Transformers (DT)	Total (DT)
					Overhead	AB cable	Overhead	AB cable		
1	2	3	4	5	6	7	8	9	10	11
			Chayana	193694-013	0	2.42	0	0.34	1 * (100 KVA (3 Ph)) + 1 * (63 KVA (3 Ph))	2
			Mafi harijan basti	193694-014	0	0.12	0	0		0
			Chiryawan ka Pura	193694-016	0	1.04	0	0.22	1 * (25 KVA (3 Ph))	1
			Kunhar Basti	193694-017	0	1.21	0	0		0
			Purab ki Harijan	193694-018	0	1.34	0	0.21	1 * (25 KVA (3 Ph))	1
			Mari mayan Harijan Basti	193694-019	0	1.2	0	0		0
			Bdhai ka Pura	193694-020	0	1.1	0	0		0
Total - Palhani					0	11.55	0	1.29		
Block :: Palhna										
1	Lahuwa Khurd	195593	CHIRAJPUR	195593-017	0	1.4	0	0.26	1 * (25 KVA (3 Ph))	1
			LATEHARA	195593-019	0	0.65	0	0		0
			MADYA RAJBHAR BASTI	195593-022	0	1.32	0	0		0
			MADYA KOHRANA	195593-023	0	0.24	0	0		0
Total - Palhna					0	3.61	0	0.26		
Summary										
Atraulia					0	8.82	0	2.4		
Palhani					0	11.55	0	1.29		

Existing Habitation Wise Infrastructure

State : UTTAR PRADESH
District : Azamgarh

Sl.No. (Vill.)	Name of Village (all villages as per census)	Census Code (2011)	Name of Habitation including main villages	Habitation Code	Existing LT Networks (in Kms)				Existing Distribution Transformers (DT)	Total (DT)
					Overhead	AB cable	Overhead	AB cable		
1	2	3	4	5	6	7	8	9	10	11
Palhna					0	3.61	0	0.26		
Grand Total					0	23.98	0	3.95		

Village Wise/Habitation Proposed Works

State : UTTAR PRADESH
District : Azamgarh

Sl.No. (Vill.)	Name of Village (all villages as per census)	Census Code (2011)	Name of Habitation including main villages	Habitation Code	Works Type	Item	Line Length(Kms)	DTR(Nos)	Earthing(Kms)		
1	2	3	4	5	6	7	8	9	10		
Block :: Atraulia											
1	Lohra	191955	Bharsani Purva	191955-009	New 11 KV Line	11KV Weasel Conductor	0.23	0	0		
						25 KVA (3 Ph)	0	1	0		
					New ABC Line	2X25+1X16	0.17	0	0		
						3X50+1X35+1X16	0.1	0	0		
					Dharwa Yadav Basti	191955-010	New 11 KV Line	11KV Weasel Conductor	0.17	0	0
								25 KVA (3 Ph)	0	1	0
			New ABC Line	2X25+1X16			0.2	0	0		
				3X50+1X35+1X16			0.18	0	0		
			Dharwa Harijan Basti	191955-011	New 11 KV Line	11KV Weasel Conductor	0.21	0	0		
						25 KVA (3 Ph)	0	1	0		
					New ABC Line	2X25+1X16	0.19	0	0		
						3X50+1X35+1X16	0.15	0	0		
			Dharwa Thakur Basti	191955-012	New 11 KV Line	11KV Weasel Conductor	0.22	0	0		
						25 KVA (3 Ph)	0	1	0		
					New ABC Line	2X25+1X16	0.18	0	0		
						3X50+1X35+1X16	0.16	0	0		
			Thakurpur Nishad Basti	191955-013	New 11 KV Line	11KV Weasel Conductor	0.23	0	0		
						25 KVA (3 Ph)	0	1	0		

Village Wise/Habitation Proposed Works

State : UTTAR PRADESH
District : Azamgarh

Sl.No. (Vill.)	Name of Village (all villages as per census)	Census Code (2011)	Name of Habitation including main villages	Habitation Code	Works Type	Item	Line Length(Kms)	DTR(Nos)	Earthing(Kms)
1	2	3	4	5	6	7	8	9	10
					New ABC Line	2X25+1X16	0.16	0	0
						3X50+1X35+1X16	0.13	0	0
			Lohra Harijan Basti	191955-016	New 11 KV Line	11KV Weasel Conductor	0.19	0	0
						25 KVA (3 Ph)	0	1	0
					New ABC Line	2X25+1X16	0.17	0	0
						3X50+1X35+1X16	0.15	0	0
			Pikkia nala ke kinare Harijan Basti	191955-019	New 11 KV Line	25 KVA (3 Ph)	0	1	0
					New ABC Line	2X25+1X16	0.2	0	0
						3X50+1X35+1X16	0.16	0	0
			Pikkia nala ke Kinare Nishad Basti	191955-020	New 11 KV Line	25 KVA (3 Ph)	0	1	0
					New ABC Line	2X25+1X16	0.18	0	0
						3X50+1X35+1X16	0.16	0	0
			Dhihwa	191955-021	New 11 KV Line	11KV Weasel Conductor	0.23	0	0
						25 KVA (3 Ph)	0	1	0
					New ABC Line	2X25+1X16	0.21	0	0
						3X50+1X35+1X16	0.18	0	0
			Kariwa Tar Nishad Basti	191955-022	New 11 KV Line	11KV Weasel Conductor	0.24	0	0
						25 KVA (3 Ph)	0	1	0

Village Wise/Habitation Proposed Works

State : UTTAR PRADESH
District : Azamgarh

Sl.No. (Vill.)	Name of Village (all villages as per census)	Census Code (2011)	Name of Habitation including main villages	Habitation Code	Works Type	Item	Line Length(Kms)	DTR(Nos)	Earthing(Kms)
1	2	3	4	5	6	7	8	9	10
					New ABC Line	2X25+1X16	0.16	0	0
						3X50+1X35+1X16	0.13	0	0
Block :: Palhani									
2	Tamauli	193694	Purab ka Pura	193694-011	New 11 KV Line	11KV Weasel Conductor	0.15	0	0
						25 KVA (3 Ph)	0	1	0
					New ABC Line	3X50+1X35+1X16	0.12	0	0
						2X25+1X16	0.17	0	0
			Pachim ka Pura	193694-012	New 11 KV Line	11KV Weasel Conductor	0.17	0	0
						25 KVA (3 Ph)	0	1	0
					New ABC Line	3X50+1X35+1X16	0.14	0	0
						2X25+1X16	0.18	0	0
			Chayana	193694-013	New 11 KV Line	11KV Weasel Conductor	0.24	0	0
						25 KVA (3 Ph)	0	1	0
					New ABC Line	3X50+1X35+1X16	0.11	0	0
						2X25+1X16	0.2	0	0
			Mafi harijan basti	193694-014	New 11 KV Line	11KV Weasel Conductor	0.22	0	0
						25 KVA (3 Ph)	0	1	0
					New ABC Line	3X50+1X35+1X16	0.14	0	0
						2X25+1X16	0.17	0	0
			Chiryawan ka Pura	193694-016	New 11 KV Line	11KV Weasel Conductor	0.25	0	0
						25 KVA (3 Ph)	0	1	0

Village Wise/Habitation Proposed Works

State : UTTAR PRADESH
District : Azamgarh

Sl.No. (Vill.)	Name of Village (all villages as per census)	Census Code (2011)	Name of Habitation including main villages	Habitation Code	Works Type	Item	Line Length(Kms)	DTR(Nos)	Earthing(Kms)
1	2	3	4	5	6	7	8	9	10
					New ABC Line	3X50+1X35+1X16	0.14	0	0
						2X25+1X16	0.2	0	0
			Kunhar Basti	193694-017	New 11 KV Line	11KV Weasel Conductor	0.18	0	0
						25 KVA (3 Ph)	0	1	0
					New ABC Line	3X50+1X35+1X16	0.08	0	0
						2X25+1X16	0.15	0	0
			Purab ki Harijan	193694-018	New 11 KV Line	11KV Weasel Conductor	0.21	0	0
						25 KVA (3 Ph)	0	1	0
					New ABC Line	3X50+1X35+1X16	0.1	0	0
						2X25+1X16	0.14	0	0
			Mari mayan Harijan Basti	193694-019	New 11 KV Line	11KV Weasel Conductor	0.11	0	0
						25 KVA (3 Ph)	0	1	0
					New ABC Line	3X50+1X35+1X16	0.1	0	0
						2X25+1X16	0.18	0	0
			Bdhai ka Pura	193694-020	New 11 KV Line	11KV Weasel Conductor	0.23	0	0
						25 KVA (3 Ph)	0	1	0
New ABC Line	3X50+1X35+1X16	0.12			0	0			
	2X25+1X16	0.16			0	0			
Block :: Pahlua									
3	Lahuwa Khurd	195593	CHIRAJPUR	195593-017	New 11 KV Line	11KV Weasel Conductor	0.34	0	0

Village Wise/Habitation Proposed Works

State : UTTAR PRADESH
District : Azamgarh

Sl.No. (Vill.)	Name of Village (all villages as per census)	Census Code (2011)	Name of Habitation including main villages	Habitation Code	Works Type	Item	Line Length(Kms)	DTR(Nos)	Earthing(Kms)
1	2	3	4	5	6	7	8	9	10
						25 KVA (3 Ph)	0	1	0
					New ABC Line	2X25+1X16	0.16	0	0
						3X50+1X35+1X16	0.13	0	0
			LATEHARA	195593-019	New 11 KV Line	11KV Weasel Conductor	0.24	0	0
						25 KVA (3 Ph)	0	1	0
					New ABC Line	2X25+1X16	0.19	0	0
						3X50+1X35+1X16	0.13	0	0
			MADYA RAJBHAR BASTI	195593-022	New 11 KV Line	11KV Weasel Conductor	0.25	0	0
						25 KVA (3 Ph)	0	1	0
					New ABC Line	2X25+1X16	0.19	0	0
						3X50+1X35+1X16	0.1	0	0
			MADYA KOHANA	195593-023	New 11 KV Line	11KV Weasel Conductor	0.34	0	0
						25 KVA (3 Ph)	0	1	0
					New ABC Line	2X25+1X16	0.17	0	0
						3X50+1X35+1X16	0.13	0	0
Block Wise Summary									
1	Atraulia				New 11 KV Line	11KV Weasel Conductor	1.72	0	0
						25 KVA (3 Ph)	0	10	0
					New ABC Line	2X25+1X16	1.82	0	0
						3X50+1X35+1X16	1.5	0	0

Village Wise/Habitation Proposed Works

State : UTTAR PRADESH
District : Azamgarh

Sl.No. (Vill.)	Name of Village (all villages as per census)	Census Code (2011)	Name of Habitation including main villages	Habitation Code	Works Type	Item	Line Length(Kms)	DTR(Nos)	Earthing(Kms)
1	2	3	4	5	6	7	8	9	10
2	Palhani				New 11 KV Line	11KV Weasel Conductor	1.76	0	0
						25 KVA (3 Ph)	0	9	0
					New ABC Line	3X50+1X35+1X16	1.05	0	0
						2X25+1X16	1.55	0	0
3	Palhna				New 11 KV Line	11KV Weasel Conductor	1.17	0	0
						25 KVA (3 Ph)	0	4	0
					New ABC Line	2X25+1X16	0.71	0	0
						3X50+1X35+1X16	0.49	0	0
District Wise Summary									
1	New 11 KV Line					11KV Weasel Conductor	4.65	0	0
						25 KVA (3 Ph)	0	23	0
2	New ABC Line					2X25+1X16	4.08	0	0
						3X50+1X35+1X16	3.04	0	0